

KRN 3 & 4 FSAR

1. INTRODUCTION AND GENERAL DESCRIPTION OF PLANT

1.1 INTRODUCTION

This Final Safety Analysis Report (FSAR) is submitted in support of the application of the Korea Hydro & Nuclear Power Company(KHNP) to obtain an operating license for the Kori Nuclear units 3 and 4 (KRN 3 & 4).

1.1.1 THE KORI NUCLEAR UNITS 3 AND 4

Unit 3 and Unit 4 each consist of a pressurized water reactor, a turbine generator, and associated auxiliaries. The two units are virtually identical with a limited number of shared facilities. Kori Nuclear Units 3 and 4 will hereafter be referred to as the facility.

The facility is located at the Kori Nuclear Power Plant site which is on the southeastern coast of the Korean peninsula approximately 16 miles south of Ulsan and 20 miles northeast of Pusan.

The containment for the nuclear steam supply system (N3SS) is a dry, prestressed concrete, steel-lined structure which is designed by Overseas Bechtel, Incorporated (Bechtel).

The N3SS is manufactured by the Westinghouse Electric Corporation (Westinghouse). The N3SS is a pressurized water reactor (PWR) type.

The reactor core is designed for a thermal output of 2900 MWt. When the reactor coolant pumps heat input of 12 MWt is added to the core output, the resulting warranted N3SS output is 2912 MWt, which is defined as the rated power in the license application.

The turbine generator is rated for operation at the N3SS warranted output of 2912 MWt with a corresponding electrical output of 1033.2 MWe. This corresponds to a net electrical output for each unit of 953.2 MWe. The turbine is supplied by General Electric Company of England (GEC) and the generator is supplied by Hitachi Ltd. Power & Industrial systems.

The date of completion of construction and initiation of fuel loading at Unit 3 is anticipated to be April 1984 and the date of commercial operation is anticipated to be October 1984. The construction completion date and commercial operation date for Unit 4 are anticipated to be April 1985 and October 1985, respectively.

## INTRODUCTION

### 1.1.2 THE FINAL SAFETY ANALYSIS REPORT

#### 1.1.2.1 Organization and Format

This FSAR for the KNU 5 & 6 adheres to Regulatory Guide 1.70, Standard Format and Content of Safety Analysis Reports for Nuclear Power Plants, Revision 2, prepared by the Regulatory Staff of the U.S. Nuclear Regulatory Commission (USNRC) and issued in September 1975.

the FSAR is paginated to provide flexibility when incorporating changes to text and figures. All text pages are numbered by section; e.g., 1.1-1 is the first page of section 1.1. Tables and figures are also numbered in a similar manner; e.g., table 1.1-1 is the first table in section 1.1., and they are placed at the end of the section. In some cases, appendices are included at the end of a chapter of the FSAR to provide supplemental information.

Topical reports and other documents referenced in the text are listed at the end of each section. Topical reports and other documents incorporated into the application by reference are also listed in section 1.6, Material Incorporated by Reference.

- Delete -

Standards used for abbreviations and symbols are the latest editions of the following American National Standards Institute publications: ANSI-Y1.1, Abbreviations; ANSI-Y10.19, Letter Symbols for Units Used in Science and Technology; and ANSI-Y10.5, Letter Symbols for Quantities Used in Electrical Science and Electrical Engineering. Abbreviations used in this FSAR are defined as they first occur.

When additional or revised information is incorporated in this FSAR, those pages affected will be identified with the amendment number in the lower corner of the margin opposite the binding margin, and the amendment date in the lower corner of the binding margin. A vertical line with the amendment number is placed in the binding margin next to the material affected.

#### 1.1.2.2 Approach to Design Bases

As used within this FSAR, the design bases are a list of requirements that the system must meet in order to:

- A. Perform directly a specific safety or power generation function, including support of another system in

## INTRODUCTION

performance of its required function; e.g., provide cooling water flow for other components, maintain a given compartment temperature, etc.

- B. Comply with a regulatory or statutory requirement or guideline; e.g., a regulatory guide or a jurisdictional building code.
- C. Meet a specific operator interface, startup, or important or specific testing requirement.
- D. Meet a design classification or code requirement; e.g., be designed to withstand the safe shutdown earthquake (SSE).

In effect, the design bases for a system are determined by assessment of the characteristics the system must have due to requirements imposed by other systems, regulations, guidelines, or other factors separate and distinct from the components of the system itself. The system itself is thought of as a unit, the boundaries of which are defined by Regulatory Guide 1.70, and which must meet specific requirements. The design bases should describe all essential characteristics of the system with sufficient clarity so that an experienced engineer, using these design bases and material referenced in the design bases, can understand the functions of the system with respect to the rest of the plant. Items implicit to contemporary design; e.g., use of the English system of weights and measures or the exercise of good engineering practice, are not specified.

### 1.1.2.2.1 Safety Design Bases

Safety design bases are those engineering objectives which directly establish or increase nuclear safety. Specifically, safety design bases provide for, or assure, the following:

- A. The integrity of the reactor coolant pressure boundary (RCPB)
- B. The capability to shut down the reactor and maintain it in a safe shutdown condition
- C. The capability to prevent or mitigate the consequences of accidents that could result in potential offsite radiation exposures comparable to the guideline exposures of Title 10, U.S. Code of Federal Regulations, Part 100 (10 CFR 100)
- D. The accomplishment of a specifically articulated requirement for structures, systems, or components important to safety.

## INTRODUCTION

The control room operator is considered as one of the fundamental means of achieving these criteria.

Safety-related equipment or structures, systems, and components important to safety means the portions of systems which are indispensable to nuclear safety. Items that are associated with safety-related equipment, but which in themselves are not absolutely essential to a nuclear safety function, are not safety-related.

Redundancy requirements and system performance conditions are considered a feature of the equipment's capability to shut down the reactor safely, or to prevent or mitigate accidents.

### 1.1.2.2.2 Power Generation Design Bases

Power generation design bases are those design bases which are not related to nuclear plant safety. They are called power generation design bases because they necessarily relate directly or indirectly to power generation, in the sense that all station requirements which are not imposed for safety reasons support the major function of the station as a whole; i.e., the generation of electrical power. An example of a power generation design basis is the requirement to provide domestic water for plant personnel.

### 1.1.2.3 Drawings

Drawings are included throughout this FSAR with the appropriate system descriptions. Symbols and abbreviations used on Bechtel- and Westinghouse-designed flow diagrams and piping and instrumentation diagrams (P&IDs) are shown in figures 1.1-1 and 1.1-2, respectively. Tables 1.7-1 and 1.7-2 provide cross references between FSAR figure numbers and drawing numbers to facilitate the identification of pertinent material.

### 1.1.2.4 Definition

ITS is an acronym of 'Improved Technical Specification', "운영기술지침서" in Korean, which is used in FSAR as follows:


- a. ITS Chapter 1 3.4 is 운영기술지침서 제1편 3.4
- b. ITS Chapter 1 Table 3.3.1-1 is 운영기술지침서 제1편 Table 3.3.1-1

ITS Base is "운영기술지침서 기술배경서", used as follows:


- a. ITS Base B 3.4 is 운영기술지침서 기술배경서 B 3.4

357





500





Amendment 539  
2015. 11. 19



KOREA HYDRO & NUCLEAR POWER  
COMPANY KORI 3 & 4 FSAR

SYMBOLS & LEGEND  
BOP FLOW DIAGRAMS AND  
P&I DIAGRAMS  
(SHEET 2 OF 3)  
Figure 1.1-1



 **KOREA ELECTRIC POWER CORPORATION**  
**KOREA NUCLEAR UNITS 5 & 6**  
**FSAR**

**SYMBOLS & LEGEND**  
**BOP FLOW DIAGRAMS AND**  
**P&I DIAGRAMS**  
**(Sheet 3 of 3)**

**Figure 1.1-1**



KOREA ELECTRIC POWER CORPORATION  
KOREA NUCLEAR UNITS 5 & 6  
FSAR

NSSS FLOW DIAGRAM  
LEGEND

Figure 1.1-2



## KNU 5 & 6 FSAR

### 1.2 GENERAL PLANT DESCRIPTION

#### 1.2.1 SITE DESCRIPTION

##### 1.2.1.1 Site Location

The Kori site is on the southeastern coast of the Korean peninsula 16 miles south of Ulsan and 20 miles northeast of Pusan at the village of Kori on a point known as Kodang-Mal. The approximate coordinates are

Figure 1.2-3 shows the general location of the station.

The Kodang-Mal point is approximately one-half-mile wide and extends southward about one-half mile from the main coastline. The Kori Nuclear Power Station is located at the southern tip of the point. The topography of the point is typical of the area topography which is characterized by mountains and valleys and a fairly sheer coastline. Elevations in the site region range from about 20 feet above msl to 262 feet above msl at the exclusion boundary. In grading the site to provide level areas for the plant structures, the cut was used as fill to form a strip at the end of the point 3575 feet long by 900 feet wide. Units 1 and 2 are located on the western section of the strip at elevation 20 feet while Units 5 and 6 are on the eastern section of the strip at elevation 31 feet. The Kori 345kV switchyard is located north-west of the strip at elevation 248 feet.

532

##### 1.2.1.2 Geology

Geologically, the site lies within the Cretaceous-aged Milyang basin and has an extremely complex geologic structure. On an areal basis, almost all of the site is underlain by ancient sedimentary rock formations which have been folded and faulted. The rock layers and faults are intersected and intruded by many igneous intrusive dykes. No area within the plant site is free of faults or dykes.

The faults and dykes are ancient features which have not moved in at least 10 to 15 million years and do not form a major fault system. Although the area is inactive seismically, earthquakes, ranging in intensity to a maximum of JMA (Japan Meteorological Agency Scale) IV to V, have occasionally been reported within the site region. At the site area, the maximum historical intensity of an earthquake has been estimated at JMA III.

The Kodang-Mal Point is surrounded by a narrow, irregular, gravelly and rocky beach which gives way to a sandy beach along the northwest shore at the villages of Kilchon-Ri and

Amendment 532

1.2-1

2015. 09. 15

GENERAL PLANT  
DESCRIPTION

Wolnae-Ri. At a distance of 60 to 90 feet inland from the shoreline, the topography rises abruptly to about 26 feet above sea level and then flattens somewhat, but continues to rise northward across the site. At about 65 feet elevation, the surface grade increases and continues to rise northward until it reaches the crest of a steep hill at 285 feet above sea level. The small but prominent bluff which parallels the shoreline is cut at several locations by minor surface drainage.

#### 1.2.1.3 Meteorology

The site is on the southeast coast of Korea and the climate can be described as continental in nature during the winter season. The strong summer weather systems are influenced primarily by tropical air masses from the south-southwest, while in the winter season, the weather is influenced by polar continental air masses.

Snow is uncommon during winter, with an estimated annual accumulation of 30 cm/y. Precipitation during the winter months occurs principally as rain on the southeast coast. Heavy precipitation occurs during the summer months and is most often associated with the passage of typhoons and tropical storms which occur primarily in the months of May through September.

An average of two typhoons a year come close enough to the coast to affect Korea. These typhoons usually bring torrential rainfall which, combined with high tides, results in flood conditions for low-lying areas along the coast. However, less than one typhoon actually crosses the Korean coast.

Average annual rainfall is 1300 mm with 40 to 50 percent of the rainfall occurring during the months of June through August. Maximum hourly rainfall is 68 to 71 mm. Flooding will not occur at the site because of its location and topographical features.

The high that develops off the Pacific Ocean during the summer season results in a moist southerly flow of air from the South Sea to the site region.

During the winter season, a semi-permanent high pressure cell develops over the central region of Mongolia, resulting in a prevailing northwesterly flow of air into the site area. The mean annual wind speed for the Pusan area is 4.4 m/s. The mean annual wind speed for the Ulsan area and the site area is 2.7 m/s and 3.6 m/s respectively.

GENERAL PLANT  
DESCRIPTION

The maximum recorded temperature was 38C at Ulsan. The record minimum was -16.7C. The normal annual relative humidity from Pusan and Ulsan is 66 percent and 71 percent respectively.

The recorded highest temperature was 33.5C at the site.

#### 1.2.1.4 Hydrology

The KNU 5 & 6 site is on the southeastern coast of Korea, approximately 32 kilometers northeast of Pusan.

High and low water levels, as indicated by the land datum, are as follows:

Highest high-water level	+ 1.133 m
High water level	+ 0.705 m
Mean water level	+ 0.309 m
Low water level	- 0.087 m
Lowest low-water level	- 0.497 m

#### 1.2.1.5 Population Distribution

The 1981 residential population within 16 kilometers of the site was 128,225. This is shown in table 1.2-1 and figure 1.2-1. About 42,190 people live within 8 kilometers of the site.

The area within 16 kilometers of the plant site is predominantly rural and is characterized by mountains and hills, interspersed with farmlands. The 1981 residential population between 16 kilometers and 80 kilometers of the site was 5,660,600. This is shown in table 1.2-2 and figure 1.2-2.

Population densities vary by sectors; relatively higher density sectors are found in the southwestern sectors bordering the seashore.

## KNU 5 & 6 FSAR

### GENERAL PLANT DESCRIPTION

#### 1.2.2 PLANT ARRANGEMENT

The Korea Nuclear Units 5 and 6 (KNU 5 & 6) are comprised of two pressurized water reactor nuclear steam supply systems (NSSS) that will have a production per unit of 993 MWe at maximum core power. The station features separate containment, auxiliary, control and component cooling water buildings, turbine buildings, diesel generator buildings, fuel storage buildings, auxiliary buildings, and shared intake structure, radwaste building, auxiliary boiler, and material storage facilities. The ultimate heat sink for all Seismic Category I cooling water systems is salt water from the East Sea, supplied to the component cooling water heat exchangers by nuclear service cooling water pumps located within the intake structure. Seawater pumped from the intake structure by the circulating water pumps serves as the heat sink for the heat rejected by the main condensers and the turbine plant cooling water system. The turbine generator orientation with respect to the containment is peninsular and the two units are in a slide-along orientation. The Kori 345 kV switchyard is located north-west of the two units. The plant arrangement is presented in figures 1.2-3 through 1.2-16.

532

#### 1.2.3 NUCLEAR STEAM SUPPLY SYSTEM

For each unit, the NSSS consists of a pressurized water reactor (PWR), reactor coolant system (RCS), and associated auxiliary systems. The RCS (figure 1.2-17) is arranged as three reactor coolant loops connected in parallel to the reactor vessel, each containing a reactor coolant pump and a steam generator. An electrically heated pressurizer is connected to the hot leg of one reactor coolant loop.

High pressure water circulates through the reactor core to remove the heat generated by the nuclear chain reaction. The heated water exits from the reactor vessel and passes via the coolant loop piping to the steam generator. Here it gives up its heat to the feedwater to generate steam for the turbine generator. The cycle is completed when the water is pumped back to the reactor vessel. The entire RCS is composed of leaktight components to ensure that all fluids are confined to the system.

The core is of the multi-region type. All fuel assemblies are mechanically identical, although the fuel enrichment is not the same in all assemblies. In the initial core loading, three fuel enrichments are used. Thirty-six fuel assemblies with the highest enrichment and sixteen assemblies with the second highest enrichment are placed in the core periphery, or outer region. The other sixteen assemblies with the highest enrichment are located inboard on the core diagonals. Thirty-six assemblies with the second highest enrichment and



GENERAL PLANT  
DESCRIPTION

fifty three assemblies with the lowest enrichment are arranged in a selected pattern in the central region (see figure 4.3-1). In subsequent refuelings, approximately one-third of the fuel is discharged and fresh fuel is loaded into the core. The remaining fuel is arranged in the core in such a manner as to achieve optimum power distribution.

Rod cluster control assemblies (RCCAs) are used for reactor control and consist of clusters of cylindrical absorber rods. The absorber rods move within guide tubes in certain fuel assemblies. Above the core, each cluster of absorber rods is attached to a spider connector and drive shaft, which is raised and lowered by a drive mechanism mounted on the reactor vessel head. Following trip, downward movement of the rod cluster control is by gravity.

The reactor coolant pumps are Westinghouse vertical, single-stage, centrifugal pumps of the shaft-seal type.

The steam generators are Westinghouse vertical U-tube units which contain Inconel tubes. Integral moisture separation equipment reduces the moisture content of steam to 0.25 percent or less.

The reactor coolant piping and all of the pressure-containing and transfer surfaces in contact with reactor water are stainless steel clad, except the steam generator tubes which are Inconel and the fuel tubes which are Zircaloy. Reactor core internals, including control rod drive shafts, are primarily stainless steel.

An electrically heated pressurizer connected to one reactor coolant loop maintains RCS pressure during normal operation; limits pressure variations during plant load transients and keeps system pressure within design limits during abnormal conditions.

Auxiliary system components are provided to charge the RCS and add makeup water, purify reactor coolant water, provide chemicals for corrosion inhibition and reactivity control, cool system components, remove decay heat when the reactor is shut down, and provide for emergency safety injection.

#### 1.2.3.1 Principal Design Criteria

The inherent design of the pressurized water, closed-cycle reactor significantly reduces the quantities of fission products which are released to the atmosphere. Four barriers exist between the fission product accumulation and the environment. These are the uranium dioxide fuel matrix, the fuel cladding, the reactor vessel and coolant loops, and the containment system. The consequences of a breach of the

KRN 3 & 4 FSAR

GENERAL PLANT  
DESCRIPTION

fuel cladding are greatly reduced by the ability of the uranium dioxide lattice to retain fission products. Escape of fission products through fuel cladding defects would be contained within the reactor pressure vessel, coolant loops, and auxiliary systems. Breach of these systems or equipment would release the fission products to the containment where they would be retained. The reactor containment is designed to adequately retain these fission products under the most severe accident conditions, as analyzed in chapter 15.

Design criteria are established to ensure the following:

- A. The minimum departure from nucleate boiling ratio during normal operation and anticipated operational occurrences which provides at least a 95% probability with 95% confidence that departure from nucleate boiling does not occur, is not less than the limit value described in Subsection 4.4.1.1.
- B. The maximum fuel centerline temperature evaluated at the design overpower condition is below that value which could lead to centerline fuel melting. The melting point of the UO<sub>2</sub> is not reached during normal operation and anticipated operational occurrences.
- C. Fuel rod clad is designed to maintain cladding integrity throughout fuel life. Fission gas release within the rods and other factors affecting fuel design life are considered for the maximum expected exposures.
- D. The reactor system is designed so that any xenon transients are adequately damped.
- E. The RCS is designed and constructed to maintain its integrity throughout the expected plant life. Appropriate means of test and inspection are provided.
- F. Power excursions that could result from any credible reactivity addition incident do not cause damage either by deformation or rupture of the pressure vessel, nor do they impair operation of the engineered safety features (ESF).
- G. The combined response of the fuel temperature coefficient, the moderator temperature coefficient, the moderator void coefficient, and the moderator pressure coefficient to an increase in reactor thermal power is a decrease in reactivity. In addition, reactor power transients remain bounded and damped in response to any expected change in any operating variable.

382

#### 1.2.3.2 Operating Characteristics

The reactor is controlled by temperature coefficients of reactivity; by control rod cluster motion, which is required for load follow transients and for startup and shutdown; and by the soluble neutron absorber, boron, in the form of boric acid. The boric acid is inserted during cold shutdown, is partially removed at startup, and is adjusted in concentration during core lifetime to compensate for such effects as fuel depletion and accumulation of fission products which tend to slow the nuclear chain reaction.

The control system allows the plant to accept step load increases of 10 percent and ramp load increases of 5 percent per minute over the load range of 15 to 100 percent of full power. Equal step and ramp load reductions are possible, over the range of 100 to 15 percent of full power.

Below 10 percent power, the unit can accept a turbine trip without initiating a reactor trip.

11

#### 1.2.3.3 Safety Considerations

Several ESFs have been incorporated into the plant design to reduce the consequences of a loss of coolant accident (LOCA). These safety features include a safety injection system which automatically delivers borated water to the reactor vessel for cooling the core under high and low reactor coolant pressure conditions. The safety injection system also serves to insert negative reactivity into the core in the form of borated water during an uncontrolled plant cooldown following a steam line break or an accidental steam release. Other safety features which have been included in the reactor containment design are a containment air recirculation and cooling system which acts to limit the containment pressure following a loss of coolant, and a containment spray system which acts to depressurize the containment and remove elemental iodine from the atmosphere.

The reactor is refueled by equipment which handles spent fuel under water from the time it leaves the reactor vessel until it is placed in a shipping cask for shipment from the site. Underwater transfer of spent fuel provides an economic and transparent radiation shield, as well as a reliable coolant for removal of decay heat.

GENERAL PLANT  
DESCRIPTION

The fuel handling system is divided into two areas: the refueling canal area, which is flooded for refueling; and the fuel pool, which is external to the containment and is always accessible to plant personnel. The two areas are connected by a fuel transfer system which carries the fuel through an opening in the containment.

Spent fuel is removed from the reactor vessel by a refueling machine and is placed in the fuel transfer system. In the fuel pool, the fuel is removed from the transfer system and is placed into storage racks. After a suitable decay period, the fuel is able to be removed from storage and loaded into a shipping cask for removal to a reprocessing plant.

Primary coolant leakage from the reactor vessel closure seals, pressure and relief valves, pump and relief valve seals, and other identified leakage sources of primary coolant are collected at the source and are piped to the equipment drain tank or pressurizer relief tank. This decreases the radioactivity released to the containment atmosphere and increases the sensitivity of detecting unidentified leakage.

The nuclear design analyses and evaluation establish physical locations for control rods and burnable poisons and physical parameters such as fuel enrichments and boron concentration in the coolant. The nuclear design evaluation established that the reactor core has inherent characteristics which, together with corrective actions of the reactor control and protective systems, provide adequate reactivity control even if the highest reactivity worth RCCA is stuck in the full withdrawn position.

The thermal-hydraulic design analyses and evaluation establish coolant flow parameters which assure that adequate heat transfer is provided between the fuel clad and the reactor coolant. The thermal design takes into account local variations in dimensions, power generation, flow distribution, and mixing. The mixing vanes incorporated in the fuel assembly spacer grid design induce additional flow mixing between the various flow channels within a fuel assembly as well as between adjacent assemblies.

Instrumentation is provided in and out of the core to monitor the nuclear, thermal-hydraulic, and mechanical performance of the reactor and to provide inputs to automatic control functions.



#### 1.2.4 ENGINEERED SAFETY FEATURES AND EMERGENCY SYSTEMS

Engineered safety features (ESFs) protect the public and plant personnel in the highly unlikely event of an accidental release of radioactive fission products from the reactor system, particularly as the result of a LOCA. These safeguards function to localize, control, mitigate, and terminate such accidents to hold exposure levels below 10 CFR 100 limits.

##### 1.2.4.1 Containment System

###### 1.2.4.1.1 Containment Building

The containment is a prestressed, reinforced concrete structure in the shape of a cylinder with a hemispherical roof and a flat foundation slab. The cylindrical portion of the containment structure is prestressed by a post-tensioning system consisting of horizontal (hoop) and vertical (inverted U) tendons. Hoop tendons are anchored at three buttresses equally spaced around the containment structure. These tendons extend 240 degrees around the cylinder periphery, bypassing intermediate buttresses. The dome has a two-way, post-tensioning system. Prestressing of the hemispherical dome is achieved by a two-way pattern of tendons that are a part of the vertical (inverted U tendons). The dome horizontal tendons start at the springline and continue up to the 45 degree line of the dome.

The foundation slab is conventionally reinforced with high-strength reinforcing steel. Near the outer edge of the foundation slab, a continuous access gallery is provided for installation and inspection of vertical tendons. The interior surface of the containment shell is steel-lined for leaktightness. A protective layer of concrete covers the portion of the liner over the foundation slab. The containment structure concrete provides biological shielding for normal and accident conditions.

The containment building completely encloses the reactor and RCS and is designed so that the leakage of radioactive materials to the environment will not exceed 0.1 percent volume in 24 hours, even in the unlikely event of a LOCA. The dimensions of the containment are as follows: inside diameter, 130 feet; inside height, 195 feet above filler slab; cylindrical wall nominal thickness, 4 feet, and minimum dome thickness at the top of the dome, 3 feet 2 inches. The net free volume is approximately 2,080,000 ft<sup>3</sup>. The internal structures and compartment arrangement provide equipment missile protection and biological shielding for maintenance personnel.

GENERAL PLANT  
DESCRIPTION

The containment building is designed for all credible loading combinations, including normal loads, loads during a LOCA, test loads, and loads due to adverse environmental conditions. The following are considered:

- A. Loads caused by the pressure and temperature transients due to accident conditions
- B. Dead loads
- C. Thermal Loads
- D. Live loads
- E. Earthquake loads
- F. Wind loads
- G. Typhoon loads
- H. External pressure loads
- I. Prestressing loads
- J. Missile impact loads

The containment building design pressure of 60 psig is greater than the peak pressure that would occur as a result of the pipe break accidents analyzed in subsection 6.2.1. Energy contribution from the steam system, due to reverse heat transfer through the steam generator tubes, is included in the calculation of the design containment pressure transient. The supports for the RCS are designed to withstand the forces associated with the sudden severance of the reactor coolant piping with coincidental earthquake. In addition, the containment design pressure will not be exceeded during any subsequent long term pressure transient as determined by the combined effect of heat sources such as residual heat and limited metal-water reactions, structural heat sinks, and the operation of the ESF using only emergency onsite electrical power.

The containment building is discussed further in section 6.2.

#### 1.2.4.1.2 Containment Spray System

The Containment Spray System (CSS) is provided to cool the atmosphere and reduce the pressure in the containment. It also provides chemical additive (sodium hydroxide) to remove iodine following a postulated LOCA. A common spray additive tank and

GENERAL PLANT  
DESCRIPTION

two 100 percent capacity spray subsystems are provided, each consisting of a pump, spray header, and spray additive eductor. The containment spray pumps take suction initially from refueling water storage tank. The spray additive eductor takes suction from the spray additive tank.

The containment spray system is further discussed in sub-sections 6.2.2 and 6.5.2

1.2.4.1.3 Containment Atmosphere Emergency Cooling System

The containment atmosphere emergency cooling system (CAECS) is provided to cool the atmosphere and reduce the pressure in the containment. Four 100 percent atmosphere coolers are provided.

The containment atmosphere emergency cooling system is further discussed in section 6.2.

1.2.4.2 Emergency Core Cooling System (ECCS)

The principal ECCS mechanical components which provide core cooling immediately following a LOCA are the accumulators (one for each reactor coolant loop), the centrifugal charging (high head safety injection) pumps, the residual heat removal (low head safety injection) pumps, and the associated valves, tanks, and piping.

In order that fuel rod damage, to the extent that it would impair effective cooling of the core, is prevented, the ECCS is designed to cool the reactor core and to provide additional shutdown capability following initiation of the following accident conditions:

- A. Pipe breaks and valve failures in the RCS which cause a discharge larger than that which can be made up by the normal makeup system, up to and including the instantaneous circumferential rupture of the largest pipe in the RCS.
- B. Rupture of a control rod drive mechanism (CRDM) causing a control rod assembly ejection accident.
- C. Pipe breaks and valve failures in the steam system, up to and including the instantaneous circumferential rupture of the largest pipe in the steam system.
- D. A steam generator tube rupture.

GENERAL PLANT  
DESCRIPTION

The acceptance criteria for the consequences of each of these accidents is described in chapter 15 in the respective accident analyses sections.

In order to ensure that the ECCS will perform its desired function during the accidents listed above, it is designed to tolerate a single active failure during the short term immediately following an accident, or to tolerate a single active or passive failure during the long term following an accident.

In the highly unlikely event of a LOCA, the centrifugal charging pumps and the residual heat removal pumps take suction from the refueling water storage tank and inject borated water into the RCS. This provides cooling to limit core damage and fission product release and ensures adequate shutdown margin. After the inventory of coolant in the refueling water storage tank is completely depleted, the borated water in the containment sump is recirculated through the residual heat removal heat exchangers and the reactor core to provide long term cooling of the core.

#### 1.2.4.3 Emergency Electrical Systems

##### 1.2.4.3.1 Standby Power Supply

A diesel generator, complete with accessories, fuel transfer systems, and fuel storage system is provided as the standby power supply for all of the equipment of each of the two redundant ESF trains for each unit. Each diesel generator is rated at 7000 kW for continuous operation and 7700 kW for short time operation at 4.16 kV, 60 Hz. There are a total of four diesel generators for KNU 5 & 6.

Two independent and redundant air starters, actuated by air at 200 to 250 psig, are used to provide the torque to automatically start each diesel generator upon receipt of either an ESF actuation signal or an unacceptable degradation of the voltage on the 4.16 kV Class 1E bus to which the generator is connected. Each diesel generator is able to accept loads in approximately 10 seconds after the receipt of a starting signal and complete the starting sequence for all required safety-related equipment within 60 seconds thereafter.

A 7-day onsite inventory of fuel oil is provided for each diesel generator. Oil is transferred from the underground cylindrical storage tank to the day tank by redundant transfer pumps with the excess flow being returned to the storage tank.



GENERAL PLANT  
DESCRIPTION

The heat of combustion is transferred from the engine cylinder liners, the fuel injectors, the lubrication system, and the intercooler by a closed cycle cooling water system heat exchanger to the nuclear services cooling water system. The cooling water is circulated by a pump driven by the diesel engine.

Ventilation and combustion air for each diesel generator room is provided by two 50 percent capacity, direct drive, vaneaxial exhaust fans at a total flowrate of 150,000 cfm and a static pressure of 1.0 in. wg. When the diesel is not operating, the ventilation flowrate is 6300 cfm, which is provided by a direct drive, vaneaxial exhaust fan.

1.2.4.3.2 Emergency Lighting System

The emergency lighting system provides an adequate amount of dc lighting in the areas used during shutdown or emergency. These areas include the main control room, the auxiliary shutdown panels, and local control stations required to shut down and maintain the plant in a hot shutdown condition from outside the control room.

In other critical areas and emergency exit corridors where the minimum illumination required for the safety of plant personnel is furnished. The dc lighting consists of strategically located and seismically qualified portable battery pack units. The fixtures are designed to provide rated lighting for a minimum continuous period of 8 hours.

1.2.4.4 Fire Protection System

Fire protection is achieved at the station through the application of fire prevention, fire detection, and fire extinguishment methodologies.

Noncombustible and heat resistant materials are used in the station construction to minimize the potential for the occurrence of fires and to limit the flame intensity if a fire should occur. Sufficient separation between the components of redundant safety systems is provided to maintain the integrity of at least one of the systems so that the plant may be shut down safely. Where sufficient separation cannot be achieved, fire barriers are used between the two safety systems to ensure system integrity.

A combination of fire and smoke detection equipment is used throughout the station to detect the occurrence and location of a fire. Ionization chambers are used to detect combustion

GENERAL PLANT  
DESCRIPTION

products. Photoelectric cells and ionization chambers are used to detect smoke. Infrared sensors are used to detect the presence of heat and flames. Heat actuated devices are used to detect the energy released by the fire. The selection of a sensor for a specific application is determined by an evaluation of the fire potential for each area of the station.

The fire extinguishment systems include at least the following major features:

- A. Fire protection water supplies, yard mains, hydrants, and valves
- B. Automatic wet sprinklers, hydraulically designed, ordinary hazard schedule
- C. Water spray systems, hydraulically designed
- D. Automatic pre-action sprinklers, ordinary hazard
- E. Standpipes and hose reels
- F. Portable extinguishers

The water inventory in the two 435,000 gallon storage tanks is delivered to the sprinkler, spray, and standpipe systems by two 1500 gpm automatic diesel engine-driven and one 1500 gpm motor-driven fire pump at a pump discharge pressure of 125 psig. Through the use of main loops, each branch is provided with two sources of water.

Selected components of the fire protection system are designed to meet Seismic Category I criteria in order to provide manual fire fighting capability in safety-related areas in the event of safe shutdown earthquake. This system is designed to supply water from Seismic Category I Condensate Storage Tanks to at least two standpipes and hose connections in areas containing equipment required for safe shutdown.

The fire and smoke monitoring, detection, and alarm system includes a supervisory circuit which indicates the failure of individual circuits and detectors. Both monitoring and supervisory alarm signals register locally and on the audible-visual fire annunciator panel in the control room.

#### 1.2.4.5 Control Room Emergency HVAC System

The control room emergency HVAC system is designed to maintain the control room habitable during the postulated conditions resulting from a hypothetical LOCA, a fuel handling accident, or any other occurrence generating high level airborne radioactivity at the control room air intake.

GENERAL PLANT  
DESCRIPTION

The emergency HVAC system consists of two redundant trains whose major components include a supply/recirculation air handling unit and a filtration train. Upon receipt of an ESF actuation signal, fuel building high airborne radiation signal, or control room outside air intake high radiation signal, the control room emergency HVAC system is automatically started. The emergency HVAC system may also be initiated manually from the control room.

Transfer to the emergency mode consists of isolating the habitability area from the normal HVAC system, opening the outside air isolation valve to the emergency filtration trains, and starting the fans in the emergency filtration train and in the emergency supply/recirculation unit. Should, for some reason, the self-closing doors to the control room be prevented from shutting, an alarm reminds the operator to shut them. The emergency train fan discharges into the emergency supply/recirculation air handling unit. Thus, the emergency train fan draws outside air through HEPA filters and carbon adsorbers and discharges into the control room; since there is no control room exhaust, the control room atmosphere exfiltrates to the outside of the control room.

Control room air is recirculated at a rate of 21,000 cfm through the emergency supply/recirculation air handling unit to be cooled. The processing of outside air through the emergency filtration train allows 1000 cfm of outside air to be introduced into the control room. The temperature of the control room is maintained between 68 and 78F.

In addition, 1000 cfm of the recirculated air is processed through the emergency filtration train to aid in the removal of particulates and iodines which have built up in the control room atmosphere.

#### 1.2.4.6 Containment Isolation System

The containment isolation system consists of the piping, valves, and actuators required to isolate the containment following a LOCA, steam line rupture, main feedwater line rupture, or fuel handling accident inside the containment.

Each line which penetrates the containment and is either a part of the reactor coolant pressure boundary, or is connected directly to the containment atmosphere and is not a closed system, is provided with one of the following containment isolation valve arrangements.

- A. One locked shut isolation valve inside and one locked shut isolation valve outside containment

GENERAL PLANT  
DESCRIPTION

- B. One automatic isolation valve inside and one locked shut isolation valve outside containment
- C. One locked shut isolation valve inside and one automatic isolation valve outside containment (a simple check valve is not used as the automatic isolation valve outside containment)
- D. One automatic isolation valve inside and one automatic isolation valve outside containment (a simple check valve is not used as the automatic isolation valve outside containment)

Isolation valves outside containment are located as close to the containment as practical and, upon loss of actuating power, air-operated automatic isolation valves fail shut.

Containment isolation during a LOCA is initiated in two phases, phase A and phase B. Phase A containment isolation occurs upon any one of the following conditions:

- A. Low pressurizer pressure
- B. High containment pressure (Hi-1)
- C. Low pressure steam line
- D. Manual safety injection signal (SIS) actuation
- E. Manual containment isolation actuation.

A phase A containment isolation signal isolates all process lines penetrating containment which do not increase the potential for damage of containment equipment when isolated and which are not required for operation of the ESF.

Phase B isolation is initiated upon sensing of containment high pressure (Hi-3). A phase B isolation signal isolates process lines penetrating containment which were not isolated during phase A and which are not required for operation of the ESF. These lines are those which supply cooling water and seal water flow to the reactor coolant pumps. Coincident with phase B isolation, the containment spray system is actuated.

Upon failure of a main steam line or main feedwater line, the containment isolation system isolates the containment and steam generators to prevent excessive cooldown of the RCS or overpressurization of the containment.



GENERAL PLANT  
DESCRIPTION

Steam line isolation is initiated upon receipt of one of the following signals:

- A. High steam pressure rate
- B. Low pressure steam line
- C. Containment high pressure (Hi-2)
- D. Manual actuation.

Upon initiation of steam line isolation, the main steam isolation valves and feedwater isolation valves are shut in order to prevent excessive cooldown of the RCS.

Feedwater line isolation is initiated upon receipt of one of the following signals:

- A. Low pressurizer pressure
- B. High containment pressure (Hi-1)
- C. Low pressure steam line
- D. Steam generator level Hi-Hi
- E. Manual SIS actuation.

Upon initiation of the feedwater isolation signal, the feedwater isolation valves are shut in order to prevent excessive cooldown of the RCS.

The main steam isolation valves and piping are designed to prevent uncontrolled blowdown from more than one steam generator. The main steam isolation valves will shut fully within 5 seconds after steam line isolation is initiated. The blowdown rate is restricted by steam flow restrictors in each steam generator. For main steam line breaks upstream of an isolation valve, uncontrolled blowdown from more than one steam generator is prevented by the isolation valves in the unaffected steam lines and by the isolation valve in the affected line. For main steam line breaks downstream of an isolation valve, double blowdown is prevented by the main steam isolation valves on each main steam line.

Failure of any of the above components relied upon to prevent uncontrolled blowdown of more than one steam generator will not permit a second steam generator blowdown to occur. Piping restraints and pipe whip barriers between the main steam lines prevent a rupture in one line from causing a blowdown from more than one steam generator. No single

GENERAL PLANT  
DESCRIPTION

active component failure will result in the failure of more than one main steam isolation valve to operate.

1.2.4.7 Combustible Gas Control System

A hydrogen recombiner system and a hydrogen purge system are used to control the concentration of hydrogen in the containment atmosphere to less than 3.5 percent following a postulated LOCA. Two independent, full capacity intake and return piping systems are provided at each unit, to which one or both of the mobile hydrogen recombiners that are shared by the two units may be connected within 24 hours after the start of the LOCA. The containment atmosphere is circulated through each recombiner at a rate of 70 cfm, which is sufficient to decrease the expected hydrogen concentration of 3.5 percent at 12 days after accident initiation to 3.3 percent at 20 days after accident initiation for the operation of one recombiner or to 2.6 percent for the operation of two recombiners.

If both of the mobile hydrogen recombiners should fail to perform their function, the hydrogen purge system may be valved into the recombiner intake piping system to provide a flow from the containment atmosphere of 50 cfm, which is compensated by a 50 cfm inflow from the compressed air system. The purge flow is passed through a mist eliminator, electrical heater, high efficiency air filter, a charcoal absorber, and a second high efficiency air filter prior to being released to the environment.

1.2.5 INSTRUMENTATION, CONTROL, AND ELECTRICAL SYSTEMS

1.2.5.1 Instrumentation and Control Systems

The reactor is controlled by temperature coefficients of reactivity; by control rod cluster motion, which is required for load follow transients and for startup and shutdown; and by a soluble neutron absorber. Boron in the form of boric acid which is inserted during cold shutdown, is partially removed at startup, and is adjusted in concentration during core lifetime to compensate for such effects as fuel consumption and accumulation of fission products which tend to slow the nuclear chain reaction.

The control system allows the plant to accept step load increases of 10 percent and ramp load increases of 5 percent per minute over the load range of 15 to 100 percent of full power. Equal step and ramp load reductions at 5 percent per minute are possible, over the range of 100 to 15 percent of full power.

GENERAL PLANT  
DESCRIPTION

Additional information on instrumentation and controls is presented in chapter 7.

1.2.5.1.1 Introduction

To preclude unsafe conditions for equipment or personnel, the plant protection system monitors selected plant parameters in order to initiate reactor trip and/or ESF actuation. Multiple independent channels monitor each of the selected plant parameters. The plant protection system logic is designed to initiate automatically protective action whenever the monitored parameters reach a limiting safety system setting. Redundancy is provided in all parts of the plant protection system to assure that no single failure will prevent protective action when it is required.

The plant protection system is designed in conformance with IEEE Standard 279, Criteria for Protection Systems for Nuclear Power Generating Stations.

Sufficient redundancy is installed to permit periodic testing of the plant protection system so that a single failure or removal from service of any one protection system component or portion of the system does not preclude protective actions when required.

1.2.5.1.2 Reactor Trip System Summary Description

The reactor trip system (RTS) includes the reactor protection system and the arrangement of components that perform the protective action after receiving a signal from the protection system or the licensed operator. The reactor trip signal deenergizes the control rod drive motor (CRDM) coils, allowing the RCCAs to drop into the core.

The instrumentation and controls of the RTS are specifically designed to permit on-line testing of the circuitry, down to the final actuating element, while the remaining portion of the system continues to conform to the single failure criteria. The instrumentation and controls are designed such that no single failure will initiate spurious reactor trip.

1.2.5.1.3 Engineered Safety Features System Instrumentation  
Summary Description

The ESF systems include the engineered safety features actuation system (ESFAS) and the arrangement of components that perform protective actions after receiving a signal from the ESFAS or the operator.

GENERAL PLANT  
DESCRIPTION

The instrumentation and controls of the ESF systems are designed to permit testing while retaining the required capability for accomplishing their protective functions. Independence of redundant instrumentation and controls is provided so that a single failure within the systems will not prevent the ESF systems from accomplishing their protective functions.

1.2.5.1.4 Systems Required for Safe Shutdown Instrumentation  
Summary Description

The systems required for safe shutdown (SRSS) are those systems which are required to shut down the reactor and maintain the reactor in a safe shutdown condition.

The instrumentation and controls of the SRSS are designed to permit testing while retaining the required capability for accomplishing their safe shutdown function.

Separation and independence of redundant instrumentation and controls is provided so that a single failure within the system will not prevent the SRSS from accomplishing their required functions.

1.2.5.1.5 Safety-Related Display Instrumentation Summary  
Description

The safety-related display instrumentation (SRDI) provides information to enable the operator to perform the required safety functions.

The instrumentation provided monitors conditions in the RCS, the containment, the process systems, the RTS, the ESF systems, and the systems required for safe shutdown throughout planned operations, anticipated operational occurrences, and accident and post-accident conditions.

1.2.5.2 Electrical Power Systems

1.2.5.2.1 Transmission and Generation Systems

The KEPCO grid system consists of interconnected hydroelectric plants, fossil fuel plants, and nuclear plants supplying electric energy over a system of 345 and 154 kV transmission lines and lower voltage distribution networks. The grid system is described in chapter 8.



## KNU 5 & 6 FSAR

### GENERAL PLANT DESCRIPTION

KEPCO provides all of the electric power in South Korea. No interconnections are made with any other utility.

The main generator is an 1800 rpm, three-phase, 60-hertz, synchronous unit. The generator is connected through a coupling to the turbine shaft.

360

Power from the generator is stepped up from 22 to 362 kV by the unit main transformers and is supplied by overhead lines to The Kori 345 kV switchyard to both units. This switchyard is connected to the offsite transmission network by eight 345 kV transmission lines.

532

#### 1.2.5.2.2 Electric Power Distribution Systems

Electric power is supplied from the switchyard to the onsite power system for the electrical auxiliaries of each unit through two independent circuits. Power is supplied to auxiliaries at 13.8 kV, 4.16 kV, and 480V levels.

The power distribution system includes Class 1E and non-Class 1E ac and dc power systems. The Class 1E power system supplies equipment used to shut down the reactor and limit the release of radioactive material following a design basis accident (DBA).

The Class 1E ac system for each unit consists of two independent and redundant load groups and four independent 120V vital ac instrumentation and control power supply systems. The load groups include 4.16 kV switchgear, 480V load centers and motor control centers (MCCs). The vital ac instrumentation and control power supply systems include battery systems, static inverters, regulating transformers, and distribution panels. Load group power voltage levels are designed for a range of plus/minus 10 percent. Vital ac instrumentation and control power systems are designed for a voltage range of plus/minus 2 percent. All equipment is furnished to be compatible with these voltage levels.

One independent diesel generator is provided as a standby source for each of the two Class 1E ac load groups of each unit. Each generator has sufficient capacity to operate all the equipment of one unit which is necessary to prevent undue risk to public health and safety in the event of a DBA.

One Non-Class 1E diesel generator which is in the independent AAC Building separated from the existing power blocks is provided as an alternate AC(AAC) source for common use of KORI Units 1,2,3 and 4 to cope with station blackout(SBO). This diesel generator is capable of supplying one division of shutdown loads of any Unit of KORI Units 1,2,3 and 4 which are required to bring the plant to hot shutdown mode and to maintain hot stand-by mode.

314

The non-Class 1E ac system includes 13.8 kV switchgear, 4.16 kV switchgear, 480V load centers, and MCCs.

Direct current power for the Class 1E dc loads of each unit is supplied by four independent Class 1E 125V batteries and associated battery chargers. One 250V and one 125V non-Class 1E battery and associated battery chargers supply power for the non-Class 1E dc system loads. And another direct current power for coping with station blackout(SBO) of KORI 1,2,3 and 4 is supplied by an independent Non-Class 1E 125V battery with an associated battery charger and a distribution panel.

314

These systems are discussed individually in chapter 8.

#### 1.2.6 POWER CONVERSION SYSTEM

The steam and power conversion system removes heat energy from the reactor coolant in three steam generators and converts it to electrical energy with the turbine generator. These systems are discussed in detail in chapter 10.

The turbine generator is an 1800 rpm, tandem-compound, six-flow exhaust, condensing unit design for saturated steam conditions. The turbine section consists of one high-pressure turbine element and three low-pressure turbine elements. The generator rating is 1222 MVA at 22,000 volts and 60 hertz.

Steam enters the high-pressure turbine through the main stop valves and the governing control valves. From the high-pressure turbine exhaust, the steam flows through combined moisture separator/reheaters to the low-pressure turbines.

The main steam lines are provided with turbine bypass valves which discharge to the condenser, and safety, dump, and relief valves which discharge to the atmosphere.

Steam is taken from one of the moisture separator/reheaters for steam supply to the steam generator feedwater pump turbine drivers. The auxiliary feedwater pump turbine is supplied with driving steam from the main steam lines upstream of the main steam isolation valves. The two-stage reheaters are supplied with heating steam extracted from the high-pressure turbine and also from the main steam cross-connection header.

A turbine bypass system is provided which will bypass up to 36 percent of full-load main steam flow directly to the main condenser, and exhaust 28 percent of full-load main steam flow to the atmosphere. The bypass and atmospheric dump systems are designed to help maintain secondary side steam pressure below safety valve setpoint pressures during transient conditions.

321

The main condenser transfers unusable heat in the turbine exhaust steam to the water being circulated through the condenser tubes by the circulating water pumps. The circulating water is then returned to the East Sea.



KRN 3 & 4 FSAR

GENERAL PLANT  
DESCRIPTION

Parallel strings of regenerative feedwater heaters utilize turbine extraction steam and turbine exhaust steam to heat the condensate and feedwater after it is pumped from the main condenser hotwell and before it is pumped into the steam generator.

1.2.7 FUEL HANDLING AND STORAGE SYSTEMS

The reactor is refueled by equipment which handles spent fuel under water from the time it leaves the reactor vessel until it is placed in a cask for shipment from the site.

Underwater transfer of spent fuel provides an economic and transparent radiation shield, as well as a reliable coolant for removal of decay heat.

The fuel handling system is divided into two areas : the refueling canal, which is flooded for refueling; and the fuel storage pool and fuel transfer canal, which is external to the reactor containment and is always accessible to plant personnel. The refueling canal and fuel transfer canal are connected by a fuel transfer system which carries the fuel through a penetration from the reactor containment.

Spent fuel is removed from the reactor vessel by a refueling machine and is placed in the fuel transfer system. In the fuel storage pool, the fuel is removed from the transfer system and is placed in storage racks. After a suitable decay period, the fuel can be removed from storage and loaded into a shipping cask for removal to a reprocessing plant.

New fuel and spent fuel assemblies are stored in the fuel building. New fuel assemblies are stored in vertical racks in either the new fuel storage pit or in the spent fuel storage pool. The new fuel storage pit is a reinforced concrete pit which provides dry storage for 60 new fuel assemblies. New fuel assemblies can also be in the spent fuel storage pool prior to initial fuel load or refueling.

308

169. The stainless steel lined reinforced concrete spent fuel storage pool  
56. provides wet storage for 2,260 fuel assemblies (14.4 reactor cores) for Kori  
15 3, and 2,262 fuel assemblies (14.4 reactor cores) for Kori 4.

308

Spent fuel assemblies are stored in vertical racks so spaced as to preclude criticality in a non-borate cooling water environment.

The design criteria and evaluation of the fuel storage facility are discussed in subsection 9.1.2. Control of the fuel storage pool water temperature during normal operation is accomplished by circulating the fuel pool water through a heat exchanger cooled by the CCWS. Purification and clarification of the fuel storage pool water is by the use of a filter, strainers, and an ion exchanger. A description and evaluation of the

Amendment 308

GENERAL PLANT  
DESCRIPTION

fuel pool cooling and purification system is presented in subsection 9.1.3.

The fuel handling system, as further discussed in subsection 9.1.4, provides for the safe handling of fuel and control rod assemblies and for the required assembly, disassembly, and storage of reactor internals. These systems include a refueling machine located inside the containment above the refueling canal, the fuel handling crane, the fuel transfer carriage, the upending machines, the fuel transfer tube, a fuel handling machine in the spent fuel storage area, and various devices used for handling and storing the reactor vessel head and internals.

1.2.8 COOLING WATER AND OTHER AUXILIARY SYSTEMS

1.2.8.1 Cooling Water Systems

Water systems in operation at the facility include the nuclear service water system, CCWS, demineralized water system, domestic water system, condensate storage facility, reactor makeup water storage, refueling water storage, circulating water system, essential chilled water system, and central chilled water system, turbine plant closed cooling water system, and turbine plant open cooling water system. Except for the circulating water system, which is discussed in subsection 10.4.5, all of the water systems are covered individually in section 9.2.

The CCWS, essential chilled water system, refueling water storage system, condensate storage system and nuclear service water system are required for safe shutdown of the plant following a DBA, and the single failure criterion of 10 CFR 50 applies. These systems are Seismic Category I and each is designed for redundancy, as required, with functional and physical separation of each train of redundant components.

The CCWS is provided to remove heat from various reactor auxiliary systems which require cooling water of higher quality than service water. The system also provides a monitored intermediate barrier between potentially radioactive water and the service water system, reducing the probability of leakage of radioactive water into the service water.

The CCWS routes cooling water to equipment essential for normal operations of the NSSS and for cooling following a DBA. It also furnishes cooling water to various space cooling units throughout the containment.

Component cooling water circulates through two interconnected loops which are isolated to provide two physically separated



GENERAL PLANT  
DESCRIPTION

closed loops following an ESF actuation. Each of these loops removes heat from the residual heat removal (RHR) heat exchangers, the containment spray pump lube oil cooler, the RHR pump lube oil coolers, the charging pump lube oil coolers, and the containment fan coolers. The CCWS also cools nonsafety-related auxiliary heat loads which function during normal plant operation. These nonsafety-related loads are automatically isolated from the safety-related loops following an ESF actuation. In these loops the temperature of water supplied to equipment being cooled varies according to loop bulk thermal load.

The nuclear service cooling water system furnishes cooling water from the ultimate heat sink for the component cooling water heat exchangers, the diesel generator cooling water heat exchangers, and the essential chilled water system. The system is composed of four nuclear service cooling water pumps and piping forming two physically separated nuclear service cooling water loops. Either of the nuclear service cooling water loops will satisfy service water requirements for safe shutdown of the plant under postulated DBAs.

The refueling water storage system is designed to supply borated water to the containment spray system and to the emergency core cooling system during the injection phase following a LOCA. The system consists of a 540,000 gallon tank and associated piping.

The essential chilled water system is designed to maintain the ambient temperature of the ESF equipment rooms and switchgear room during operation under accident conditions below maximum design ambient temperature. The major components of the system are the chiller, chilled water pump air separator, and compression tank.

The ultimate heat sink is required for the dissipation of residual heat after reactor shutdown and after an accident. The ultimate heat sink is the East Sea, which guarantees an unlimited cooling water supply in the event of an accident.

The other water systems of the plant are necessary for proper functioning of the plant. These auxiliary systems provide water as designated by their names and are analyzed in section 9.2.

#### 1.2.8.2 Other Auxiliary Systems

The process auxiliary systems include the compressed air system, the process sampling system, the equipment and floor drainage system, the chemical and volume control system (CVCS), and the gross failed fuel detection system. Process auxiliaries are discussed further in section 9.3.

GENERAL PLANT  
DESCRIPTION

The compressed air system provides a reliable continuous supply of filtered, dried, oil-free air for pneumatic instruments and controls. The system also provides service air to outlets throughout the plant for pneumatic tools and other service requirements. The compressed air system is required for the plant normal operation; however, pneumatically operated devices in the plant which are required for safe shutdown are designed to move to the safe position upon loss of air pressure, or are provided with individual air accumulators or safety-related instrument air for emergency service.

The safety-related instrument air system consists of Seismic Category 1 air storage tanks, piping and valves. These tanks will automatically supply instrument air to the main steam power-operated relief valves and the flow control valves on the discharge of the motor-driven auxiliary feedwater pumps in the event that the normal instrument air supply is unavailable.

Process sampling systems are provided for the RCS and other secondary systems. Process sampling is used for determining chemical and radiochemical conditions of various fluids used in the plant.

The equipment and floor drainage systems are designed to collect drainage. The collected drainage from potentially radioactive equipment and floor drains can be processed in the liquid waste management systems. Monitoring capability is provided to ensure that inadvertent releases of radioactivity are prevented.

The CVCS is designed to provide a programmed water level in the pressurizer and the injection flow to the seal water system of the reactor coolant pumps. In addition, the CVCS controls water chemistry, reactivity level, concentration of soluble chemical neutron absorber, and makeup of the reactor coolant. The CVCS is also used for emergency core cooling.

The boron recycle system receives and recycles reactor coolant effluent for reuse of the boric acid and makeup water. The system decontaminates the effluent by means of demineralization and gas stripping, and uses evaporation to separate and recover the boric acid and makeup water.

The gross failed fuel detector is connected to the hot leg of a primary coolant loop. The coolant sample passes through a cooler and then into a coil containing a neutron detector and moderator, after which it flows back into the volume control tank. Chemistry samples can be taken to validate indications higher than normal. Rapid and large increases in activity are indicative of gross fuel failures.

### 1.2.8.3 Ventilation Systems Summary Descriptions

Ventilation systems are provided for normal plant operation and for DBA. The control building, access control building, turbine building, auxiliary building, fuel building, diesel generator rooms, radwaste building, nuclear service water pumphouse, and the containment are all provided with HVAC systems. These ventilation systems are designed to provide suitable environments for equipment and personnel. Where appropriate, ventilation zones are arranged within buildings to promote the flow of air from clean areas to areas of potentially greater radiation contamination prior to final exhaust. These systems are described further in sections 6.4 and 9.4.

The control building ventilation system maintains internal environmental conditions in the control room, cable spreading rooms, electrical rooms, and the computer room.

The control room ventilation system is designed to provide year-round air conditioning by filtering, heating, and cooling outside supply air and control room recirculated air. For post-DBA conditions, redundant emergency filtration trains are provided to maintain a habitable control room atmosphere. A smoke removal system is provided for purging.

The cable spreading room ventilation systems are designed to maintain temperatures compatible with normal operating requirements by filtering and cooling recirculated air from the cable spreading rooms. A smoke removal system is provided for purging.

The electrical room ventilation systems are designed to maintain temperatures compatible with the normal equipment operating requirements by filtering and cooling outside and recirculating air. Redundant systems for exhausting the battery rooms are provided for the removal of hydrogen.

The computer room and access control building ventilation systems are designed to maintain temperatures compatible with the working or operating equipment environment by filtering, heating, and cooling outside and recirculated air.

The fuel building ventilation system is designed to maintain a habitable working environment inside the building. Outside air is filtered, cooled, and supplied to the building through redundant supply units and is exhausted to outside atmosphere through redundant normal exhaust fans. An emergency fuel building exhaust system filters the building exhaust to mitigate the effects of postulated accidents.



GENERAL PLANT  
DESCRIPTION

The diesel generator rooms are ventilated to prevent equipment damage from extremes of temperature. A separate ventilation system is provided for each diesel generator room.

The auxiliary building ventilation system is designed to supply filtered and cooled outside and recirculated air to maintain temperatures compatible with normal operating requirements. Individual local recirculating units with cooling coils provide cooling for the ESF pumps during operation of the pumps, in addition to providing additional local cooling in selected areas. Air is exhausted through redundant filtered exhaust systems.

The turbine building ventilation system provides a source of outside air for removal of internally generated heat and heat transmitted to the building from external sources. Heated exhaust air is discharged to the atmosphere.

The containment ventilation system is designed for the following operating requirements:

- A. Maintain temperatures at levels compatible with normal operating requirements by the operation of the containment fan coolers, reactor cavity cooling units, and CRDM shroud fans.
- B. Remove heat from the containment atmosphere following a postulated LOCA or main steam line break inside the containment by the operation of the containment fan coolers.
- C. Provide a backup to the hydrogen recombiners to prevent the concentration of hydrogen following an accident by the use of a containment purge system.
- D. Purge of the containment during plant shutdown by supplying filtered and heated or cooled outside air through the high volume purge supply unit and exhausting the containment air through the high volume exhausting unit.
- E. Purge the containment during plant operations by supplying filtered and heated or cooled outside air through the low volume purge supply unit and exhausting the containment air through a filtration unit.

The nuclear service water pumphouse is ventilated to maintain temperatures compatible with normal operating requirements.



GENERAL PLANT  
DESCRIPTION

1.2.9 RADIOACTIVE WASTE MANAGEMENT

The radioactive waste treatment systems provide all equipment necessary to collect, process, monitor, and dispose of radioactive liquid, gaseous, and solid wastes that are produced during reactor operation.

Liquid wastes containing potentially radioactive material are collected and monitored. Prior to discharge, equipment is provided for filtering, evaporating, and demineralizing the liquid as required. The treated water from the filters or demineralizers or the evaporator distillate may be recycled for use in the plant or may be discharged if it is within the limits of 10 CFR 20 and 10 CFR 50, Appendix I. A steam generator blowdown treatment system and a condensate polisher system are provided to permit continued plant operation with limited fuel clad defects concurrent with steam generator tube leaks.

Liquid and solid waste which cannot be either recycled in the plant or discharged to the environment are processed by the solid radwaste system for offsite disposal. Processing includes solidification of liquid wastes and packaging of all wastes into approved shipping containers.

Gaseous wastes are held up for radioactive decay in charcoal decay beds. Discharge to the environment is controlled to keep the offsite dose within the limits of 10 CFR 20 and 10 CFR 50, and Appendix I.

GENERAL PLANT  
DESCRIPTION

Table 1.2-1

1981 POPULATION BY SECTOR AND DISTANCE  
WITHIN 16 KILOMETERS OF THE SITE

Sector	0-1.6 (km)	1.6-3.2 (km)	3.2-4.8 (km)	4.8-6.4 (km)	6.4-8.0 (km)	8.0-16 (km)	Total 0 - 16 (km)
W	0	1,218	2,738	236	415	4,940	9,547
WNW	0	2,649	110	170	171	5,706	8,806
NW	4,403	4,093	707	693	179	6,771	16,846
NNW	287	617	268	411	545	1,877	4,005
N	0	1,478	836	268	74	9,818	12,494
NNE	268	986	452	388	0	14,893	16,987
NE	0	1,097	2,420	1,018	952		5,467
ENE	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0
SSW	0	0	0	0	334	12,022	12,356
SW	0	0	3,166	87	4,448	27,471	35,172
WSW	0	0	2,787	1,167	74	2,537	6,565
Total	4,958	12,118	13,484	4,438	7,192	86,035	128,225

GENERAL PLANT  
DESCRIPTION

Table 1.2-2


1981 POPULATION BY SECTOR AND DISTANCE  
 BETWEEN 16 AND 80 KILOMETERS FROM THE SITE

(Population in thousands)

Sector	16 - 32 (km)	32 - 48 (km)	48 - 64 (km)	64 - 80 (km)	Total 16 - 80 (km)
W	41.0	46.9	182.7	277.6	548.2
WNW	13.5	31.3	53.9	73.6	172.3
NW	16.5	10.4	47.1	149.8	223.8
NNW	23.7	19.9	32.9	132.9	209.4
N	183.9	36.9	141.0	321.8	683.6
NNE	228.2	22.9	24.2	41.6	316.9
NE	0	0	0	0	0
ENE	0	0	0	0	0
E	0	0	0	0	0
ESE	0	0	0	0	0
SE	0	0	0	0	0
SSE	0	0	0	0	0
S	0	0	0	0	0
SSW	35.3	0	0	0	35.3
SW	1,660.5	889.4	4.4	70.3	2,624.6
WSW	474.3	206.8	64.5	100.9	846.5
Total	2,676.9	1,264.5	550.7	1,168.5	5,660.6

본 문서는 한국수력원자력(주)이 정보 공개용으로 작성한 문서입니다.

Population within 1.6 km of the site				
Direction	NW	NNW	N	NNE
Population	4,403	287	0	268



0-1.6 (km)	1.6-3.2 (km)	3.2-4.8 (km)	4.8-6.4 (km)	6.4-8.0 (km)	8.0-16 (km)	Total
4,958	12,118	13,484	4,438	7,192	86,035	128,225




KOREA ELECTRIC POWER CORPORATION  
KOREA NUCLEAR UNITS 5 & 6  
FSAR

POPULATION DISTRIBUTION  
WITHIN 10 MILES

Figure 1.2-1



본 문서는 한국수력원자력(주)이 정보 공개용으로 작성한 문서입니다.



16 ( $\bar{k}m$ ) <sup>32</sup>	32 ( $\bar{k}m$ ) <sup>48</sup>	48 ( $\bar{k}m$ ) <sup>64</sup>	64 ( $\bar{k}m$ ) <sup>80</sup>	Total
2,676.9	1,264.5	550.7	1,168.5	5,660.6




KOREA ELECTRIC POWER CORPORATION  
KOREA NUCLEAR UNITS 5 & 6  
FSAR

POPULATION DISTRIBUTION  
BETWEEN 10 AND 50 MILES

Figure 1.2-2

본 문서는 한국수력원자력(주)이 정보 공개용으로 작성한 문서입니다.

THIS FIGURE APPEARS  
IN A SUPPLEMENT  
TO THE FSAR




KOREA ELECTRIC POWER CORPORATION  
KOREA NUCLEAR UNITS 5 & 6  
FSAR

LOW POPULATION ZONE AND  
EXCLUSION AREA BOUNDARY

Figure 1.2-3

THIS FIGURE APPEARS  
IN A SUPPLEMENT  
TO THE FSAR



KOREA ELECTRIC POWER CORPORATION  
KOREA NUCLEAR UNITS 5 & 6  
FSAR

EXCLUSION AREA BOUNDARY

Figure 1.2-4

본 문서는 한국수력원자력(주)이 정보 공개용으로 작성한 문서입니다.

THIS FIGURE APPEARS  
IN A SUPPLEMENT  
TO THE FSAR




**KOREA ELECTRIC POWER CORPORATION  
KOREA NUCLEAR UNITS 5 & 6  
FSAR**

**SITE PLAN**

**Figure 1.2-5**






KOREA ELECTRIC POWER CORPORATION  
KOREA NUCLEAR UNITS 5 & 6  
FSAR

GENERAL ARRANGEMENT  
MISCELLANEOUS PLANS



Figure 1.2-6




KOREA HYDRO & NUCLEAR POWER COMPANY  
KRN 3 & 4 FSAR

GENERAL ARRANGEMENT  
PLAN EL. 59'-0" TO GRADE

Figure 1.2-7






KOREA HYDRO & NUCLEAR POWER COMPANY  
KEN 3 & 4 FSAR

GENERAL ARRANGEMENT  
PLAN AT TURBINE  
OPERATING FLOOR EL. 135'-6"

Figure 1.2-9






KOREA ELECTRIC POWER CORPORATION  
KOREA NUCLEAR UNITS 5 & 6  
FSAR

GENERAL ARRANGEMENT  
PLAN AT CONTAINMENT  
OPERATING FLOOR EL. 148'-0"

Figure 1.2-10





KOREA HYDRO & NUCLEAR POWER COMPANY  
KHNP 3 & 4 EGR

390

GENERAL ARRANGEMENT  
SECTION A


Figure 1.2-11




 KOREA ELECTRIC POWER CORPORATION  
KOREA NUCLEAR UNITS 5 & 6  
FSAR


GENERAL ARRANGEMENT  
SECTION B

Figure 1.2-12



	KOREA ELECTRIC POWER CORPORATION KOREA NUCLEAR UNITS 5 & 6 FSAR
	GENERAL ARRANGEMENT SECTION C AND E
	Figure 1.2-13






KOREA HYDRO & NUCLEAR POWER COMPANY  
KRN 3 & 4 FSAR

390

GENERAL ARRANGEMENT  
SECTION F D G H & J


Figure 1.2-14




KOREA ELECTRIC POWER CORPORATION  
KOREA NUCLEAR UNITS 5 & 6  
FSAR

GENERAL ARRANGEMENT  
RADWASTE BUILDING


Figure 1.2-15



	KOREA ELECTRIC POWER CORPORATION KOREA NUCLEAR UNITS 5 & 6 FSAR
GENERAL ARRANGEMENT EQUIPMENT LIST (Sheet 1 of 3) Figure 1.2-16	








KOREA HYDRO & NUCLEAR POWER COMPANY  
KRN 3 & 4 FSAR

390

GENERAL ARRANGEMENT  
EQUIPMENT LIST  
(Sheet 3 of 3)


Figure 1.2-16



KOREA ELECTRIC POWER CORPORATION  
KOREA NUCLEAR UNITS 5 & 6  
FSAR

REACTOR COOLANT SYSTEM

Figure 1.2-17




KOREA HYDRO & NUCLEAR POWER  
COMPANY KORI 3 & 4 FSAR

AAC D/G BUILDING SITE PLAN

Figure 1 , 2-18

본 문서는 한국수력원자력(주)이 정보 공개용으로 작성한 문서입니다.



Amendment 533  
2015.09.23



### 1.3 COMPARISON TABLES

#### 1.3.1 COMPARISON WITH SIMILAR FACILITY DESIGNS

This subsection highlights the principal differences and similarities between the major design features of this facility and other similar plants. In tables 1.3-1 and 1.3-2, comparisons with the other plants of similar design are listed. Table 1.3-1 documents the major similarities and differences of the nuclear steam supply system (NSSS) components and equipment of the facility with those of Maanshan (Taiwan Power Company) and Shearon Harris (Carolina Power and Light, North Carolina, USA) Nuclear Power Plants. In table 1.3-2, Maanshan, Pebble Springs, and SNUPPS have been listed for comparison with the facility concerning plant features other than the NSSS.

#### 1.3.2 COMPARISON OF FINAL AND PRELIMINARY DESIGNS (FSAR)

Table 1.3-3 provides a listing of significant differences between the final design and preliminary design of the facility which have occurred since the submittal of the PSAR.




Table 1.3-1

N888 VENDOR SUPPLIED COMPONENTS COMPARISON WITH SIMILAR FACILITY DESIGNS  
(Sheet 1 of 33)

Chapter	System/parameter	KRN 3 & 4	Maanshan	Shearon Harris
4	Core Mechanical Design	Section 4.2		
	Fuel assemblies			
	Design	RCC canless	RCC canless	RCC canless
	Number of fuel assemblies	157	157	157
	UO <sub>2</sub> rods per assembly	264	264	264
	Rod pitch, mm.	12.6	12.6	12.6
	Overall dimensions, mm.	214.02 × 214.02	215.04 × 215.04	215.04 × 215.04
	Fuel weight (as UO <sub>2</sub> ), per assembly, kg	≈ 521.7	≈ 476.3	≈ 498.92
	Clad weight per assembly, kg	≈ 107	≈ 118.8	≈ 128.7
	Number of grids per assembly	2 End(Top, Bottom) grid : Incore 1 VIB 8 Mid grid : SIBRD 3 IFM grid (BPA) : SIBRD 5 IFM grid (ACT) : SIBRD 3 Protective grid : Incore 1 VIB	2 - Type R 6 - Type 2	8 - Type R
	Loading technique	3-region nonuniform	3-region nonuniform	3-region nonuniform
	Fuel rods			
	Number	41,448	41,448	41,448
	Outside diameter, mm.	9.5	9.14	9.5

• RFA : Robust Fuel Assembly

Table 1.3-1

N888 VENDOR SUPPLIED COMPONENTS COMPARISON WITH SIMILAR FACILITY DESIGNS  
(Sheet 2 of 33)

Chapter	System/Parameter	KRN 3 & 4	Maanshan	Shearon Harris
4	Diametral gap, mm.	0.17	0.157	0.17
	Clad thickness, mm.	0.57	0.64	0.64
	Clad material	ZIRLO	Zircaloy-4	Zircaloy-4
	Fuel pellets			
	Material	UO <sub>2</sub> /UO <sub>2</sub> -Gd <sub>2</sub> O <sub>3</sub> sintered	UO <sub>2</sub> sintered	UO <sub>2</sub> sintered
	Density, % of theoretical	95	95	95
	Diameter, mm.	8.19	7.84	8.05
	Length, mm.	9.83	12.88	10.00
	Rod cluster control assemblies			
	Neutron absorber	Ag-In-Cd (full length)	B <sub>4</sub> C (with Hf or Ag-In-Cd Tips)	Ag-In-Cd or Hf
	Cladding material	Type 304(or 316L) SS-cold worked	Type 304 SS-cold worked	Type 304 SS-cold worked
	Clad thickness, mm.	0.47	0.57	0.47
	Number of cluster full and part length	52/0	52/0	52/0

19

278

321

19

876

278

19

302

19

KRN 3 & 4 FSAR

COMPARISON TABLES

본 문서는 한국수력원자력(주)이 정보 공개용으로 작성한 문서입니다.

Table 1.3-1

NSSS VENDOR SUPPLIED COMPONENTS COMPARISON WITH SIMILAR FACILITY DESIGNS  
(Sheet 3 of 33)

Chapter	System/Parameter	KRN 3 & 4	Maanshan	Shearon Harris
4	Number of absorber rods per cluster	24	24	24
	Core structure			
	Core barrel, ID/OD, cm.	339.98 / 350.2	339.98 / 350.2	340.1/340.1
	Thermal shield, ID/OD, cm.	Neutron pad design	Neutron pad design	Neutron pad design
	Structural characteristics			
	Core diameter, cm. (equivalent)	304	304	304
	Core height, cm. (active fuel)	365.8	365.8	365.8
	Reflector thickness and composition			
	Top - water plus steel, cm.	25.4	25.4	25.4
	Bottom - water plus steel, cm.	25.4	25.4	25.4
	Side - water plus steel, cm.	38.1	38.1	38.1

KRN 3 & 4 FSAR

COMPARISON TABLES

Amendment 19  
April, 15, 1994

1.3-4



Table 1.3-1

NSSS VENDOR SUPPLIED COMPONENTS COMPARISON WITH SIMILAR FACILITY DESIGNS  
(Sheet 4 of 33)

Chapter	System/Parameter	KRN 3 & 4	Maanshan	Shearon Harris
4	H <sub>2</sub> O/U molecular ratio core, lattice (cold)	2.54	2.73	2.43
	Feed enrichment, w/o			
	Region 1	1.60	1.60	2.10
	Region 2	2.40	2.40	2.60
	Region 3	3.10	3.10	3.10
	Thermal and hydraulic design	Section 4.4		
	Reactor core heat output, MWt	2,775	2,775	2,775
	Reactor core heat output, 10 <sup>6</sup> Btu/h	9,471	9,471	9,471
	Heat generated in fuel, %	97.4	97.4	97.4
	System pressure, nominal, kg/cm <sup>2</sup> [bar]	160.3[157.2](4)	157.2	155.1
	System pressure, minimum steady-state, kg/cm <sup>2</sup> [bar]	158.2[155.1](4)	155.1	153.1
	Minimum DNBR for design transients		≥1.49	≥1.30
	Typical Flow Channel	1.35		
	Thimble Flow Channel	1.33		

KRN 3 & 4 FSAR

COMPARISON TABLES

273

1.3-5

19

Table 1.3-1

N388 VENDOR SUPPLIED COMPONENTS COMPARISON WITH SIMILAR FACILITY DESIGNS  
(Sheet 4 of 33)

Chapter	System/Parameter	KRN 3 & 4	Maanshan	Shearon Harris
4	H <sub>2</sub> O/U molecular ratio core, lattice (cold)	2.54	2.73	2.43
	Feed enrichment, w/o			
	Region 1	1.60	1.60	2.10
	Region 2	2.40	2.40	2.60
	Region 3	3.10	3.10	3.10
	Thermal and hydraulic design	Section 4.4		
	Reactor core heat output, MWt	2,900	2,775	2,775
	Reactor core heat output, 10 <sup>6</sup> Btu/h	9,898	9,471	9,471
	Heat generated in fuel, %	97.4	97.4	97.4
	System pressure, nominal, kg/cm <sup>2</sup> [bar]	158.2[155.1]	157.2	155.1
	System pressure, minimum steady-state, kg/cm <sup>2</sup> [bar]	154.3[151.3]	155.1	153.1
	Minimum DNBR for design transients		≥ 1.49	≥ 1.30
	Typical Flow Channel	1.25		
	Thimble Flow Channel	1.25		

KRN 3 & 4 FSAR

COMPARISON TABLES

321

19  
273

Table 1.3-1

N888 VENDOR SUPPLIED COMPONENTS COMPARISON WITH SIMILAR FACILITY DESIGNS (17×17 ACE7)  
(Sheet 4 of 33)

Chapter	System/parameter	KRN 3 & 4	Maanshan	Shearon Harris
4	H <sub>2</sub> O/U molecular ratio	2.54	2.73	2.43
	core, lattice (cold)			
	Feed enrichment, w/o			
	Region 1	1.60	1.60	2.10
	Region 2	2.40	2.40	2.60
	Region 3	3.10	3.10	3.10
	Thermal and hydraulic design	Section 4.4		
	Reactor core heat output, MWt	2,900	2,775	2,775
	Reactor core heat output, 10 <sup>6</sup> Btu/h	9,898	9,471	9,471
	Heat, generated, in fuel, %	97.4	97.4	97.4
	System pressure, nominal, bar	155.1	157.2	155.1
	System pressure, minimum steady-state, bar	151.3	155.1	153.1
	Minimum DNBR for design transients		≥ 1.49	≥ 1.30
	Typical Flow Channel	<b>1.23</b>		
	Thimble Flow Channel	<b>1.23</b>		

1.3-5a

KRN 3 & 4 FSAR

376

COMPARISON TABLES

Table 1.3-1

N388 VENDOR SUPPLIED COMPONENTS COMPARISON WITH SIMILAR FACILITY DESIGNS  
(Sheet 5 of 33)

Chapter	System/Parameter	KRN 3 & 4	Maanshan	Shearon Harris
4	Coolant flow			
	Total thermal flow rate, kg/sec(5)	13,331	14,099	13,620
	Effective flow rate for heat transfer, kg/sec	12,436	13,444	13,032
	Effective flow area for heat transfer, m <sup>2</sup>	3.86	4.09	3.87
	Average velocity along fuel rods, m/sec	4.30	4.66	4.69
	Average mass velocity, kg/m <sup>2</sup> ·sec	3,221	3,287	3,380
	Coolant temperature, °C			
	Nominal inlet	289.4	292.2	291.1
	Average rise in vessel	37.8	34.1	35.4
	Average rise in core	40.1	35.9	37.0
	Average in core	310.7	310.9	310.7
	Average in vessel	308.3	310.1	314.6

\* VSH : Vantage - SH  
RFA : Robust Fuel assembly

KRN 3 & 4 PSAR

COMPARISON TABLES

273 321



Table 1.3-1a

N888 VENDOR SUPPLIED COMPONENTS COMPARISON WITH SIMILAR FACILITY DESIGNS (17×17 ACE7)  
(Sheet 5 of 33)

Chapter	System/Parameter	KRN 3 & 4	Meanshan	Shearon Harris
4	Coolant flow			
	Total thermal flow rate, kg/sec(5)	13,192	14,099	13,620
	Effective flow rate for heat transfer, kg/sec	12,058	13,444	13,032
	Effective flow area for heat transfer, m <sup>2</sup>	3.86	4.09	3.87
	Average velocity along fuel rods, m/sec	4.18	4.66	4.69
	Average mass velocity, kg/m <sup>2</sup> · sec	3.123	3.287	3.380
	Coolant temperature, °C			
	Nominal inlet	<b>289.2</b>	292.2	291.1
	Average rise in vessel	<b>58.1</b>	34.1	35.4
	Average rise in core	<b>41.2</b>	35.9	37.0
	Average in core	<b>311.2</b>	310.9	310.7
	Average in vessel	<b>308.3</b>	310.1	314.6

376

KRN 3 & 4 FSAR

COMPARISON TABLES

Table 1.3-1

N338 VENDOR SUPPLIED COMPONENTS COMPARISON WITH SIMILAR FACILITY DESIGNS  
(Sheet 6 of 33)

Chapter	System/Parameter	KRN 3 & 4	Maanshan	Shearon Harris
4	Heat transfer			
	Active heat transfer surface area, m <sup>2</sup>	4,550	4,350	4,550
	Average heat flux, kW/m <sup>2</sup>	626	638	610
	Maximum heat flux for normal operation, kW/m <sup>2</sup>	1,627	1,481	1,415
	Average linear power, kW/ft	5.69	5.44	5.44
	Peak linear power for normal operation, kW/ft	14.8	12.6	12.6
	Peak linear power resulting from over-power transients/operator error (assuming a maximum overpower of 118%) kW/ft	< 22.5	18.0	18.0
	Heat flux hot channel factor, F <sub>Q</sub>	2.60	2.30	2.32

(1) This limit is associated with the value of F<sub>Q</sub>=2.60

(2) See subparagraph 4.3.2.2.6

(3) This is the value of F<sub>Q</sub> for normal operation.

(4) Values used for thermal hydraulic analysis

(5) Based on the Thermal Design Flow Rate

\* ( ) : Values for V-SH fuel

19

1.3-7

Amendment 321  
2006.12.14

4

321

4

273

321

KRN 3 & 4 FSAR

COMPARISON TABLES

Table 1.3-1

N388 VENDOR SUPPLIED COMPONENTS COMPARISON WITH SIMILAR FACILITY DESIGNS  
(Sheet 7 of 33)

Chapter	System/Parameter	KRN 3 & 4	Maanshan	Shearon Harris
4	Peak fuel centerline temperature at peak linear power for prevention of centerline melt, °C	2.593-3.75xWg(w/o Gd <sub>2</sub> O <sub>3</sub> )	2.593	2.593
5	RCS Design and Operating Parameters	Section 5.1		
	Plant design life, yr	40	40	40
	Nominal operating pressure, psig	2,235	2,235	2,235
	Total system volume including pressurizer and surge line, ft <sup>3</sup>	9,275	9,410	9,723
	System liquid volume, including pressurizer water at maximum guaranteed power, ft <sup>3</sup>	8,700	8,833	8,963
	Pressurizer spray rate, maximum gpm	700	700	600
	Pressurizer heater capacity, kW	1,400	1,400	1,400
	Pressurizer relief tank volume, ft <sup>3</sup>	1,300	1,300	1,300

273  
321

KRN 3 & 4 FSAR

COMPARISON TABLES

Table 1.3-1

N888 VENDOR/SUPPLIED COMPONENTS COMPARISON WITH SIMILAR FACILITY DESIGNS  
(Sheet 8 of 33)

Chapter	System/Parameter	KRN 3 & 4			Maanshan	Shearon Harris
5	RCS thermal and hydraulic data					
	N888 power, MWt	2.912			2.785	2.785
	Thermal design flows, gpm					
	Active loop	94,200			97,600	97,600
	Idle loop	-			-	-
	Reactor	282,600			292,800	292,800
	Tavg(°F)	587	586	580		
	Total reactor flow, 10 <sup>6</sup> lb/h	105.8	105.9	106.9	109.1	109.2
	Temperatures, °F					
	Reactor vessel outlet	621.0	620.0	614.4	619.9	619.0
	Reactor vessel inlet	553.0	552.0	545.6	557.0	556.0
	steam generator outlet	552.7	551.7	545.3	556.7	555.8
	Steam generator steam	535.4	534.3	527.7	540.2	540.2
	Feedwater	445.9	445.9	445.9	440.0	435.0

321

COMPARISON TABLES

KRN 3 & 4 FSAR



Table 1.3-1

N338 VENDOR SUPPLIED COMPONENTS COMPARISON WITH SIMILAR FACILITY DESIGNS  
(Sheet 9 of 33)

Chapter	System/Parameter	KRN 3 & 4			Maanshan	Shearon Harris
5	Steam pressure, psia	926.0	918.0	868.0	964	964
	Total steam flow, 10 <sup>6</sup> lb/h	12.94	12.93	12.91	12.3	12.2
	Best estimate flows, gpm					
	Active loop		102,600		102,800	103,000
	Reactor		307,800		308,400	309,000
	Mechanical design flows, gpm					
	Active loop		106,900		106,900	107,100
	Reactor		320,700		320,700	321,300
	System pressure drops					
	Reactor vessel ΔP, psi		41.0		41.0	43.8
	Steam generator ΔP, psi		41.0		41.0	38.7
	Hot leg piping ΔP, psi		1.4		1.4	2.0
	Pump suction piping ΔP, psi		3.4		3.4	3.6
	Cold leg piping ΔP, psi		3.4		3.4	2.0
	Pump head, ft		280		280	279

321

KRN 3 & 4 FSAR

COMPARISON TABLES

5

Table 1.3-1

NSSS VENDOR SUPPLIED COMPONENTS COMPARISON WITH SIMILAR FACILITY DESIGNS  
(Sheet 10 of 33)

Chapter	System/Parameter	KNU 5 & 6	Maanshan	Shearon Harris
5	RCS design pressure settings	Section 5.2		
	Hydrostatic test pressure, psig	3,107	3,107	3,107
	Design pressure, psig	2,485	2,485	2,485
	Safety valves (begin to open), psig	2,485	2,485	2,485
	High pressure reactor trip, psig	2,385	2,385	2,385
	High pressure alarm, psig	2,310	2,310	2,335
	Power relief valves, psig	2,335 <sup>(4)</sup>	2,335	2,335
	Pressurizer spray valves (full open), psig	2,310	2,310	2,310
	Pressurizer spray valves (begin to open), psig	2,260	2,260	2,260
	Proportional heaters, (begin to operate), psig	2,250	2,250	2,250
	Operating pressure, psig	2,235	2,235	2,235
	Proportional heater (full operation), psig	2,220	2,220	2,220

(4) At 2,335 psig, a pressure signal initiates actuating (opening) of these valves, remote manual control is also provided.

NSSS VENDOR SUPPLIED COMPONENTS COMPARISON WITH SIMILAR FACILITY DESIGNS  
(Sheet 11 of 33)

Chapter	System/Parameter	KNU 5 & 6	Maanshan	Shearon Harris
5	Backup heaters on, psig	2,210	2,210	2,210
	Pressurizer relief valve interlock, psig	2,185 <sup>(5)</sup>	2,335	2,185
	Low pressure reactor trip (typical, but variable), psig	1,945	1,970	1,825
	Reactor vessel design			
	Design/operating pressure, psig	2485/2235	2,485/2,235	2,485/2,235
	Design temperature, °F	650	650	650
	Overall height of vessel and closure head, ft-in. (bottom head outside diameter to top of control rod mechanism adapter)	42-7 3/16	42-7 3/16	42-7 3/16
	Thickness of insulation, minimum, in.	3	3	3
	Number of reactor closure head studs	58	58	58

(5) This interlock closes the power operated relief valves and their block valves when pressure drops to indicated value.

1.3-12

KNU 5 & 6 FSAR

COMPARISON TABLES

Table 1.3-1

NSSS VENDOR SUPPLIED COMPONENTS COMPARISON WITH SIMILAR FACILITY DESIGNS  
(Sheet 12 of 33)

Chapter	System/Parameter	KNU 5 & 6	Maanshan	Shearon Harris
5	Diameter of reactor closure head/studs, in. (minimum shank)	6	6	6
	Inside diameter of flange, in.	149 9/16	149 9/16	149 9/16
	Outside diameter of flange, in.	184	184	184
	Inside diameter at shell, in.	157	157	157
	Inlet nozzle inside diameter, maximum, in.	27 1/2	27 1/2	27 1/2
	Outlet nozzle inside diameter, maximum, in.	29	29	29
	Clad thickness, minimum, in.	1/8	1/8	1/8
	Lower head thickness, minimum, in.	5	5	5
	Vessel belt-line thickness, minimum, in.	7 7/8	7 7/8	7 7/8
	Closure head thickness, minimum, in.	6 3/16	6 3/16	6 3/16

1.3-13

KNU 5 & 6 FSAR

COMPARISON TABLES



Table 1.3-1

N388 VENDOR SUPPLIED COMPONENTS COMPARISON WITH SIMILAR FACILITY DESIGNS  
(Sheet 13 of 33)

Chapter	System/Parameter	KRN 3 & 4	Maanshan	Shearon Harris
5	Reactor coolant pump design			
	Unit design pressure, psig	2,485	2,485	2,485
	Unit design temperature, °F	650 <sup>(6)</sup>	650	650
	Unit overall height, ft	27.5	26.93	26
	Seal water injection, gpm	8	8	8
	Seal water return, gpm	3	3	3
	Cooling water flow, gpm per RCP	516	596	195
	Maximum continuous cooling water inlet temperature, °F	105	105	105
	Pump			
	suction temperature, °F	556.7	557	
	Discharge nozzle, ID, in.	27-1/2	27-1/2	27-1/2
	Suction nozzle, ID, in.	31	31	31
	Speed, rpm	1,188	1,185 - 1,190	1,183

(6) Design temperature of pressure retaining parts of the pump assembly exposed to the reactor coolant and injection water on the high pressure side of the controlled leakage seal shall be that temperature determined for the parts for a primary loop temperature of 650 °F.

321

Table 1.3-1

N338 VENDOR SUPPLIED COMPONENTS COMPARISON WITH SIMILAR FACILITY DESIGNS  
(Sheet 14 of 33)

Chapter	System/parameter	KRN 3 & 4	Maanshan	Shearon Harris
5	Water volume, ft <sup>3</sup>	80 <sup>(7)</sup>	80	57
	Weight (dry), lb	207,000	203,500	201,900
	Motor			
	Type	Drip-proof squirrel cage induction water/air cooled, totally enclosed	Drip-proof squirrel cage	Drip-proof squirrel cage induction air cooled
	Power, hp	7,000	7,000	7,000
	Voltage, volts	13,200	13,200	6,600
	Phase	3	3	3
	Frequency, Hz	60	60	60
	Current			
	starting	1900 amp @ 13,200 volts	1750 amp @ 13,200 volts	3,000 amp @ 6,600 volts
	Input, hot reactor coolant	271 amp	254 ± 5 amp	~ 491 amp
	Input, cold reactor coolant	338 amp	336 ± 7 amp	~ 660 amp

(7) Composed of reactor coolant in casing and of injection and cooling water in the thermal barrier.

본 문서는 한국수력원자력(주)이 정보 공개용으로 작성한 문서입니다.

Table 1.3-1

NSSS VENDOR SUPPLIED COMPONENTS COMPARISON WITH SIMILAR FACILITY DESIGNS  
(Sheet 15 of 33)

Chapter	System/Parameter	KNU 5 & 6	Maanshan	Shearon Harris
5	Pump moment of inertia, lb-ft <sup>2</sup> maximum			
	Flywheel	70,000	70,000	70,000
	Motor	22,500	22,500	22,500
	Shaft	520	520	520
	Impeller	1980	1,980	1,980
	Steam generator design			
	Design pressure, reactor coolant side, psig	2,485	2,485	2,485
	Design pressure, steam side, psig	1,185	1,185	1,185
	Design temperature, reactor coolant side, °F	650	650	650
	Design temperature, steam side, °F	600	600	600
	Total heat transfer surface area, ft <sup>2</sup>	55,000	55,000	48,000
	Maximum moisture carryover, wt%	0.25	0.25	0.25
	Overall height, ft-in.	67-8	67-8	67-8
	Number of U-tubes	5,626	5,626	4,674

1.3-16

KNU 5 & 6 FSAR

COMPARISON TABLES

Table 1.3-1

NSSS VENDOR SUPPLIED COMPONENTS COMPARISON WITH SIMILAR FACILITY DESIGNS  
(Sheet 16 of 33)

Chapter	System/Parameter	KNU 5 & 6	Maanshan	Shearon Harris
5	U-Tube outer diameter, in.	0.688	0.688	0.750
	Tube wall thickness, nominal, in.	0.040	0.040	0.043
	Number of manways	4	4	4
	Inside diameter of manways, in.	16	16	16
	Design fouling factor	0.00006	0.00006	0.00005
	Reactor coolant piping design			
	Reactor inlet piping, inside diameter, in.	27-1/2	27-1/2	27-1/2
	Reactor inlet piping, nominal wall thickness, in.	2.32	2.32	2.32
	Reactor outlet piping, inside diameter, in.	29	29	29
	Reactor outlet piping, nominal wall thickness, in.	2.45	2.45	2.45

1.3-17

KNU 5 & 6 FSAR

COMPARISON TABLES

본 문서는 한국수력원자력(주)이 정보 공개용으로 작성한 문서입니다.

Table 1.3-1

NSSS VENDOR SUPPLIED COMPONENTS COMPARISON WITH SIMILAR FACILITY DESIGNS  
(Sheet 17 of 33)

Chapter	System/Parameter	KNU 5 & 6	Maanshan	Shearon Harris
5	Coolant pump suction piping, inside diameter, in.	31	31	31
	Coolant pump suction piping, nominal wall thickness, in.	2.60	2.60	2.60
	Pressurizer surge line piping, nominal pipe size, in.	14	14	14
	Pressurizer surge line piping, nominal wall thickness, in.	1.406	1.406	1.406
	Reactor coolant loop piping			
	Design/operating pressure, psig	2485/2235	2,485/ 2,235	2,485/2,235
	Design temperature, °F	650	650	650
	Pressurizer surge line			
	Design pressure, psig	2,485	2,485	2,485
	Design temperature, °F	680	680	680

1.3-18

KNU 5 & 6 FSAR

COMPARISON TABLES



Table 1.3-1

NSSS VENDOR SUPPLIED COMPONENTS COMPARISON WITH SIMILAR FACILITY DESIGNS  
(Sheet 18 of 33)

Chapter	System/Parameter	KNU 5 & 6	Maanshan	Shearon Harris
5	Pressurizer safety valve inlet line			
	Design pressure, psig	2,485	2,485	2,485
	Design temperature, °F	680	680	680
	Pressurizer power-operated relief valve inlet line			
	Design pressure, psig	2,485	2,485	2,485
	Design temperature, °F	680	680	680
	Pressurizer relief tank inlet line			
	Design pressure, psig	600	600	600
	Design temperature °F	600	600	600
	RHRS Design bases	Subsection 5.4.7		
	Residual heat removal system startup	~4 hours after reactor shut-down	~4 hours after reactor shut-down	~4 hours after reactor shut-down
	Reactor coolant system initial pressure, psig	~400	~425	400

1.3-19

KNU 5 & 6 FSAR

COMPARISON TABLES

Table 1.3-1

N388 VENDOR SUPPLIED COMPONENTS COMPARISON WITH SIMILAR FACILITY DESIGNS  
(Sheet 19 of 33)

Chapter	System/parameter	KRN 3 & 4	Maanshan	Shearon Harris	
5	Reactor coolant system initial temperature, °F	-350	-350	350	
	Component cooling water temperature, °F	105	105	105	321
	Cooldown time, hours after initiation of residual heat removal system operation	-16	-16	16	
	Reactor coolant system temperature at end of cooldown, °F	140	140	140	
	Decay heat generation at 20 hours after reactor shutdown, Btu/h	$64.2 \times 10^6$	$62.4 \times 10^6$	$59 \times 10^6$	321
	Residual heat removal pump				
	Number	2	2	2	
	Design pressure, psig	600	600	600	
	Design temperature, °F	400	400	400	

KRN 3 & 4 FSAR

COMPARISON TABLES

Table 1.3-1

NSSS VENDOR SUPPLIED COMPONENTS COMPARISON WITH SIMILAR FACILITY DESIGN  
(Sheet 20 of 33)

Chapter	System/Parameter	KNU 5 & 6	Maanshan	Shearon Harris
5	Design flow, gpm	3,000	3,000	3,750
	Design head, ft	270	270	240
	Residual heat exchanger			
	Number	2	2	2
	Design heat removal capacity, Btu/h	$31.2 \times 10^6$	$31.2 \times 10^6$	$29.5 \times 10^6$

Table 1.3-1

NSSS VENDOR SUPPLIED COMPONENTS COMPARISON WITH SIMILAR FACILITY DESIGNS  
(Sheet 21 of 33)

Chapter	System/Parameter	KNU 5 & 6		Maanshan		Shearon Harris	
		Tube-Side	Shell-Side	Tube-Side	Shell-Side	Tube-Side	Shell-Side
5	RHR heat exchanger (cont'd)						
	Design pressure, psig	600	150	600	150	600	150
	Design temp, °F	400	200	400	200	400	200
	Design flow, lb/h	$1.5 \times 10^6$	$2.6 \times 10^6$	$1.5 \times 10^6$	$2.6 \times 10^6$	$1.87 \times 10^6$	$2.8 \times 10^6$
	Inlet temp, °F	140	105	140	105	140	105
	Outlet temp, °F	119.2	117.2	119.2	117	124.3	116.5
	Material	Austenitic stainless steel	Carbon steel	Austenitic stainless steel	Carbon steel	Austenitic stainless steel	Carbon steel
	Fluid	Reactor coolant	Component cooling water	Reactor coolant	Component cooling water	Reactor coolant	Component cooling water

Table 1.3-1

NSSS VENDOR SUPPLIED COMPONENTS COMPARISON WITH SIMILAR FACILITY DESIGNS  
(Sheet 22 of 33)

Chapter	System/Parameter	KNU 5 & 6	Maanshan	Shearon Harris
5	Pressurizer design			
	Design pressure, psig	2,485	2,485	2,485
	Design temperature, °F	680	680	680
	Surge line nozzle diameter, in.	14	14	14
	Internal volume, ft <sup>3</sup>	1,400	1,400	1,400
	Pressurizer relief tank design			
	Design pressure, psig	100	100	100
	Rupture disc release pressure, psig	Nominal: 91 Range: 86-100	Nominal: 91 Range: 86-100	85 ± 5%
	Design temperature, °F	340	340	340
	Total rupture disc relief capacity, lb/h at 100 psig	1.14 x 10 <sup>6</sup>	1.14 x 10 <sup>6</sup>	1.14 x 10 <sup>6</sup>



Table 1.3-1

NSSS VENDOR SUPPLIED COMPONENTS COMPARISON WITH SIMILAR FACILITY DESIGNS  
(Sheet 23 of 33)

Chapter	System/Parameter	KNU 5 & 6	Maanshan	Shearon Harris
5	RCS valve design			
	Design/normal operating pressure, psig	2,485/2,235	2,485/2,235	2,485/2,235
	Preoperational plant hydrotest, psig	3,107	3,107	3,107
	Design temperature, °F	650	650	650
6	ECCS design	Section 6.3		
	Charging pumps			
	Pump design parameters			
	Number	3	3	3
	Type	Horizontal centrifugal	Horizontal centrifugal	Horizontal centrifugal
	Design pressure, psig	2,800	2,800	2,800
	Design temperature, °F	300	300	300
	Design flow rate, gpm	150	150	150
	Maximum flow rate, gpm	650	650	650

1.3-24

KNU 5 & 6 FSAR

COMPARISON TABLES

Table 1.3-1

NSSS VENDOR SUPPLIED COMPONENTS COMPARISON WITH SIMILAR FACILITY DESIGNS  
(Sheet 24 of 33)

Chapter	System/Parameter	KNU 5 & 6	Maanshan	Shearon Harris
6	Design head, ft	5,800	5,800	5,800
	Shutoff head, ft	6,200	6,200	6,150
	Residual heat removal pumps			
	Pump design parameters			
	Number	2	2	2
	Type	Vertical centrifugal	Vertical centrifugal	Vertical centrifugal
	Design pressure, psig	600	600	600
	Design temperature, °F	400	400	400
	Design flow, per pump, gpm	3,000	3,000	3,750
	Design head, at maximum flowrate ft	270	270	240
	Boron injection recirculation pumps			
	Pump design parameters			
	Number	2	2	2
	Type	Canned centrifugal	Canned centrifugal	Canned centrifugal

1.3-25

KNU 5 & 6 FSAR

COMPARISON TABLES

Table 1.3-1

NSSS VENDOR SUPPLIED COMPONENTS COMPARISON WITH SIMILAR FACILITY DESIGNS  
(Sheet 25 of 33)

Chapter	System/Parameter	KNU 5 & 6	Maanshan	Shearon Harris
6	Design pressure, psig	150	150	240
	Design temperature, °F	250	250	200
	Design flow, per pump, gpm	20	20	20
	Design head, ft	100	100	100
	Accumulator design parameters			
	Number	3	3	3
	Design pressure, psig	700	700	700
	Design temperature, °F	300	300	300
	Operating temperature, °F	100-150	70-150	100-150
	Normal operating pressure, psig	660	660	660
	Minimum operating pressure, psig	600	600	600
	Total volume, ft <sup>3</sup>	1,450 each	1,450	1,450

1.3-26

KNU 5 & 6 FSAR

COMPARISON TABLES

Table 1.3-1

NSSS VENDOR SUPPLIED COMPONENTS COMPARISON WITH SIMILAR FACILITY DESIGNS  
(Sheet 26 of 33)

Chapter	System/Parameter	KNU 5 & 6	Maanshan	Shearon Harris
6	Minimum water volume at operating conditions, ft <sup>3</sup> (each)	1,000	1,000	1,000
	Nominal boron concentration, ppmB	1,950	1,950	2,000
	Boron injection tank design parameters			
	Number	1	1	1
	Total volume, gal	900	900	900
	Nominal boric acid concentration, ppmB	21,000	21,000	21,000
	Design pressure, psig	2,735	2,735	2,735
	Design temperature, °F	300	300	300
	Operating temperature, °F	155-175	155-175	155-175
	Heater banks, number	2	2	2
	Heater power, kW/heater bank	6	6	6

1.3-27

KNU 5 & 6 FSAR

COMPARISON TABLES

Table 1.3-1

NSSS VENDOR SUPPLIED COMPONENTS COMPARISON WITH SIMILAR FACILITY DESIGNS  
(Sheet 27 of 33)

Chapter	System/Parameter	KNU 5 & 6	Maanshan	Shearon Harris
6	Boron injection surge tank parameters			
	Number	1	1	1
	Total volume, gal	75	75	75
	Design pressure, psig	Atmos- pheric	Atmos- pheric	Atmos- pheric
	Operating pressure, psig	Atmos- pheric	Atmos- pheric	Atmos- pheric
	Design temperature, °F	200	200	200
	Operating temperature, °F	155-175	155-175	155-175
	Heater banks, number	1	1	1
	Heater bank power, kW	6	6	6



Table 1.3-1  
NSSS VENDOR SUPPLIED COMPONENTS COMPARISON WITH SIMILAR FACILITY DESIGNS  
(Sheet 28 of 33)

Chapter	Valves		KNU 5 & 6	Maanshan	Shearon Harris
6	1. All motor-operated valves which must function on SIS	Maximum opening or closing time:			
	a. up to and including 8 in.	Time, s	15	15	15
	b. Over 8 in.	Valve stem travel, in./min	49	49	49
	2. All other motor-operated valves	Maximum opening or closing time:			
	a. Up to and including 8 in.	Valve stem travel, in./min	12	12	12
	b. over 8 in.	Time, s	120	120	120
	3. Leakage				
	a. Conventional globe valves	Disc leakage, cm <sup>3</sup> /h/in. of nominal pipe size	3	3	3

본 문서는 한국수력원자력(주)이 정보 공개용으로 작성한 문서입니다.

Table 1.3-1  
NSSS VENDOR SUPPLIED COMPONENTS COMPARISON WITH SIMILAR FACILITY DESIGNS  
(Sheet 29 of 33)

Chapter	Valves		KNU 5 & 6	Maanshan	Shearon Harris
6	b. Gate valves	Backseat leakage (when open), cm <sup>3</sup> /h/in. of stem diameter	1	1	1
		Disc leakage, cm <sup>3</sup> /h/in. of nominal pipe size	3	3	1
	c. Check valves	Backseat leakage (when open), cm <sup>3</sup> /h/in. of stem diameter	1	1	1
		Disc leakage, cm <sup>3</sup> /h/in. of nominal pipe size	3	3	3
	d. Diaphragm valves	Disk leakage	None	None	None
	e. Pressure relief valves	Disk leakage, cm <sup>3</sup> /h/in. of nominal pipe size	3	3	3
	f. Accumulator	Disk leakage, cm <sup>3</sup> /h/in. of nominal pipe size	3	3	3

1.3-30

KNU 5 & 6 FSAR

COMPARISON TABLES

Table 1.3-1

NSSS VENDOR SUPPLIED COMPONENTS COMPARISON WITH SIMILAR FACILITY DESIGNS  
(Sheet 30 of 33)

Chapter	Chapter Title System/Component	KNU 5 & 6	Significant Similarities to MNPS	Significant Differences with MNPS
7	Instrumentation and controls			
	Reactor trip system	Section 7.2	System functions are similar	None
	Engineered safety features systems	Section 7.3	System functions are similar	None
	Systems required for safe shutdown	Section 7.4	System functions are similar	None
	Safety-related display instrumentation	Section 7.5	Parametric display is similar	None
	Other systems required for safety	Section 7.6	Operational functions are similar	None
	Control systems not required for safety	Section 7.7	Operational functions are similar	None

1.3-31

KNU 5 & 6 FSAR

COMPARISON TABLES

본 문서는 한국수력원자력(주)이 정보 공개용으로 작성한 문서입니다.

Table 1.3-1

NSSS VENDOR SUPPLIED COMPONENTS COMPARISON WITH SIMILAR FACILITY DESIGNS  
(Sheet 31 of 33)

Chapter	System/Parameter	KNU 5 & 6	Maanshan	Shearon Harris
9	CVCS design	Subsection 9.3.4		
	General			
	Seal water supply flow rate, for three reactor coolant pumps, nominal, gpm	24	24	24
	Seal water return flow rate, for three reactor coolant pumps, nominal, gpm	9	9	9
	Leakage flow:			
	Normal, gpm	75	75	75
	Maximum, gpm	120	120	120
	Charging flow (excludes sealwater):			
	Normal, gpm	60	60	60
	Maximum, gpm	105	105	105
	Temperature of letdown reactor coolant enter- ing system, °F	560	560	<560

1.3-32

KNU 5 & 6 FSAR

COMPARISON TABLES

Table 1.3-1

NSSS VENDOR SUPPLIED COMPONENTS COMPARISON WITH SIMILAR FACILITY DESIGNS  
(Sheet 32 of 33)

Chapter	System/Parameter	KNU 5 & 6	Maanshan	Shearon Harris
9	Temperature of charging flow directed to RCS, °F	≥485	≥485	>485
	Temperature of effluent directed to boron recycle system, °F	115	115	115
	Centrifugal charging pump bypass flow (each), gpm	60	60	60
	Amount of 4% boric acid solution required to meet cold shutdown requirements shortly after full power operation, gal	11,300	11,300	11,300

1.3-33

KNU 5 & 6 FSAR

COMPARISON TABLES



Table 1.3-1

NSSS VENDOR SUPPLIED COMPONENTS COMPARISON WITH SIMILAR FACILITY DESIGNS  
(Sheet 33 of 33)

Chapter	Chapter Title System/Component	References	Significant Similarities	Significant Differences
11.0	Radioactive waste management			
	Source terms	Section 11.1	Maanshan and Shearon Harris	None
14.0	Initial tests and operation	Chapter 14	Similar to Maanshan and Shearon Harris	None
15.0	Accident analyses	Chapter 15	Similar to Maanshan and Shearon Harris	This sec- tion has been written to conform to USNRC R.G. 1.70 Rev. 02  This sec- tion has been written to conform to USNRC Standard Technical Specifica- tions, Rev. 4

357

KRN 3&4 FSAR

COMPARISON TABLES

1.3-34

Table 1.3-2

PLANT COMPONENTS OTHER THAN NSSS COMPARISON WITH  
SIMILAR FACILITY DESIGNS (Sheet 1 of 3)

Chapter No.	System/Parameter	References	KNU 5 & 6	Maanshan	SNUPPS	Pebble Springs
3	Containment type	Section 3.8	Steel-lined post-tensioned pre-stressed concrete cylinder, hemispherical dome roof	Steel-lined post-tensioned pre-stressed concrete cylinder, hemispherical dome roof	Steel-lined post-tensioned pre-stressed concrete cylinder, hemispherical dome roof	Steel-lined post-tensioned pre-stressed concrete cylinder, hemispherical dome roof
	Leak rate, %/d		0.1 (24 h), 0.05 (after 24 h)	0.1 (24 h), 0.05 (after 24 h)	0.2 (24 h), 0.01 (after 24 h)	0.1
	Design pressure, psig		60	60	60	60
	Free volume, 10 <sup>6</sup> ft <sup>3</sup>		2.15	2.0	2.50	2.45
	Diameter/height, ft		130/195	130/195	140/205	130/225
6	Containment spray	Paragraph 6.2.2.1				
	Number of pumps		2	2	2	2
	Design capacity, ea gal/min		3,000 (Injection) 3,650 (Recirculation)	3,000 (Injection) 3,650 (Recirculation)	3,165 (Injection) 3,750	3,350
	Spray additive		NaOH	NaOH	NaOH	Hydrazine
	Containment coolers	Paragraph 6.2.2.2				
	Type		Fan coolers	Fan coolers	Fan coolers	Fan coolers
	Number of units		4	4	4	6
	Capacity, 10 <sup>6</sup> btu/h		50	50	110	97
8	Onsite power systems, ac	Subsection 8.3.1				
	Generator prime mover		Diesel engine	Diesel engine	Diesel engine	Diesel engine
	Number of units		2	2	2	2
	Capacity, ea, kW		7,000	7,000	6,200	5,000
9	Ultimate heat sink	Subsection 9.2.5				
	Type		East Sea	Nan Wan Bay	(a)	Reservoir
	Backup		None	None		Spray pond
	Condensate Storage facility	Subsection 9.2.6				
	Capacity, 10 <sup>3</sup> gal		900	750	450	500
	Plant fire protection	Subsection 9.5.1				
	Water source		Tank storage	Tank storage	(b)	Reservoir
	Backup source		None	None		None

Table 1.3-2

PLANT COMPONENTS OTHER THAN NSSS COMPARISON WITH  
SIMILAR FACILITY DESIGNS (Sheet 2 of 3)

Chapter No.	System/Parameter	References	KNU 5 & 6	Maanshan	SNUPPS	Pebble Springs
10	Diesel generators	Subsection 9.5.4	7	7	7	7
	Fuel oil storage capacity, per diesel operating at full power, days					
	Turbine-generator output, MWe	Section 10.2	993	951.8	1,186	1,313
	Main steam supply	Section 10.3				
	Total steam flow, 10 <sup>6</sup> lb/h		12.29	12.29	15.13	15.30
	Steam generator outlet pressure, psia		964	964	1,000	1,060
	Steam generator outlet temp, °F		540.2	540	544.6	605
	Main condensers	Subsection 10.4.1				
	Type		Single pressure	Single pressure	Multiple pressure	Single pressure
	Pressure, in. HgA		1.5	2.54	2.06/2.56/3.22	1.5
	Turbine bypass	Subsection 10.4.4				
	Capacity, % of rated load main steam flow		40 (to condenser) 30 (to atmosphere)	32 (to condenser) 53 (to atmosphere)	40	40
	Circulating water	Subsection 10.4.5				
	Type		Once-through, East Sea	Once-through, Nan Wan Bay	(c)	Closed system, reservoir
	Auxiliary feedwater pump prime movers	Subsection 10.4.9	1 steam turbine, 2 electric motors 1082 (turbine), 554 (motor)	1 steam turbine, 2 electric motors 1084 (turbine), 554 (motor)	1 steam turbine, 2 electric motors 1145 (turbine), 575 (motor)	2 diesel engines, 2 electric motors 600 (engine), 600 (motor)
	Rated flowrate, ea gal/min					

1.3-36

KNU 5 & 6 FSAR

COMPARISON TABLES

Table 1.3-2

PLANT COMPONENTS OTHER THAN NSSS COMPARISON WITH  
SIMILAR FACILITY DESIGNS (Sheet 3 of 3)

Chapter No.	System/Parameter	References	KNU 5 & 6	Maanshan	SNUPPS	Pebble Springs
11	Radioactive waste management					
	Liquid waste systems tankage	Section 11.2	95,000 gal	95,000 gal	65,000 gal	223,000 gal
	Gaseous waste systems holdup time(MIN.) system type	Section 11.3	45d Charcoal delay	45d Charcoal delay	NA (zero release system) Decay tanks	45d Decay tanks
	Solid waste management solidification agent	Section 11.4	Cement	Cement	Cement	Undecided

a. Ultimate heat sink (SNUPPS)

- Callaway (2 unit site) - Two 4-cell mechanical draft cooling towers with a retention pond as makeup source
- Sterling - Once-through system utilizing Lake Ontario
- Wolf Creek - Cooling pond

b. Plant fire protection (SNUPPS)

- Callaway - Two 300,000 gallon storage tanks; water from supply to potable water
- Sterling - Directly from Lake Ontario by fire pumps and pressurizing pump at circulating water system intake
- Wolf Creek - Circulating water screen house intake bay

c. Circulating water (SNUPPS)

- Callaway - Closed system, natural draft cooling tower, flowrate  $550 \times 10^3$  gal/min
- Sterling - Once-through system, Lake Ontario, flowrate  $795 \times 10^3$  gal/min
- Wolf Creek - Closed system, man-made lake, flowrate  $550 \times 10^3$  gal/min

4

KNU 5 & 6 FSAR

COMPARISON TABLES

April 1985

1.3-37

Amendment 4



KNU 5 & 6 FSAR

COMPARISON TABLES

Table 1.3-3

SIGNIFICANT CHANGES FROM THE PSAR  
(Sheet 1 of 3)

FSAR Charge	FSAR Chapter/ Section	Reason for Change
1. Fuel design	4.0, 15.0 & 16.0	Shorter burnable poison rods and reduced number of burnable poison rods
2. Safety grade cold shutdown added	5.4, 6.3, 9.3	Regulatory Guide 1.139 adopted
3. Cold over-pressure mitigation	5.2, 7.6, 16	Provides additional RCS overpressure protection during low temperature water solid operation
4. Fuel loading design change	4	To reduce core radial leakage
5. Automated sump suction valve opening	6.3	Post-accident switch-over from ECCS injection to recirculation improved.
6. Diesel generator output increased from 6,000 to 7,000 kW	8.3	Increased power requirements
7. Fuel storage capacity	9.1	Increase capacity
8. Condensate water storage decreased from 1,500,000 to 900,000 gallons	9.2.6	Incorporation of safety grade cold shutdown
9. Addition of a firewater system designed to withstand SSE loads	9.5.1	Assures availability of water for fighting fires following an SSE

433



KNU 5 & 6 FSAR

COMPARISON TABLES

Table 1.3-3

SIGNIFICANT CHANGES FROM THE PSAR  
(Sheet 2 of 3)

FSAR Change	FSAR Chapter/ Section	Reason for Change
10. Additional of a startup feedwater pump	10.4	To minimize use of auxiliary feedwater system during normal plant startup and shutdown.
11. Seismic Category I instrument air storage tanks added	9.3	Implement Reg. Guide 1.139
12. Second steam generator PORV added per main steam lines	10.3	Incorporation of safety grade cold shutdown
13. LRS second evaporator added	11.2	To optimize system availability and performance
14. Fuel leak detection system	9	Detection of clad leakage
15. Reactor coolant purity control system	9	Better chemistry control of reactor makeup water and recycled boric acid
16. Metal impact monitoring system	4	Detects objects or metal in the RCS
17. Revised control rod pattern	4	To insure nonpositive moderator coefficient
18. Full load rejection capability	5, 10	Provides capability for turbine trip from full load without reactor trip

433

Table 1.3-3  
SIGNIFICANT CHANGES FROM THE PSAR  
(Sheet 3 of 3)

FSAR Change	FSAR Chapter/Section	Reason for Change
19. Critical leak monitoring system	5	Detects vibration in RCS piping & components
20. Automatic steam generator level control	7, 10	Automatic control of steam generator water level at low power
21. Auxiliary shut-down panel design changed to two redundant panels and upgraded to meet Seismic Category 1 criteria	7	To meet separation single failure, and SSE criteria.
22. Control isolation devices added to train is auxiliary shutdown panel	7	Protect one train of of hot shutdown equipment
23. RWST water storage increased from 450,000 to 540,000 gallons and additional level instrumentation installed.	6, 9	Increase capacity to ensure adequate water for ECCS operation
24. High density concrete added to auxiliary building shielding.	12	Improve effectiveness of shielding.

## KRN 3 & 4 FSAR

### 1.4 IDENTIFICATION OF AGENTS AND CONTRACTORS

#### 1.4.1 APPLICANT - KOREA HYDRO & NUCLEAR POWER COMPANY

KOREA HYDRO & NUCLEAR POWER COMPANY(KHNP), the sole government organized power utility in Korea, has total responsibility for construction and operation of KRN 3 & 4. KHNP has a long history of building and operating conventional electric generating plants. The overall KHNP organization is shown in figure 13.1-1. The home office of KHNP is in Gyeongju, Gyeongsangbuk-Do which is located about 33 miles north-northeast of the Kori Nuclear Power site. KHNP is the sole applicant for the construction permit and facility license for KRN 3 & 4 .

554

KHNP, as owner, is responsible for the design, construction, and operation of these units. Overseas Bechtel, Incorporated, (Bechtel) assisted KHNP in engineering, procurement, and construction management. Westinghouse Electric Corporation" supplied the nuclear steam supply systems and provided the services for nuclear fuel fabrication. GEC Turbine Generators, Ltd., supplied the turbine and Hitachi supplied the generators.

390

The Nuclear Power Construction Department (NPCD) of KHNP is responsible for the construction of KRN 3 & 4, and the Nuclear Power Generation Department (NPGD) of KHNP is responsible for the safe operation and maintenance of the units in compliance with technical specifications and other applicable requirements. The organization of NPCD and NPGD is shown in figure 13.1-1. Plant organization and responsibilities for plant operation are described in subsections 13.1.2 and 13.1.3. Plant organization and responsibilities during preoperational testing, startup, and initial operation are described in chapter 14.

#### 1.4.2 BECHTEL'S QUALIFICATIONS AND EXPERIENCE

Overseas Bechtel, Incorporated, has been retained by KHNP to provide architectural and engineering services, including procurement, construction, and technical direction and services for KRN 3 & 4.

390

Bechtel has been continuously engaged in construction and engineering activities since 1898. Since the close of World War II, Bechtel has placed strong emphasis on electrical power-generation projects. During this period, Bechtel has been responsible for the design and/or construction of over 237 thermal generating units, representing more than 126,000,000 kW of new generating capacity. Of this number, a nuclear capacity of more than 65,000,000 kW has been, or is being, engineered.

## IDENTIFICATION OF AGENTS AND CONTRACTORS

The ratings of thermal generating plants designed by Bechtel range to 1,470,000 kW per unit and include most types of station designs and arrangements, such as reheat and non-reheat, indoor and outdoor stations, single and multiple units, and wide ranges of steam conditions up to 3500 psig, 1050/1000F. Also, some of the larger units are fully automated and computer controlled. The majority of contracts for these facilities provided Bechtel with complete responsibility for engineering, construction, and startup.

For more than 26 years Bechtel has been actively working on nuclear projects involving power plants, as well as such facilities as nuclear accelerators, research laboratories, hot cells, experimental reactors, and nuclear fuel processing plants. The responsibilities have covered design, construction, startup, site surveys, license applications, feasibility studies, and equipment procurement.

### 1.4.3 WESTINGHOUSE'S QUALIFICATIONS AND EXPERIENCE AS A SUPPLIER OF NUCLEAR STEAM SUPPLY SYSTEMS

Westinghouse Electric Corporation (Westinghouse) is responsible for supplying the NSSS and fuel for Korea Units 5 & 6.

Westinghouse has designed, developed, and manufactured nuclear power facilities since the 1950s, beginning with the world's first large central station nuclear power plant (Shippingport), which has produced power since 1957. Completed or presently contracted commercial nuclear capacity totals in excess of 97,000 megawatts. Westinghouse pioneered new nuclear design concepts, such as chemical shim control of reactivity and the rod cluster control concept, throughout the last two decades. Westinghouse manufacturing facilities include the largest commercial nuclear fuel fabrication facility in the world, and the world's most modern heat transfer equipment production facility as well as other facilities producing NSSS components. Table 1.4-1 lists all Westinghouse pressurized water reactor (PWR) plants to date, including those plants currently under construction or on order.

The U.S. Nuclear Regulatory Commission (NRC) and the Edison Power Research Institute have contracted with Westinghouse for research into NSSS-related activities. Westinghouse experience was also utilized by the NRC and Metropolitan Edison immediately following the Three Mile Island Unit 2 accident and remains as a heavy participant with the Westinghouse Owner's Group of utilities in addressing the NRC's action plan for corrective actions.



IDENTIFICATION OF  
AGENTS AND CONTRACTORS

1.4.3.1 Plants in Operation

Westinghouse PWR plants in operation are as follows:

A. Shippingport

Shippingport was the world's first large central station nuclear power plant. The reactor plant was designed by the Bettis Atomic Power Laboratory, which is operated by Westinghouse under an NRC contract. Shippingport's PWR has produced power for Duquesne Light Company since December 1957.

B. Yankee-Rowe

Singled out by the NRC as a "Nuclear Success Story," Yankee-Rowe went on line in November 1960. Owned and operated by the Yankee Atomic Electric Company, Yankee-Rowe has progressed from an initial rating of 120 MWe to its present 175 MWe rating. Westinghouse supplied the NSSS and the turbine generator.

C. Trino Vercellese (Enrico Fermi)

The Trino Vercellese nuclear plant was one of the first Westinghouse-designed plants to incorporate chemical shim control of reactivity. Chemical shim has since become a standard feature of Westinghouse PWR control. Trino Vercellese achieved initial criticality in June 1964 and began power operation in October 1964. The plant is rated at 260 MWe.

D. Chooz (Ardennes)

The Chooz plant is unique in that the Westinghouse PWR and its auxiliaries are housed in man-made caverns. Ardennes, a joint Franco-Belgian undertaking, owned and operated by the Societa d'Energie Nucleaire Franco-Belge des Ardennes (SENA), is located in France near the French-Belgian border. Chooz achieved initial criticality in October 1966 and began power operation in 1967.

E. San Onofre No. 1

San Onofre No. 1 employs the Westinghouse-developed rod cluster control concept which has since become a standard feature of the Westinghouse PWR. Owned by the Southern California Edison Company and the San Diego Gas and Electric Company, the 450 MWe



IDENTIFICATION OF  
AGENTS AND CONTRACTORS

plant is located near San Clemente, California. Westinghouse supplied the NSSS and the turbine generator. Initial criticality was achieved in June 1967, and power operation began in January 1968.

F. Haddam Neck (Connecticut Yankee)

Owned and operated by the Connecticut Yankee Atomic Power Company, this plant went critical in July 1967 and attained full power operation in December 1967. Like San Onofre No. 1, the plant employs rod cluster control in conjunction with chemical shim control. Westinghouse supplied the NSSS and the turbine generator. The plant has been uprated to 575 MWe.

G. Jose Cabrera - (Zorita)

The Jose Cabrera station is located near Zorita, Spain. The 153 MWe plant employs rod cluster control, chemical shim control and a Zircaloy-clad core. Construction began in mid-1965, and power operation began in 1968. Jose Cabrera is owned and operated by the Union Electrica, S.A., a Spanish utility.

H. Beznau No. 1 and No. 2

Beznau No. 1, Switzerland's first commercial nuclear power plant, achieved initial criticality in June 1969 and supplied power to the system in July 1969. The 350 MWe plant was designed and constructed by the Westinghouse-Brown Boveri Consortium for the owner/operator utility, Nordostschweizerische Kraftwerke A.G. The plant started producing power less than 4 years after award of the plant contract. Beznau No. 2 achieved criticality in October 1971 and began commercial operation in early 1972.

I. Robert Emmett Ginna

The Robert Emmett Ginna Plant, owned and operated by Rochester Gas and Electric Corporation, is located in New York on the south shore of Lake Ontario. Westinghouse supplied the 490 MWe plant on a turnkey basis. Construction began in April 1966 with initial criticality being achieved in November 1969 (just 42 months after start of construction). Power was supplied to the system in December 1969.

IDENTIFICATION OF  
AGENTS AND CONTRACTORS

J. Mihama No. 1 and Takahama No. 1

These plants are owned by the Kansai Electric Power Company, Inc. Mihama No. 1 is a two-loop, 320 MWe unit and marks the beginning of a line of Westinghouse PWRs supplying the generation needs of the Far East. Westinghouse International Company was the prime contractor for the Mihama project, supplying the NSSS engineering, nuclear fuel, and some major system components. Mihama No. 1 required only 44 months from the start of site construction to first power production in August 1970. Takahama No. 1 is a three-loop, 780 MWe unit. Initial criticality was achieved in March 1974.

K. H.B. Robinson No. 2

This plant is a three-loop, 707 MWe unit which was built on a turnkey basis for the Carolina Power and Light Company. The plant is located at a site near Hartsville, South Carolina, on a man-made cooling lake. The construction permit was granted in April 1967. The plant achieved criticality in August 1970 and first power to system in October 1970.

L. Point Beach No. 1 and No. 2

The Point Beach Project consists of two 497 MWe units, which were built on a turnkey basis for the Wisconsin Michigan Power Company and the Wisconsin Electric Power Company. The plants are located near Two Creeks, Wisconsin, 90 miles north of Milwaukee on Lake Michigan. This was the first two-unit station to utilize many common facilities and shared auxiliary systems. The construction permit for Point Beach No. 1 was granted in July 1967 with initial criticality and first power to the system in November 1970. Point Beach No. 2 went critical in May 1972 and was available for commercial operation in October 1972.

M. Surry No. 1 and No. 2

The Surry Power Station, two three-loop 822 MWe units, is owned by the Virginia Electric and Power Company. The James River Station is about 30 miles from Norfolk, Virginia. First criticality on Surry No. 1 was achieved in July 1972. Commercial operation began in September 1972. Initial criticality on Surry No. 2 was achieved in March 1973.

IDENTIFICATION OF  
AGENTS AND CONTRACTORS

N. Turkey Point No. 3 and No. 4

Florida Power and Light Company is the owner of a four-unit station on Biscayne Bay, Florida. Turkey Point Nos. 3 and 4 of the station are three-loop, 745 MWe plants. Commercial status for Turkey Point No. 3 was achieved in December 1972. Initial criticality for Turkey Point No. 4 was achieved in June 1973.

O. Indian Point No. 2 and No. 3

Consolidated Edison Company of New York operates three nuclear units located in Buchanan, New York; two (Units 1 and 2) are owned by the company and one (Unit No. 3) is owned by the Power Authority of the state of New York. Units 2 and 3 are Westinghouse PWRs rated at 873 and 965 MWe respectively. Indian Point No. 2 achieved initial criticality in May 1973 and Indian Point No. 3 achieved initial criticality in April 1976.

P. Prairie Island No. 1 and No. 2

Northern States Power Company is the owner of these two-loop, 530 MWe units located in Welch, Minnesota. Initial criticality was achieved in December 1973 for Prairie Island No. 1, and in December 1974 for Prairie Island No. 2.

Q. Zion No. 1 and No. 2

Commonwealth Edison Company is the owner of these two four-loop, 1050 MWe units. The units are located on Lake Michigan near Zion, Illinois. Initial criticality was achieved in June 1973 for Zion No. 1 and in December 1973 for Zion No. 2.

R. Kewaunee

Wisconsin Public Service Corporation, Wisconsin Power and Light Company, and Madison Gas and Electric Company are the owners of this two-loop, 541 MWe plant located in Kewaunee, Wisconsin. Initial criticality was achieved in March 1974.

S. Ringhals No. 2

Statens Vattenfallsverk (SSPB) is the owner of this three-loop, 822 MWe unit located in Sweden. Initial criticality was achieved in June 1974.

IDENTIFICATION OF  
AGENTS AND CONTRACTORS

T. Donald C. Cook No. 1 and No. 2

Indiana and Michigan Electric Company is the owner of this four-loop, 1090 MWe plant located in Bridgman, Michigan. This plant is the first to use the Westinghouse Ice Condenser Containment design. Initial criticality was achieved in January 1975 for Unit 1 and March 1978 for Unit 2.

U. Trojan

This four-loop, 1130 MWe plant is jointly owned by Portland General Electric Company, Eugene Water and Electric Board, and Pacific Power and Light Company. In addition to being the first commercial nuclear plant to operate in the Pacific Northwest (located on the Oregon shore of the Columbia River near Rainier, Oregon), Trojan is the first 17 x 17 fuel-rod-per-assembly plant to achieve criticality. Initial criticality was achieved in December 1975.

V. Beaver Valley No. 1

This three-loop, 852 MWe plant is jointly owned by Duquesne Light Company, Ohio Edison Company, and Pennsylvania Power Company. Beaver Valley No. 1 is located on the Ohio River, 22 miles northwest of Pittsburgh, Pennsylvania. Commercial operation began in early 1976.

W. Salem No. 1 and No. 2

Salem No. 1 and 2, owned jointly by the Public Service Electric and Gas Company, Philadelphia Electric Company, Atlantic Electric Company, and Delmarva Power and Light Company, is located on Artificial Island, a man-made peninsula in Salem County, New Jersey. The 1090 MWe, four-loop plant achieved initial criticality for Unit 1 in late 1976 and Unit 2 achieved criticality in August 1980.

X. North Anna No. 1 and No. 2

Virginia Electric and Power Company owns the two approximately 907 MWe (net) plants located 40 miles north of Richmond, Virginia on Lake Anna. Unit 1 achieved criticality in May 1978 and Unit 2 achieved criticality in June 1980.



IDENTIFICATION OF  
AGENTS AND CONTRACTORS

Y. Joseph M. Farley No. 1 and No. 2

The two 899 MWe (net) Alabama Power Company units are located at Dothan, Alabama, (approximately 180 miles south-southwest of Atlanta, Georgia. Unit 1 achieved criticality in August 1977, Unit 2 achieved criticality in February 1981.

Z. Sequoyah No. 1 and No. 2

The two units approximately 1148 MWe (net) are located on the Tennessee River near Chattanooga, Tennessee. These units are owned by Tennessee Valley Authority. Sequoyah No. 1 received a full power license in September 1980.

1.4.3.2 Westinghouse Facilities

Westinghouse, in its effort to plan for the future, has developed a broad range of facilities to satisfy the needs of the nuclear industry. The following paragraphs briefly describe these facilities:

A. Columbia Plant, Nuclear Fuel Division

The Columbia Plant is capable of performing all operations necessary to manufacture finished nuclear fuel assemblies. These operations include conversion of uranium hexafluoride to uranium dioxide powder, fabrication of fuel assembly grids, complete pellet loading, and final fabrication of assemblies. The plant, located at Columbia, South Carolina, began full production in early 1970. The Columbia Plant is the largest commercial nuclear fuel fabrication facility in the world.

B. Tampa Division\*

The Tampa Division Plant is the world's most modern heat transfer equipment production facility. The plant has 236,000 square feet of working space with two manufacturing aisles for the production of steam generators and pressurizers. Transportation facilities include four railroad spurs and a complete barge slip and dock facility for water shipment to all parts of the world. The Tampa Division Plant made its first steam generator and pressurizer shipment in September 1969.

\*All manufacturing from the Tampa Division Plant has been transferred to the Westinghouse Pensacola Division.



IDENTIFICATION OF  
AGENTS AND CONTRACTORS

C. Pensacola Division

The Pensacola Division Plant, located on Escambia Bay on the northwest coast of Florida, is a new 140,000-square-foot manufacturing plant for producing precision reactor vessel internals. Contributing to the precision manufacturing capability is an environmental control system which minimizes year-round temperature changes throughout the shop area. Transportation facilities of the plant include a railroad spur which permits loading and unloading inside the shop, and access to barge loading facilities on Escambia Bay. Pensacola shipped its first package of reactor internals in July 1970.

D. Cheswick Plant, Electro-Mechanical Division

The Electro-Mechanical Division was established in Cheswick, Pennsylvania, in 1953 to manufacture canned motor primary coolant pumps for nuclear reactors. Today, the product line has expanded to include shaft seal pumps (reactor coolant pumps), valves from 4 inches to 31 inches, and control rod drive mechanisms, essential components of the Westinghouse PWR. The facility occupies 250,000 square feet and now contains the most modern facilities available for the production and testing of nuclear plant components.

E. Specialty Metals Division

The Specialty Metals Division located in Blairsville, Pennsylvania, was completed in late 1967. Several essential PWR component processes are accomplished at Blairsville, including: the precision manufacture of Inconel tubing for steam generators, and the complete processing of zircaloy seamless tubing for nuclear fuel cladding. At Blairsville, complete quality control facilities are utilized for the evaluation and analysis of all specialty metal products used in Westinghouse nuclear systems.

F. Westinghouse Nuclear Center

The headquarters of Westinghouse Nuclear Energy Systems is located just east of Pittsburgh, in Monroeville, Pennsylvania. Operating primarily as a headquarters and engineering facility, the complex houses many of the divisions which encompass Westinghouse's nuclear activities associated with the electric utility industry.

IDENTIFICATION OF  
AGENTS AND CONTRACTORS

G. Zion Nuclear Training Center

The Westinghouse Electric Corporation and the Commonwealth Edison Company of Chicago have built and are operating a nuclear training center at Zion, Illinois. The 28,000-square-foot training center contains classrooms, a training reactor, training material center, video recording facilities, and multi-plant nuclear power plant simulators. Westinghouse staffs and operates the center, supplies all the equipment required, and is responsible for the development and presentation of all training programs. Commonwealth Edison provided the building, access to the Zion nuclear units for conducting in-plant observation training, and advises and assists Westinghouse in developing training programs.

1.4.4 GENERAL ELECTRIC COMPANY'S QUALIFICATIONS AS A SUPPLIER  
OF TURBINES

The General Electric Company (GEC), Limited, designed, fabricated, and delivered the turbine, as well as provided technical assistance for the installation and startup of this equipment.

GEC Limited has a long history in the application of turbine generators in nuclear power plants.

1.4.4.1 Contractor Description

GEC Power Engineering Limited, one of five functional management subsidiaries, is the largest specialist group of its kind in Europe and provides for every facet of power generation, transmission, and distribution. The Group employs about 25,000 people and its annual sales approach \$500 million. The GEC Power Engineering Group provides a complete capability in the power field.

The Group, both directly and through AEI and English Electric, has had extensive experience in the design and construction of complete nuclear power plants. It was the lead contractor in the Consortia which built Tokai Mura, Hunterston A, Hinckley Point A, Sizewell A, and Wylfa nuclear power stations. Additionally, the Group has many year's experience as lead contractor for the design and construction of complete fossil, hydro, and gas turbine stations in all continents of the world.

GEC generating plant and ancillary equipment is installed in fossil and nuclear fueled power stations throughout the world. GEC is the major supplier of 660 MW turbine generators

IDENTIFICATION OF  
AGENTS AND CONTRACTORS

to Britain's home electricity generating boards, and, in the overseas market, the 1200 MW sets for the U.S.A. are among the largest produced anywhere.

The Group, through its trading subsidiaries, is actively engaged in a number of power station contracts in the U.S.A., Canada, Africa, the Middle East, Scandinavia, and the Far East.

GEC, an international leader in power transmission and distribution, offers a wide range of circuit breakers and switchgear: also transformers and reactors, up to the largest capacities required. In addition, GEC supplies completely engineered schemes for dc transmission, and the compensation of ac transmission and distribution networks using either synchronous or static compensation and employing GEC's unique designs of saturated reactor.

GEC Turbine Generators Limited is the principal member of the GEC Power Engineering Group. The GEC Turbine Generator Company is the major supplier to the United Kingdom Central Electricity Generating Board, itself the world's largest interconnected electricity supply system. It has a long history of technical development, innovation, and achievement in large-sized units and has 57 units of 500 MW or greater unit size installed or on order, totaling 34,334 MW.

The company has a similarly impressive record in the nuclear field and has 43 units totaling 15,094 MW installed or on order for nuclear power stations in Britain, the U.S.A., Canada, Sweden, Japan, and India. Since the company's first nuclear turbine generator started operation 15 years ago, 289 unit years of nuclear turbine operating experience have been accumulated in association with a variety of reactor types, Magnox, Advanced Gas Cooled, Pressurized water, Boiling Water, Candu, Steam Generating Heavy Water, High Temperature Gas Cooled and Fast Reactors. Nuclear units of 660 MW are already operational and 12 more units of 600 to 1200 MW are in advanced stages of constructions.

The turbine being supplied by GEC for this project is one of GEC's current family of 600 MW to 1200 MW, 1800 rpm turbine generator designs for nuclear power stations. Existing contracts for this class of equipment are the 600 MW Ko-Ri I, 650 MW Ko-Ri II and the 1200 MW Enrico Fermi and San Onofre machines.

The 1200 MW unit for Enrico Fermi (Detroit, U.S.A.) was shipped in October 1974, and the turbine for the first San Onofre station was shipped in March 1977. The 600 MW unit for Ko-Ri I was shipped in 1975 and is currently in use.

IDENTIFICATION OF  
AGENTS AND CONTRACTORS

The extensive experience of GEC in the design, supply, and construction of nuclear turbine generators and associated mechanical and electrical auxiliaries, and in the management of complete nuclear and thermal power stations, coupled with the accumulated experience of power station construction in Korea, makes GEC well qualified to participate in this nuclear project.

1.4.4.2 Contractor Experience

1.4.4.2.1 General Design Parameters

In the context of a reference plant already manufactured or in service, it is pertinent to assess various design criteria in order to demonstrate that component design for the KRN 3 & 4 machines falls within existing experience. Such design criteria are listed below for the following principal components:

- A. High pressure turbine
- B. Low pressure turbine
- C. Control interface
- D. Moisture separators and reheaters

390

The criteria listed in tables 1.4-2 and 1.4-3 cover details such as sizes, weights, flow parameters, and stress parameters as appropriate.

1.4.4.2.1.1 High Pressure Turbine. Three parameters may be considered in assessing the relevance of one design relative to another:

- A. Volumetric flow at inlet to the blading, measured as  $\frac{GV}{N}$ , where:

G = mass flow at turbine inlet

V = specific volume at inlet

N = number of flows in HP cylinder

This parameter has relevance to the blading area required, that is, to blade heights and mean diameters.



IDENTIFICATION OF  
AGENTS AND CONTRACTORS

B. Average torque developed in each state ( $T_i$ ), which has relevance to the blading strength.

C. A "sealing duty coefficient"  $S$ , or pressure force per unit of casing length, measured as  $D_i \times \Delta p$ ,

where:

$D_i$  = casing internal diameter

$\Delta p$  = pressure drop across casing

both in the region of the first stage

This has relevance to the sealing duty of the horizontal joint.

These parameters for the reference installations (Kori 1, Ringhals 1 and 2, and San Onofre 2 and 3) are listed in table 1.4-4.

Tables 1.4-5 and 1.4-6 show comparisons of principal rotor and blading dimensions for the reference installations plus the IP rotor for Peterhead 660 MW, 3000 rpm fossil-fired machine, which is representative of 11 similar machines.

1.4.4.2.1.2 Low Pressure Turbine. The low pressure turbines for KNU 5 & 6 are closely similar to those in service at Kori 1 and under construction for Kori 2, Enrico Fermi 2, and San Onofre 2 and 3. In addition, the reheat pressures and temperatures associated with these water-cooled reactor plants have been selected to ensure that the low pressure cylinder exhaust wetness is comparable with the wetness in conventional fossil-fired plant. The vast accumulation of experience on material selection and protective measures obtained from all of these plants has been applied to the turbines for KNU 5 & 6.

1.4.4.2.2 Relevant Design Rating Parameters

As the low pressure turbines offered are very similar or even virtually identical geometrically and in the choice of materials to the low pressure turbines in two of the reference installations, many relevant design rating parameters concerning centrifugal stressing, rotor dynamics, and blading vibration need not be considered here.



IDENTIFICATION OF  
AGENTS AND CONTRACTORS

The remaining relevant design rating parameters which are variable with the steam cycle and design applications are:

G - steam flow through last stage of a low pressure turbine

or  $\frac{G}{A_e}$  - last blade loading

where  $A_e$  - annulus area of last stage blading in the low pressure turbine (2 flows)

With regard to the likelihood of blading tip erosion, GEC has developed for design assessment purposes a sophisticated "erosion criterion number." This takes into account a large number of variables which play a part in the very complex mechanism of droplet formation and their deposition on stationary blading, subsequent stripping off and breakup of large drops followed by impact against the rotating blading. However, since the reference installations employ virtually identical low pressure turbines, it is possible in our relative comparisons to reduce the complexities of the "erosion criterion number" to a very simple expression.

$$\text{Relative erosion criterion: } \propto G \cdot \frac{x}{p^\alpha \cdot c^\beta}$$

where

G - last stage steam flow - (as before in this section)

x - wetness at inlet to the last stage, percent

p - pressure upstream of the last moving blade (at tip)

c - velocity of steam discharging from last stage stationary blading

$\alpha$  - at least 2.0, but probably between 2.0 and 3.0

Kori 1 )  
San Onofre 2 and 3 ) virtually identical complete low pressure turbine

Ringhals 1 and 2 3000 rpm turbine with comparable BWR cycle

The relevant comparative design rating parameters are summarized in tables 1.4-7, 1.4-8, and 1.4-9.

IDENTIFICATION OF  
AGENTS AND CONTRACTORS

1.4.4.2.3 Separators and Reheaters

GEC has operating experience with moisture separator/reheaters of similar design on the Ringhals 400 MW BWR machines. The Ringhals units employ live steam heating only and have extended surface stainless steel tubes welded to stainless-steel-clad forged-steel tubeplates. Apart from some initial baffle damage the separator/reheaters on both machines have given satisfactory performance since 1975.

GEC has manufactured separator/reheaters in 2 x 50 percent units for San Onofre and Enrico Fermi in the U.S.A. to operate with PWR and BWR cycles, respectively. Both San Onofre and Enrico Fermi utilize mild steel extended surface tubing welded to forged steel tubeplates.

1.4.4.2.4 Relevant Design Rating Parameters

Generally these are:

- G - mass flow of wet steam entering the separator
- x - inlet wetness of steam entering the separator
- p - pressure of wet steam entering the separator
- T - temperature of reheated steam leaving the reheater
- $\Delta T$  - approach temperature of reheated steam to live steam saturation temperature
- A - total heat exchange surface of reheater

It is, of course, well known that separation efficiency increases as the pressure decreases.

One of the possible reference installations in which moisture separating and reheating equipment of GED's own design and manufacture is employed is San Onofre Units 2 and 3 and comparative design rating parameters are as shown in tables 1.4-10 and 1.4-11.

IDENTIFICATION OF  
AGENTS AND CONTRACTORS

1.4.5 Hitachi's Qualification As a Supplier of Generators

Hitachi, Limited designed, fabricated, and delivered the turbine generator, as well as provided technical assistance for the installation and startup of this equipment.

Hitachi, Limited has a long history in the application of turbine generators in nuclear power plants.

1.4.5.1 Contractor Description

Hitachi, Limited is the largest electrical machinery manufacturing company in Japan and provides for every facet of power generation, transmission, and distribution. The Group employs about 390,000 people and its consolidated annual sales approach 11,227,000 million JPY. Hitachi provides a complete capability in the power field including boiling water type nuclear power plants.

390

The Group has had extensive experience in the design and construction of complete nuclear power plants. It was the one of consortium contractor of Kashiwazaki - Kariwa unit 6 and 7 of Japanese first ABWRs, Hamaoka unit 5 and was the complete supplier of Shika Unit 2 nuclear power stations of 1350MWe ABWRs. Additionally, the Group has many years' experience as lead contractor for the design and construction of complete fossil, hydro, and gas turbine stations in all over of the world.

Hitachi generating plant and ancillary equipment is installed in fossil and nuclear-fueled power stations throughout the world. Hitachi is the major supplier of 1100 MWe and 1350MWe turbine generators in Japan and in the overseas market.

The Group, through its trading subsidiaries, is actively engaged in a number of power station contracts in the U.S.A., Canada, China, the Middle East, and Korea.

Hitachi, an international leader in power transmission and

KRN 3 & 4 FSAR

IDENTIFICATION OF  
AGENTS AND CONTRACTORS

distribution, offers a wide range of circuit breakers and switchgear: also transformers and reactors, up to the largest capacities required. In addition, Hitachi supplies completely engineered schemes for dc transmission, and the compensation of ac transmission and distribution networks using either synchronous or Static Var Compensation system.

Hitachi has an impressive record in the nuclear field and has 20 units totaling about 18,200 MW installed or on order for nuclear power stations in Japan, Korea, Pakistan and China. Since the company's first nuclear turbine generator started operation 47 years ago, 347 unit years of nuclear turbine generator operating experience have been accumulated in association with a variety of reactor types. Pressurized Water, Boiling Water, Candu reactors. 4 Nuclear units of 1350 MW have been operated and 2 more units of 1350MW are in the stages of constructions in Japan.

The turbine generators being supplied by Hitachi for this project are Hitachi's current family of 700 MW to 1350 MW, 1800 rpm turbine generator designs for nuclear power stations.

390

The extensive experience of Hitachi in the design, supply, and construction of nuclear turbine generators and associated mechanical and electrical auxiliaries, and in the management of complete nuclear and thermal power stations, coupled with the accumulated experience of power station construction of the consortium partner of Doosan Heavy Industrial and Construction Ltd. in Korea, makes Hitachi well qualified to participate in this nuclear project

#### 1.4.5.2 Contractor Experience

##### 1.4.5.2.1 Generator

The generator of KRN 2 is of the same design except its rated capacity and cooler type of that of KRN 1 which has been tested at Hitachi Works and is operated successfully. In addition Hitachi has many experiences of the nuclear generators and the design of KRN 1 & 2 Generators is based on that of Hamaoka unit 3 & 4 generators in Japan.

The design of KRN 3 & 4 generators are also based on Hamaoka unit 3 & 4 generators, however the rated capacity, dimensions are different from those of KRN 1& 2, so the first one, KRN 4 Generator will be tested in Hitachi Works to confirm its required characteristics as same as KRN 1

KRN 3 & 4 FSAR

IDENTIFICATION OF  
AGENTS AND CONTRACTORS

generator. No development work of design parameters is required because Hitachi has been supplied many generators to nuclear power plants as shown in the below table and Hitachi design has been well proved of enough reliability.

Table 1.4-12 compares the principal design parameters for KRN 1, KRN 3 & 4, and Enrico Fermi.

Table: Hitachi supply list to nuclear power plants

Country	Power Station	Capacity (MNA)	Speed (min-1)	Voltage (KV)	Service Year
Japan	Hamaoka-5	1570	1800	22	2005
Japan	Shika-2	1540	1800	24	2006
Japan	Shimane-3	1530	1800	22	2011
Japan	Kashiwazaki Kariwa-6	1540	1500	27	1996
Japan	Fukushima-11-2	1300	1500	19	1984
Japan	Fukushima-11-4	1300	1500	19	1987
Japan	Kashiwazaki Kariwa-5	1300	1500	19	1990
Japan	Kashiwazaki Kariwa-4	1300	1500	19	1994
Japan	Hamaoka-4	1280	1800	22	1993
Japan	Hamaoka-3	1280	1800	22	1987
Japan	Hamaoka-2	940	1800	18	1978
Japan	Onagawa-3	920	1500	20	2002
Japan	Fukushima-1-4	911	1500	17	1978
Japan	Shimane-2	870	1800	15.5	1989
China	Qinshan-III-1	817	1500	22	2003
China	Qinshan-III-2	817	1500	22	2004
Korea	Kori-1	749	1800	22	2005
Japan	Hamaoka-1	626	1800	22	1976
Japan	Shika-1	600	1800	20	1993
Japan	Shimane-1	520	1800	18	1974
Pakistan	Karachi	163	3000	15	1969



Table 1.4-1

WESTINGHOUSE PRESSURIZED WATER REACTOR NUCLEAR POWER PLANTS (Sheet 1 of 15)

Plant	Owner Utility	Location	Scheduled Commercial Operation	MWe Net	Number of Loops
Shippingport	Duquesne Light Company	Pennsylvania	1957	90	4
Yankee-Rowe	Yankee Atomic Electric Company	Massachusetts	1961	175	4
Trino Vercellese (Enrico Fermi)	Ente Nazionale per l'Energia Elettrica (ENEL)	Italy	1965	260	4
Chooz (Ardennes)	Societe d'Energie Nucleaire Franco-Belge des Ardennes (SENA)	France	1967	305	4
San Onofre No. 1	Southern California Edison Co.; San Diego Gas and Electric Co.	California	1968	450	3
Haddam Neck (Connecticut Yankee)	Connecticut Yankee Atomic Power Company	Connecticut	1968	575	4
Jose Cabrera-Zorita	Union Electrica, S. A.	Spain	1969	153	1
Beznau No. 1	Nordostschweizerische Kraftwerke AG (NOK)	Switzerland	1969	350	2

1.4-17

KNU 5 & 6 FSAR

IDENTIFICATION OF AGENTS AND CONTRACTORS

Table 1.4-1

WESTINGHOUSE PRESSURIZED WATER REACTOR NUCLEAR POWER PLANTS (Sheet 2 of 15)

Plant	Owner Utility	Location	Scheduled Commercial Operation	MWe Net	Number of Loops
Robert Emmett Ginna	Rochester Gas and Electric Corporation	New York	1970	490	2
Mihama No. 1	The Kansai Electric Power Company, Inc.	Japan	1970	320	2
Point Beach No. 1	Wisconsin Electric Power Co.; Wisconsin Michigan Power Co.	Wisconsin	1970	497	2
H. B. Robinson No. 2	Carolina Power and Light Co.	South Carolina	1971	707	3
Beznau No. 2	Nordostschweizerische Kraftwerke AG (NOK)	Switzerland	1972	350	2
Point Beach No. 2	Wisconsin Electric Power Co.; Wisconsin Michigan Power Co.	Wisconsin	1972	497	2
Surry No. 1	Virginia Electric and Power Co.	Virginia	1972	822	3
Turkey Point No. 3	Florida Power and Light Co.	Florida	1972	745	3

1.4-18

KNJ 5 & 6 FSAR

IDENTIFICATION OF AGENTS AND CONTRACTORS

Table 1.4-1

WESTINGHOUSE PRESSURIZED WATER REACTOR NUCLEAR POWER PLANTS (Sheet 3 of 15)

Plant	Owner Utility	Location	Scheduled Commercial Operation	MWe Net	Number of Loops
Indian Point No. 2	Consolidated Edison Company of New York, Inc.	New York	1973	873	4
Prairie Island No. 1	Northern States Power Company	Minnesota	1973	530	2
Turkey Point No. 4	Florida Power and Light Co.	Florida	1973	745	3
Surry No. 2	Virginia Electric and Power Co.	Virginia	1973	822	3
Zion No. 1	Commonwealth Edison Company	Illinois	1973	1,050	4
Kewaunee	Wisconsin Public Service Corp.; Wisconsin Power and Light Co.; Madison Gas and Electric Co.	Wisconsin	1974	560	2
Prairie Island No. 2	Northern States Power Company	Minnesota	1974	530	2
Takahama No. 1	The Kansai Electric Power Company, Inc.	Japan	1974	781	3

1.4-19

KNU 5 & 6 FSAR

IDENTIFICATION OF AGENTS AND CONTRACTORS

Table 1.4-1

WESTINGHOUSE PRESSURIZED WATER REACTOR NUCLEAR POWER PLANTS (Sheet 4 of 15)

Plant	Owner Utility	Location	Scheduled Commercial Operation	MWe Net	Number of Loops
Zion No. 2	Commonwealth Edison Company	Illinois	1974	1,050	4
Beaver Valley No. 1	Duquesne Light Company; Ohio Edison Company; Pennsylvania Power Company	Pennsylvania	1976	852	3
Doel No. 1	Indivision Doel	Belgium	1975	390	2
Doel No. 2	Indivision Doel	Belgium	1975	390	2
Donald C. Cook No. 1	Indiana and Michigan Electric Company (AEP)	Michigan	1975	1,090	4
Donald C. Cook No. 2	Indiana and Michigan Electric Company (AEP)	Michigan	1978	1,090	4
Indiana Point No. 3	Power Authority of the State of New York (PASNY)	New York	1976	965	4
Kori No. 1	Korea Hydro & Nuclear Power Co.	Korea	1977	564	2
Ringhals No. 2	Statens Vattenfallsverk (SSPB)	Sweden	1975	822	3

1.4-20

554

KRN 3 & 4 PSAR

IDENTIFICATION OF AGENTS AND CONTRACTORS

Table 1.4-1

WESTINGHOUSE PRESSURIZED WATER REACTOR NUCLEAR POWER PLANTS (Sheet 5 of 15)

Plant	Owner Utility	Location	Scheduled Commercial Operation	MWe Net	Number of Loops
Trojan	Portland General Electric Co.; Eugene Water and Electric Board; Pacific Power and Light Company	Oregon	1976	1,130	4
Almaraz No. 1	Union Electrica, S. A.; Compania Sevillana de Electricidad, S. A.; Hidroelectrica Espanola, S. A.	Spain	1981	902	3
Diablo Canyon No. 1	Pacific Gas and Electric Co.	California	1981	1,084	4
Joseph M. Farley No. 1	Alabama Power Company	Alabama	1977	829	3
Lemoniz No. 1	Iberduero, S. A.	Spain	1984	902	3
Salem No. 1	Pacific Service Electric and Gas Company; Philadelphia Electric Co.; Atlantic Electric Co.; Delmarva Power and Light Co.	New Jersey	1977	1,090	4

1.4-21

KNU 5 & 6 FSAR

IDENTIFICATION OF AGENTS AND CONTRACTORS



Table 1.4-1

WESTINGHOUSE PRESSURIZED WATER REACTOR NUCLEAR POWER PLANTS (Sheet 6 of 15)

Plant	Owner Utility	Location	Scheduled Commercial Operation	MWe Net	Number of Loops
Sequoyah No. 1	Tennessee Valley Authority	Tennessee	1980	1,148	4
Almaraz No. 2	Union Electrica, S. A.; Compania Sevillana de Electricidad, S. A.; Hidroelectrica Espanola, S. A.	Spain	1983	902	3
Angra dos Reis	Furnas-Centraes Electricas, S. A.	Brazil	1981	626	2
Asco No. 1	Fuerzas Electricas de Cataluna, S. A. (FECSA)	Spain	1984	902	3
Diablo Canyon No. 2	Pacific Gas and Electric Co.	California	1982	1,106	4
Joseph M. Farley No. 2	Alabama Power Company	Alabama	1981	829	3
North Anna No. 1	Virginia Electric and Power Co.	Virginia	1977	898	3
North Anna No. 2	Virginia Electric and Power Co.	Virginia	1981	898	3

1.4-22

KNU 5 & 6 FSAR

IDENTIFICATION OF AGENTS AND CONTRACTORS

Table 1.4-1

WESTINGHOUSE PRESSURIZED WATER REACTOR NUCLEAR POWER PLANTS (Sheet 7 of 15)

Plant	Owner Utility	Location	Scheduled Commercial Operation	MWe Net	Number of Loops
Ohi No. 1	The Kansai Electric Power Company, Inc.	Japan	1977	1,122	4
Ohi No. 2	The Kansai Electric Power Company, Inc.	Japan	1979	1,122	4
Ringhals No. 3	Statens Vattenfallsverk (SSPB)	Sweden	1981	900	3
Sequoyah No. 2	Tennessee Valley Authority	Tennessee	1981	1,148	4
Asco No. 2	Fuerzas Electricas de Cataluna, S. A. (FECSA); Empresa Nacional Hidroelectrica del Ribagorzana, S. A. (ENHER); Fuerzas Hidroelectricas del Segre S. A.; Hidro-electrica de Cataluna, S. A.	Spain	1985	902	3
Krsko	Savske Elektrarne Ljubljana; Slovenia; Electroprivreda Zagreb, Croatia	Yugoslavia	1981	615	2

1.4-23

KNU 5 & 6 FSAR

IDENTIFICATION OF AGENTS AND CONTRACTORS

본 문서는 한국수력원자력(주)이 정보 공개용으로 작성한 문서입니다.

Table 1.4-1

WESTINGHOUSE PRESSURIZED WATER REACTOR NUCLEAR POWER PLANTS (Sheet 8 of 15)

Plant	Owner Utility	Location	Scheduled Commercial Operation	MWe Net	Number of Loops
Lemoniz No. 2	Iberduero, S. A.	Spain	1981	902	3
Watts Bar No. 1	Tennessee Valley Authority	Tennessee	1982	1,177	4
William B. McGuire No. 1	Duke Power Company	North Carolina	1981	1,180	4
Millstone No. 3	Northeast Nuclear Energy Co.	Connecticut	1986	1,156	4
Ringhals No. 4	Statens Vattenfallsverk (SSPB)	Sweden	1982	900	3
Salem No. 2	Public Service Electric and Gas Company; Philadelphia Electric Co.; Atlantic Electric Co.; Delmarva Power and Light Co.	New Jersey	1981	1,115	4
Virgil C. Summer	South Carolina Electric and Gas Company	South Carolina	1982	900	3
Watts Bar No. 2	Tennessee Valley Authority	Tennessee	1983	1,177	4

1.4-24

KNU 5 & 6 FSAR

IDENTIFICATION OF  
AGENTS AND CONTRACTORS

Table 1.4-1

WESTINGHOUSE PRESSURIZED WATER REACTOR NUCLEAR POWER PLANTS (Sheet 9 of 15)

Plant	Owner Utility	Location	Scheduled Commercial Operation	MWe Net	Number of Loops
William B. McGuire No. 2	Duke Power Company	North Carolina	1982	1,180	4
Byron No. 1	Commonwealth Edison Co.	Illinois	1983	1,120	4
Catawba No. 1	Duke Power Company	South Carolina	1983	1,153	4
Comanche Peak No. 1	Texas Utilities Generating Co.	Texas	1982	1,150	4
Kori No. 2	Korea Hydro & Nuclear Power Co.	Korea	1983	605	2
Seabrook No. 1	Public Service Company of New Hampshire; United Illuminating Company	New Hampshire	1983	1,200	4
South Texas Project Unit No. 1	Houston Lighting and Power Co.; Central Power and Light Co.; City Public Service of San Antonio; City of Austin, Texas	Texas	1984	1,250	4
Sayago No. 1	Iberduero, S. A.	Spain	1986	1,000	3

1.4-25

554

KRN 3 & 4 FSAR

IDENTIFICATION OF AGENTS AND CONTRACTORS

Table 1.4-1

WESTINGHOUSE PRESSURIZED WATER REACTOR NUCLEAR POWER PLANTS (Sheet 10 of 15)

Plant	Owner Utility	Location	Scheduled Commercial Operation	MWe Net	Number of Loops
Vandellos No. 2	Electrica de Cataluna S. A.; Hidroelectrica de Cataluna S. A.; Fuerzas Electricas Del Segre	Spain	1986		
Beaver Valley No. 2	Duquesne Light Company; Ohio Edison Company; Pennsylvania Power Co.; Cleveland Electric Illuminating Company; Toledo Edison Company	Pennsylvania	1987	852	3
Braidwood No. 1	Commonwealth Edison Company	Illinois	1985	1,120	4
Callaway No. 1	SNUPPS - Union Electric Co.	Missouri	1982	1,150	4
Jamesport No. 1	Long Island Lighting Company; New York State Electric and Gas Corp.	New York	(5)	1,150	4
NORCE (Aguirre)	Puerto Rico Water Resources Authority	Puerto Rico	(5)	583	2

1.4-26

KNU 5 & 6 FSAR

IDENTIFICATION OF AGENTS AND CONTRACTORS



Table 1.4-1

WESTINGHOUSE PRESSURIZED WATER REACTOR NUCLEAR POWER PLANTS (Sheet 11 of 15)

Plant	Owner Utility	Location	Scheduled Commercial Operation	MWe Net	Number of Loops
Seabrook No. 2	Public Service Company New Hampshire; United Illuminating Company	New Hampshire	1984	1,200	4
Braidwood No. 2	Commonwealth Edison Company	Illinois	1986	1,120	4
Byron No. 2	Commonwealth Edison Company	Illinois	1984	1,120	4
Catawba No. 2	Duke Power Company	South Carolina	1984	1,153	4
Comanche Peak No. 2	Texas Utility Generating Co.	Texas	1983	1,150	4
South Texas Project Unit No. 2	Houston Lighting and Power Co.; Central Power and Light Co.; City Public Service of San Antonio; City of Austin, Texas	Texas	1984	1,250	4

1.4-27

IDENTIFICATION OF  
AGENTS AND CONTRACTORS

KNJ 5 & 6 FSAR

본 문서는 한국수력원자력(주)이 정보 공개용으로 작성한 문서입니다.

Table 1.4-1

WESTINGHOUSE PRESSURIZED WATER REACTOR NUCLEAR POWER PLANTS (Sheet 12 of 15)

Plant	Owner Utility	Location	Scheduled Commercial Operation	MWe Net	Number of Loops
Sterling	SNUPPS - Rochester Gas and Electric Corporation; Central Hudson Gas and Electric Corporation; Niagara Mohawk Power Corporation; Orange and Rockland Utilities, Inc.	New York	(5)	1,150	4
Maanshan No. 1	Taiwan Power Company	Taiwan	1983	892	3
Wolf Creek Unit No. 1	SNUPPS - Kansas Gas and Electric Company; Kansas City Power and Light Company	Kansas	1983	1,183	4
Alvin W. Vogtle No. 1	Georgia Power Company; Oglethorpe Electric Membership Corp., Municipal Authority of Georgia; City of Dalton, Georgia	Georgia	1985	1,113	4

1.4-28

KNU 5 & 6 FSAR

IDENTIFICATION OF AGENTS AND CONTRACTORS

Table 1.4-1

WESTINGHOUSE PRESSURIZED WATER REACTOR NUCLEAR POWER PLANTS (Sheet 13 of 15)

Plant	Owner Utility	Location	Scheduled Commercial Operation	MWe Net	Number of Loops
Alvin W. Vogtle No. 2	Georgia Power Company Oglethorpe Electric Membership Corp., Municipal Authority Georgia; City of Dalton, Georgia	Georgia	1987	1,113	4
Callaway No. 2	SNUPPS - Union Electric Company	Missouri	1988	1,150	4
NEP-1	New England Power Company	Maine	(5)	1,150	4
Fort Calhoun No. 2	Omaha Public Power District; Nebraska Public Power District	Nebraska	(5)	1,136	4
Jamesport No. 2	Long Island Lighting Company; New York State Electric and Gas Corp.	New York	(5)	1,150	4
Haven No. 1	Wisconsin Electric Power Co.; Wisconsin Power and Light Co.; Wisconsin Public Service Corp.	Wisconsin	(5)	900	3

1.4-29

KNU 5 & 6 FSAR

IDENTIFICATION OF AGENTS AND CONTRACTORS

본 문서는 한국수력원자력(주)이 정보 공개용으로 작성한 문서입니다.

Table 1.4-1

WESTINGHOUSE PRESSURIZED WATER REACTOR NUCLEAR POWER PLANTS (Sheet 14 of 15)

Plant	Owner Utility	Location	Scheduled Commercial Operation	MWe Net	Number of Loops
Marble Hill No. 1	Public Service Company of Indiana, Inc.; Northern Indiana Public Service Company; East Kentucky Power Corp. Inc.; Wabash Valley Power Association	Indiana	1984	1,130	4
Sears Island	Central Maine Power Company	Maine	(5)	1,200	4
Maanshan No. 2	Taiwan Power Company	Taiwan	1984	892	3
Marble Hill No. 2	Public Service Company of Indiana, Inc.; Northern Indiana Public Service Company; East Kentucky Power Assoc.	Indiana	1985	1,130	4
Shearon Harris No. 1	Carolina Power and Light Co.	North Carolina	1984	900	3
NEP-2	New England Power Company	Maine	(5)	1,150	4
Shearon Harris No. 2	Carolina Power and Light Co.	North Carolina	1987	900	3

1.4-30

KNU 5 & 6 FSAR

IDENTIFICATION OF AGENTS AND CONTRACTORS

Table 1.4-1

WESTINGHOUSE PRESSURIZED WATER REACTOR NUCLEAR POWER PLANTS (Sheet 15 of 15)

Amendment 554  
2016.07.22

Plant	Owner Utility	Location	Scheduled Commercial Operation	MWe Net	Number of Loops
Shearon Harris No. 4	Carolina Power and Light Co.	North Carolina	1989	900	3
Shearon Harris No. 3	Carolina Power and Light Co.	North Carolina	1991	900	3
Napot Point No. 1	National Power Corp.	Philippines	1985	620	2
Kori Unit 3	Korea Hydro & Nuclear Power Co.	Korea	1984	990	3
Kori Unit 4	Korea Hydro & Nuclear Power Co.	Korea	1985	990	3
Hanbit Unit 1	Korea Hydro & Nuclear Power Co.	Korea	1986	990	3
Hanbit Unit 2	Korea Hydro & Nuclear Power Co.	Korea	1987	990	3

.1.4-31

KRN 3 & 4 FSAR

554

IDENTIFICATION OF  
AGENTS AND CONTRACTORS



Table 1.4-2

OPERATIONAL EXPERIENCE WITH UNITS DESIGNED AND CONSTRUCTED BY  
GEC TURBINE GENERATORS LTD

Authority	Installation	Reactor	Turbine Generator Rating MW	Speed rpm	TSV press Mpa gauge	Service Year	Operational Hours
HEPC of Ontario	Douglas Point	PHWR	220	1800	4.0	1967	43,000 app
CEGB	Winfrith Heath	SGHWR	100	3000	6.3	1967	42,000
	Dodewaard (Manufactured under license by Stork Rotterdam)	BWR(G.E.)	54	3000	6.6	1968	62,320
Atomic Energy Commission of India	Rajasthan 1 (R.A.P.F. 1)	PHWR	220	3000	4.0	1972	15,000
Swedish State Power Board	Ringhals 1	BWR(ASEA- Atom)	400	3000	6.7	1975	11,000
Swedish State Power Board	Ringhals 2	BWR(ASEA- Atom)	400	3000	6.7	1975	7,000
Korea Electric Co.	Ko-Ri 1	PWR(WECa)	600	1800	5.3	1977	35,000 app

1.4-32

KNU 5 & 6 FSAR

IDENTIFICATION OF  
AGENTS AND CONTRACTORS

Table 1.4-3

UNITS GEC TURBINE GENERATORS LTD IS CURRENTLY SUPPLYING (Sheet 1 of 2)

Authority	Installation	Reactor	Turbine Generator Rating MW	Speed rpm	TSV Press MPa Gauge	Service Year
Atomic Energy Commission of India	Rajasthan (RAPP 2)	PHWR	220	3000	4.0	1977
Atomic Energy Commission of India	Kalpakkam 1 (MAPP 1)	PHWR	236	3000	4.0	1977
Atomic Energy Commission of India	Kalpakkam 2 (MAPP 2)	PHWR	236	3000	4.0	1979
Southern California Edison Co	San Onofre 2	PWR(Comb Eng)	1180	1800	5.9	1980
Detroit Edison	Enrico Fermi	BWR(G.E.)	1280	1800	6.7	1980
Southern California Edison Co	San Onofre 3	PWR(Comb Eng)	1180	1800	5.9	1981
Korea Hydro & Nuclear Power Co.	Ko-Ri 2	PWR(WECO.)	650	1800	6.1	1983

1.4-33

554

Amendment 554  
2016.07.22

KRN 3 & 4 FSAR

IDENTIFICATION OF  
AGENTS AND CONTRACTORS

본 문서는 한국수력원자력(주)이 정보 공개용으로 작성한 문서입니다.

Table 1.4-3

UNITS GEC TURBINE GENERATORS LTD IS CURRENTLY SUPPLYING (Sheet 2 of 2)

Authority	Installation	Reactor	Turbine Generator Rating MW	Speed rpm	TSV Press MPa Gauge	Service Year
Atomic Energy Commission of India	Narora 1) major portion	PHWR	236	3000	4.0	1980
Atomic Energy Commission of India	Narora 2) manuf under license by HEIL India	PHWR	236	3000	4.0	1981

NOTES: From the contracts mentioned, GEC has engineered and built plants for water cooled reactors having:

1. Suitable physical and control interfaces and also appropriate control equipment required for safe and efficient operation of reactors and turbines
2. Specialized equipment for moisture removal and reheating of wet steam and for control of drain disposal, or reheat temperature, etc.
3. Specialized features for protection of the high pressure turbine horizontal joint and other sealing faces against erosion by any leaking wet stream
4. Features for protection of the turbine generator against overspeed by steam stored in the separator/reheater vessels.
5. These plants are cancelled.

1.4-34

KNU 5 & 6 FSAR

IDENTIFICATION OF  
AGENTS AND CONTRACTORS

Table 1.4-4

HP TURBINE COMPARATIVE DESIGN RATING PARAMETERS

Design Rating Parameters	System Frequency	60 Hz	60 Hz	50 Hz	60 Hz
	Rotational Speed	1800 rpm	1800 rpm	3000 rpm	1800 rpm
	Units				
P - HP turbine inlet pressure	psia	909	733	915	778
$\frac{(Gv)}{N}$ - volumetric flow parameter	cu ft/s	840	621	540	1105
$T_i$ - average torque developed in each HP turbine stage	lb ft	98722	52767	61900	103287
1st stage mean dia	in.	62.94	66.29	49.04	64.1
1st stage blade height	in.	4.0	3.13	2.94	4.8
last stage blade height	in.	11.0	7.29	10.38	12.1
S - sealing duty coefficient	lb/in.	41300	43600	52000	46600

1.4-35

KNU 5 & 6 FSAR

IDENTIFICATION OF AGENTS AND CONTRACTORS

Table 1.4-5

COMPARISON OF PRINCIPAL PHYSICAL DIMENSIONS AND WEIGHTS  
OF SIMILAR LARGE CYLINDERS

HP TURBINE

	Units	KNU 5 & 6	KORI 1	PETERHEAD IP	SAN ONOFRE 2 AND 3
Total weight of turbine cylinder	lb	502,000	504,000	340,480	504,000
Rotor weight	lb	128,000	128,000	71,680	128,000
Rotor bearing span	in.	259	259	175	259
Rotor maximum diameter	in.	58.0	59.0	57.5	58.0
Max. rotor bearing diameter	in.	30.0	30.0	20.0	30.0
Max. casing diameter	in.	138.0	140.0	130.0	140.0

1.4-36

KNU 5 & 6 FSAR

IDENTIFICATION OF  
AGENTS AND CONTRACTORS



Table 1.4-6

COMPARISON OF PRINCIPAL BLADING PARAMETERS AND OF BLADE AND ROTOR STRESSING OF SIMILAR LARGE CYLINDERS

	Units	KNU 5 & 6	KORI 1	PETERHEAD IP	SAN ONOFRE 2 AND 3
First stage blade height	in.	4.0	3.13	2.70	4.83
Last stage blade height	in.	11.0	7.29	8.07	12.10
Centrifugal rotor stress first stage	lb/in. <sup>2</sup>	7,700	7,652	13,440	7,750
Centrifugal rotor stress last stage	lb/in. <sup>2</sup>	9,000	8,920	19,264	9,200
Centrifugal blade stress first stage	lb/in. <sup>2</sup>	3,584	2,464	6,496	3,584
Centrifugal blade stress last stage	lb/in. <sup>2</sup>	9,184	4,480	12,096	6,496
Operating temperature first stage	°C(°F)	278(533)	264(508)	538(1,000)	271(520)
Operating temperature last stage	°C(°F)	193(380)	199(390)	260(500)	202(395)

1.4-37

KNU 5 & 6 FSAR

IDENTIFICATION OF  
AGENTS AND CONTRACTORS

Table 1.4-7

LP TURBINE COMPARATIVE DESIGN RATING PARAMETERS (Sheet 1 of 2)

Design Rating Parameters	Units	KNU 5 & 6	KORI 1	RINGHALS <sup>(a)</sup> 1 and 2	SAN ONOFRE 2 and 3
G - last stage steam flow	lbs/hr	2,281,532	2,032,224	892,152	2,494,237
Ae - last stage annulus area (2 flows)	ft <sup>2</sup>	265	265	155.4	265
( $\frac{G}{Ae}$ ) - exhaust blade loading	lbs/hr ft <sup>2</sup>	8,532	7,669	5,741	9,412
x - wetness at inlet to last stage	%	8.1	7.5	7.0	8.1
p - pressure before last stage (tip)	psia	2.1	1.8	1.53	2.4
c - velocity at discharge from last stationary blade	ft/s	900	900		900

1.4-38

KNU 5 & 6 FSAR

IDENTIFICATION OF  
AGENTS AND CONTRACTORS

Table 1.4-7

LP TURBINE COMPARATIVE DESIGN RATING PARAMETERS (Sheet 2 of 2)

Design Rating Parameters	Units	KNU 5 & 6	KORI 1	RINGHALS <sup>(a)</sup> 1 and 2	SAN ONOFRE 2 and 3
$G \frac{x}{p^2 \cdot c \beta}$ relative erosion criterion	Relative to Ko-Ri 1	0.89	1.00		0.75
a. Ringhals has a 36" last-stage blade running at 3000 rpm and is therefore not similar to the other installations. It is, however, constructed in accordance with the same basic design concepts and operates satisfactorily at substantially higher tip speeds and stresses.					

1.4-39

KNU 5 & 6 FSAR

IDENTIFICATION OF AGENTS AND CONTRACTORS

IDENTIFICATION OF  
 AGENTS AND CONTRACTORS

Table 1.4-8

COMPARISON OF PRINCIPAL PHYSICAL DIMENSIONS AND WEIGHTS  
 LP TURBINES

	Units	KNU 5 & 6	KORI 1	RINGHALS 1 AND 2	SAN ONOFRE 2 AND 3
Rotor weight	lb.	369,600	369,600	107,520	369,600
Overall rotor length	in.	419.5	419.5	299.5	419.5
Rotor maximum diameter	in.	90	90	64	90
Max bearing diameter	in.	30	30	19	30
Max casing diameter	in.	220	220	146	220

IDENTIFICATION OF  
 AGENTS AND CONTRACTORS

Table 1.4-9  
 COMPARISON OF PRINCIPAL BLADING PARAMETERS  
 AND OF BLADE AND ROTOR STRESSING

	Units	KNU 5 & 6	KORI 1	RINGHALS 1 AND 2	SAN ONOFRE 2 AND 3
First stage blade height	in.	3.0	2.5	1.7	3.0
Last stage blade height	in.	45.0	45.0	36.0	45.0
Centrifugal rotor stress					
first stage	lb/in. <sup>2</sup>	43,000	42,744	36,064	43,000
last stage	lb/in. <sup>2</sup>	49,428	49,428	39,200	49,428
Centrifugal blade stress					
first stage	lb/in. <sup>2</sup>	4,256	3,808	5,376	4,480
last stage	lb/in. <sup>2</sup>	41,440	41,440	67,872	41,440
Operating temperature					
first stage	°C(°F)	267(512)	251(484)	266(510)	256(493)
last stage	°C(°F)	vacuum	vacuum	vacuum	vacuum
Wetness before last stage	%	8.1	7.5	7.0	8.1
Wetness after last stage	%	11.8	11.4	10.8	11.8



IDENTIFICATION OF  
 AGENTS AND CONTRACTORS

Table 1.4-10

SEPARATOR/REHEATER COMPARATIVE DESIGN RATING PARAMETERS

Design Rating Parameter	Units	KNU 5 and 6	SAN ONOFRE 2 and 3
G - mass flow of main cycle steam (from HP turbine exhaust)	lbs/hr	10,293,177	10,937,329
x - inlet wetness of steam	%	12.8	11.8
p - pressure of main steam	psia	195	173
T - temperature to which steam is reheated	$^{\circ}\text{C}$ ( $^{\circ}\text{F}$ )	267 (512.6)	257 (495)
$\Delta T$ - (live steam temperature - T)	$^{\circ}\text{C}$ ( $^{\circ}\text{F}$ )	14 (25)	14 (25)
A - total reheater heat exchange surface	$\text{ft}^2$	260,000	468,000

IDENTIFICATION OF  
 AGENTS AND CONTRACTORS

Table 1.4-11

SEPARATOR/REHEATER COMPARATIVE DESIGN PARAMETERS

	KNU 5 & 6	SAN ONOFRE	RINGHALS
No. Vessels	2	2	2
Overall length, m	26.2 (85.96')	37.2	12.8
Shell diameter, mm	4115 (13.5')	4115	3658
Shell thickness, mm	38 (1.5")	38	32
Total tube length, m			
Live steam	41,400 (135.833')	51,646	25,346
Bled steam	24,330 (79,827')	67,073	-
Tube surface m <sup>2</sup> /m (1.20 ft <sup>2</sup> /ft)	0.366	0.366	0.247
Tube material	M.S.	M.S.	S.S.
Tubeplate material	M.S.	M.S.	M.S. (S.S. clad)
Design pressure, kPa	1,450 (210.3 psi)	1,379	1,379
Design temperature, °C	205 (401F)	198	198
Design code	BS1500	ASME VIII Div. 1	Swedish Stds and ASME VIII

KRN 3 & 4 FSAR

IDENTIFICATION OF  
AGENTS AND CONTRACTORS

Table 1.4-12


PRINCIPAL GENERATOR DESIGN PARAMETERS

Parameter	units	KRN 1	KRN 3 & 4	ENRICO FERMI
Output	MW/MVA	595/700	1,100/1,222	1,215/1,350
Voltage	kV	22	22	22
Frequency	Hz	60	60	60
Speed	rpm	1,800	1,800	1,800
Rotor body diameter	mm	1,651	1,708.2	1,651
Rotor body length	mm	5,182	7,500	8,407
Air gap length	mm	83.8	120.9	71.1
No. of stator slots		66	72	72
Current/ conductor	A	9,185	10,692	8,857
Stator current density	A/mm <sup>2</sup>	LNB 9.48 LFB 8.01	LNB 8.70 LFB 7.10	LNB 11.14 LFB 9.56
Rotor turns/ pole		43	46	43
Rotor CMR current	A	4,715	5,436	5,095
Rotor current Density	A/mm <sup>2</sup>	6.85	7.81	7.40
stator slot width	mm	38.4	43.4	33.1
Bar bumping force	kg/mm	1.13	1.3	1.21
Peak airgap flux density	Tesla	1.096	0.92	1.12
Electric loading	ac/m.	212,760	251,322	226,564

433

390

1.5




## 1.5 REQUIREMENTS FOR FURTHER TECHNICAL INFORMATION

This design is based upon proven concepts which have been developed and successfully applied to the design of pressurized water reactor systems. There are currently no areas of research and development which are required for operation of this plant.

Reference 1 presents descriptions of those safety-related Research and Development Programs which have been carried out for, by, or in conjunction with Westinghouse Nuclear Energy Systems, and which are applicable to Westinghouse pressurized water reactors.


### 1.5.1 REFERENCES

1. Eggleston, F. T. (Ed.), "Safety-Related Research and Development for Westinghouse Pressurized Water Reactors, Program Summaries, Winter 77 - Summer 78 Edition," WCAP-8768, Oct., 1978





1.6



## 1.6 MATERIAL INCORPORATED BY REFERENCE

### 1.6.1 WESTINGHOUSE TOPICAL REPORTS

This section lists those Westinghouse topical reports, referenced throughout this FSAR, which provide NRC-required information additional to that provided in Table 1.6-1. These reports have been filed separately with the NRC in support of similar applications.

The letter "A" appended to the WCAP or revision number indicates that the NRC review is complete and an acceptance letter has been issued.

Report	Section(s) Referenced
Oelhoeft, J. E., The Doppler Effect for a Non-Uniform Temperature Distribution in Reactor Fuel Elements, <u>WCAP-2048</u> , July, 1962.	4.3
Balfour, M. G., Christensen, J. A., and Ferrari, H. M., In-Pile Measurement of UO <sub>2</sub> Thermal Conductivity, <u>WCAP-2923</u> , 1966.	4.4
Hetsroni, G., Hydraulic Tests of the San Onofre Reactor Model, <u>WCAP-3269-8</u> , June, 1964.	4.4
Barry, R. F., LEOPARD, A Spectrum Dependent Non-Spatial Depletion Code for the IBM-7094, <u>WCAP-3269-26</u> , September, 1963.	4.3, 15.0, 15.4
Nodvik, R. J., Saxton Core II Fuel Performance Evaluation, <u>WCAP-3385-56, Part II</u> , Evaluation of Mass Spectrometric and Radiochemical Analyses of Irradiated Saxton Plutonium Fuel, July, 1970.	4.3, 4.4
Poncelet, C. G. and Christie, A. M., Xenon-Induced Spatial Instabilities in Large PWRs, <u>WCAP-3680-20</u> , (EURAE-1974) March, 1968.	4.3
Skogen, F. B. and McFarlane, A. F., Control Procedures for Xenon Induced X-Y Instabilities in Large PWRs, <u>WCAP-3680-21</u> , (EURAE-2111) February, 1969.	4.3
Skogen, F. B. and McFarlane, A. F., Xenon-Induced Spatial Instabilities in Three-Dimensions, <u>WCAP-3680-22</u> (EURAE-2116), September, 1969.	4.3
Cermak, J. O., et al., Pressurized Water Reactor pH - Reactivity Effect Final Report, <u>WCAP-3696-8</u> (EURAE-2074), October, 1968.	4.3
Christensen, J. A., Allio, R. J. and Biancheria, A., Melting Point of Irradiated UO <sub>2</sub> , <u>WCAP-6065</u> , February, 1965.	4.2, 4.4

본 문서는 한국수력원자력(주)이 정보 공개용으로 작성한 문서입니다.  
KRN 3 & 4 FSAR

Report	Section(s) Referenced
Poncelet, C. G., Burnup Physics of Heterogeneous Reactor Lattices, <u>WCAP-6069</u> , June, 1965.	4.4
Poncelet, C. G., LASER - A Depletion Program for Lattice Calculations Based on MUFT and THERMOS, <u>WCAP-6073</u> , April, 1966.	4.3
Nodvik, R. J., et al., Supplementary Report on Evaluation of Mass Spectrometric and Radio-chemical Analyses of Yankee Core 1 Spent Fuel, Including Isotopes of Elements Thorium Through Curium, <u>WCAP-6086</u> , August, 1969.	4.3
Chelemer, H., Weisman, J. and Tong, L. S., Sub-channel Thermal Analysis of Rod Bundle Cores, <u>WCAP-7015</u> , Revision 1, January 1969.	4.4
Burnett, T. W. T., Reactor Protection System Diversity in Westinghouse Pressurized Water Reactors, <u>WCAP-7306</u> , April, 1969.	7.2, 15.4
Szyslowski, J. J., and Salvatori, R., Determination of Design Pipe Breaks for the Westinghouse Reactor Coolant System, <u>WCAP-7503</u> , February, 1972.	5.2
Barry, R. F., et al., The PANDA Code, <u>WCAP-7557-A</u> , January, 1975, and <u>WCAP-7048-P-A</u> , January, 1975, (Proprietary).	4.3
Morrone, A., Seismic Vibration Testing with Sine Beats, <u>WCAP-7558</u> , October 1971.	3.10
Risher, D. H., Jr., An Evaluation of the Rod Ejection Accident in Westinghouse Pressurized Water Reactors Using Spatial Kinetics Methods, <u>WCAP-7588</u> , Revision 1-A, January, 1975.	3A, 15.4
Katz, D. H., Solid-State Logic Protection System Description, <u>WCAP-7672</u> , May, 1971 (Non-Proprietary), and <u>WCAP-7488-L</u> , March, 1971 (Proprietary).	7.1, 7.2, 7.3
Swogger, J. W., Testing of Engineered Safety Features Actuation System, <u>WCAP-7705</u> , Revision 2, January 1976. (Information only; i.e., not a generic topical WCAP).	7.3
Gangloff, W. C. and Loftus, W. D., An Evaluation of Solid-State Logic Reactor Protection in Anticipated Transients, <u>WCAP-7706</u> , February, 1973.	3.1, 4.6, 7.1, 7.2
Golik, M. S., Sensitized Stainless Steel in Westinghouse PWR Nuclear Steam Supply Systems, <u>WCAP-7735</u> (Non-Proprietary), August, 1971 and <u>WCAP-7477-L</u> (Proprietary).	5.2
Cadek, F. F., Interchannel Thermal Mixing with Mixing Vane Grids, <u>WCAP-7755-A</u> , January, 1975.	4.4

Report	Section(s) Referenced	
Barry, R. F. and Altomare, S., The TURTLE 24.0 Diffusion Depletion Code, <u>WCAP-7758-A</u> , January, 1975 and <u>WCAP-7213-P-A</u> , January, 1975 (Proprietary).	4.3, 15.0, 15.4	
Westinghouse PWR Internals Vibration Summary 3-Loop Internals Assurance, <u>WCAP-7765-AR</u> , November, 1973.	3.9	
Mangan, M. A., Overpressure Protection for Westinghouse Pressurized Water Reactors, <u>WCAP-7769</u> Rev. 1, June, 1972.	5.2, 15.2	
Dollard, W. J., Nuclear Fuel Division Quality Assurance Program Plan, <u>WCAP-7800</u> .	3A, 4.2, Refer to a separately published QA manual.	74
Behavior of Austenitic Stainless Steel in Post Hypothetical Loss of Coolant Accident Environment, <u>WCAP-7803</u> , (Non-Proprietary), January, 1972, and <u>WCAP-7798-L</u> (Proprietary).	6.1	
Moore, J. S., Nuclear Design of Westinghouse Pressurized Water Reactors with Burnable Poison Rods, <u>WCAP-7806</u> , December, 1971 (Non-Proprietary) and <u>WCAP-9000-L, Revision 1</u> , July, 1969 (Proprietary).	4.3	
McFarlane, A. F., Core Power Capability in Westinghouse PWRs, <u>WCAP-7809</u> , December, 1971 and <u>WCAP-7267-L</u> , October, 1969 (Proprietary).	4.3	
Langford, F. L. and Nath, R. J., Evaluation of Nuclear Hot Channel Factor Uncertainties, <u>WCAP-7810</u> , December, 1971.	4.3	
Moore, J. S., Power Distribution Control of Westinghouse Pressurized Water Reactors, <u>WCAP-7811</u> , December, 1971.	4.3	
Vogeding, E. L., Seismic Testing of Electrical and Control Equipment (Low Seismic Plants), <u>WCAP-7817</u> , (Non-Proprietary), December, 1971 and <u>WCAP-7397-L</u> (Proprietary) plus supplements 1-8.	3.10	
Potochnik, L. M., Seismic Testing of Electrical 3.10 and Control Equipment (Low Seismic Plants), <u>WCAP-7397-L</u> (Proprietary) <u>WCAP-7817</u> (Non-Proprietary), <u>Supplements 1-6</u> , December, 1971.	3.10	
Reid, J. B., Seismic Testing of Electrical and Control Equipment (WCID NUCANA 7300 Series) (Low Seismic Plants), <u>WCAP-7817</u> , <u>Supplement 4</u> , November, 1972.	3.10	
Evaluation of Protective Coatings for Use in Reactor Containment, <u>WCAP-7825</u> (Non-Proprietary), December, 1971 and <u>WCAP-7198-L</u> (Proprietary).	6.1	
Carter, F. D., Inlet Orificing of Open PWR Cores, <u>WCAP-7836</u> , January, 1972.	4.4	

Report	Section(s) Referenced
Shefcheck, J., Application of the THINC Program to PWR Design, <u>WCAP-7838</u> , January, 1972.	4.4
Kraus, S., Neutron Shielding Pads, <u>WCAP-7870</u> , May, 1972.	3.9
Burnett, T. W. T., et al., "LOFTRAN Code Description," <u>WCAP-7907-P-A</u> (Proprietary) and <u>WCAP-7907-A</u> (Non-Proprietary), April 1984.	5.2, 15.0, 15.1, 15.2, 15.3, 15.4, 15.5, 15.6
Hargrove, H. G., "FACTRAN - A FORTRAN-IV Code for Thermal Transients in a UO <sub>2</sub> Fuel Rod," <u>WCAP-7908-A</u> , December 1989.	15.0, 15.3, 15.4
McFarlane, A. F., Power Peaking Factors, <u>WCAP-7912-A</u> , January, 1975.	4.3, 4.4
Reid, J. B., Process Instrumentation for Westinghouse Nuclear Steam Supply System <u>WCAP-7913</u> , March, 1973.	7.2, 7.3
Novendstern, E. H. and Sandberg, R.O., Single Phase Local Boiling and Bulk Boiling Pressure Drop Correlations, <u>WCAP-7916</u> , June, 1972.	4.4
Damping Values of Nuclear Plant Components, <u>WCAP-7921-AR</u> , May, 1974.	3A, 3.7
Hazelton, W. S., et al., Basis for Heatup and Cooldown Limit Curves, <u>WCAP-7924-A</u> , April, 1975.	5.3
PWR Flecht Final Report, <u>WCAP-7931</u> , October, 1972.	15.6
Gesinski, T. L., "Fuel Assembly Safety Analysis 3.7 for Combined Seismic and Loss of Coolant Accident" <u>WCAP-7950</u> , July, 1972.	3.7
Hochreiter, L. E., Chelemer, H. and Chu, P. T., THINC-IV An Improved Program for Thermal-Hydraulic Analysis of Rod Bundle Cores, <u>WCAP-7956</u> , June, 1973.	4.4
Motley, F. E. and Cadek, F. F., DNB Tests Results for New Mixing Vane Grids (R), <u>WCAP-7958-A</u> , January, 1975.	4.4
Motely, F. E. and Cadek, F. F., DNB Test Results for R Grid Thimble Cold Wall Cells, <u>WCAP-7958-Addendum 1-A</u> , January, 1975.	4.4
Cadek, F. F., Motley, F. E. and Dominicis, D. P., Effect of Axial Spacing on Interchannel Thermal Mixing with the R Mixing Vane Grid, <u>WCAP-7959-A</u> , January, 1975.	4.4
Lee, J. C., et al., Axial Xenon Transient Tests at the Rochester Gas and Electric Reactor, <u>WCAP-7964</u> , June, 1971.	4.3
Risher, D. H., Jr. and Barry, R. F., TWINKLE -A Multi-Dimensional Neutron Kinetics Computer Code, <u>WCAP-8028-A</u> , January, 1975 (Non-Proprietary) and <u>WCAP-7979-P-A</u> (Proprietary).	15.0, 15.4



Report	Section(s) Referenced
Reactor Coolant Pump Integrity in LOCA, <u>WCAP-8163</u> , September 1973.	5.4
Kelly, R. D., et al., Calculational Model for Core Reflooding After a Loss of Coolant Accident (WREFLOOD Code), <u>WCAP-8171</u> , June, 1974 (Non-Proprietary) and <u>WCAP-8170</u> , June, 1974 (Proprietary).	15.6
Pipe Breaks for the LOCA Analysis of the Westinghouse Primary Coolant Loop, <u>WCAP-8172-A</u> , (Non-Proprietary), January, 1975 and <u>WCAP-8082-P-A</u> , January, 1975, (Proprietary).	3.6
Operational experience with Westinghouse Cores, <u>WCAP-8183</u> , (Latest Revision).	4.2
Hochreiter, L. E., Application of the THINC IV Program to PWR Design, <u>WCAP-8195</u> , October, 1973.	4.4
Vashi, K. M. (Ed.), Documentation of Selected Westinghouse Structural Analysis Computer Codes, <u>WCAP-8252</u> , May, 1974.	3.6, 3.9
Source Term Data for Westinghouse Pressurized Water Reactors, <u>WCAP-8253</u> , Westinghouse Electric Corporation, Pittsburgh, Pa., April, 1974.	11.1
Lipchak, J. B., Nuclear Instrumentation System, <u>WCAP-8255</u> , January, 1974.	7.2, 7.7
Nakasato, S. and DeMario, E. E., Hydraulic Flow Test of the 17 x 17 Fuel Assembly, <u>WCAP-8279</u> , February, 1974.	4.2, 4.4
Gesinski, L., Chiang, D., and Nakazato, S., Safety Analysis of the 17 x 17 Fuel Assembly for Combined Seismic and Loss-of-Coolant Accident, <u>WCAP-8288</u> , December, 1973.	3.7, 4.2
Safety Analysis of the 8-Grid 17 x 17 Fuel Assembly for Combined Seismic and Loss-of-Coolant Accident, <u>WCAP-8288</u> , January, 1974.	3.7
Motley, F. E., Wenzel, A. H., Cadek, F. F., The Effect of 17 x 17 fuel Assembly Geometry on Interchannel Thermal Mixing, <u>WCAP-8299-A</u> , January, 1975.	4.4
Bordelon, F. M., et al, LOCTA-IV Program: Loss-of-Coolant Transient Analysis, <u>WCAP-8305</u> , June, 1974 and <u>WCAP-8301</u> , June, 1974 (Proprietary).	15.0, 15.6
Bordelon, F. M. et al, SATAN-VI Program: Comprehensive Space Time Dependent Analysis of Loss of Coolant, <u>WCAP-8306</u> , June, 1974 and <u>WCAP-8302</u> , June, 1974 (Proprietary).	15.0, 15.6
Prediction of the Flow-induced Vibration of Reactor Internals by Scale Model Tests, <u>WCAP-8317-A</u> , March, 1974.	3.9

KRN 3 & 4 FSAR

Report	Section(s) Referenced
Enrietto, J. F., Control of Delta Ferrite in Austenitic Stainless Steel Weldments, <u>WCAP-8324-A</u> , June, 1975.	5.2, 3A
Bordelon, F. M. and Murphy, E. T., Containment Pressure Analysis Code (COCO), <u>WCAP-8326</u> , June, 1974. (Non-Proprietary), and <u>WCAP-8327</u> , June, 1974 (Proprietary).	15.6
Westinghouse Anticipated Transients Without Trip Analysis, <u>WCAP-8330</u> , August, 1974.	4.3, 4.6, 15.1, 15.2, 15.4, 15.8
Bordelon, F. M., Massie, H. W. and Zordan, T. A., Westinghouse ECCS Evaluation Model - Summary, <u>WCAP-8339</u> , (Non-Proprietary), July, 1974.	15.6
Westinghouse ECCS Evaluation Model Sensitivity Studies, <u>WCAP-8342</u> , July, 1974 (Non-Proprietary), and <u>WCAP-8341</u> (Proprietary).	15.6
Salvatori, R., Westinghouse ECCS - Plant Sensitivity Studies, <u>WCAP-8356</u> , July, 1974 (Non-Proprietary) and <u>WCAP-8340</u> (Proprietary).	15.6
Hellman, J. M. and Yang, J. W., Effects of Fuel Densification Power Spikes on Clad Thermal Transients, <u>WCAP-8359</u> , July, 1974.	4.3
Westinghouse Nuclear Energy Systems Divisions Quality Assurance Plan, "WCAP-8370, Revision 8A, September, 1977.	3A, 17
George, R. A., et al., Revised Clad Flattening Model, <u>WCAP-8381</u> , July, 1974.	4.2
Morita, T., et al., Topical Report, Power Distribution Control and Load Following Procedures, <u>WCAP-8403</u> , September, 1974.	4.3, 4.4
Baldwin, M. S., Merrian, M. M., Schenkel, H. S., and VandeWalle, D. J., An Evaluation of Loss of Flow Accidents Caused by Power System Frequency Transients in Westinghouse PWRs, <u>WCAP-8424, Revision 1</u> , June, 1975.	15.3
Cooper, F. W. Jr., 17 x 17 Drive Line Components Test - Phase 1B, 11, 111, D-Loop - Drop and Detection, <u>WCAP-8449</u> (Westinghouse Non-Proprietary), December, 1974 and <u>WCAP-8446</u> (Proprietary).	3.9
Burke, T.M., Meyer, C. E. and Shefcheck, J., Analysis of Data from the Zion (Unit 1) ZINC Verification Test, <u>WCAP-8454</u> , December, 1974.	4.4
Bordelon, F. M., et al., Westinghouse ECCS Evaluation Model - Supplementary Information, <u>WCAP-8472-A</u> , April, 1975 (Non-Proprietary), and <u>WCAP-8471-P-A</u> , April, 1975 (Proprietary).	15.6
Meyer, C. E. and Stover, R. L., Incore Power Distribution Determination in Westinghouse Pressurized Water Reactors, <u>WCAP-8498</u> , July, 1975.	4.3

## KRN 3 & 4 FSAR

Report	Section(s) Referenced
Enrietto, J. F., Control of Delta Ferrite in Austenitic Stainless Steel Weldments, <u>WCAP-8324-A</u> , June, 1975.	5.2, 3A
Bordelon, F. M. and Murphy, E. T., Containment Pressure Analysis Code (COCO), <u>WCAP-8326</u> , June, 1974. (Non-Proprietary), and <u>WCAP-8327</u> , June, 1974 (Proprietary).	15.6
Westinghouse Anticipated Transients Without Trip Analysis, <u>WCAP-8330</u> , August, 1974.	4.3, 4.6, 15.1, 15.2, 15.4, 15.8
Bordelon, F. M., Massie, H. W. and Zordan, T. A., Westinghouse ECCS Evaluation Model - Summary, <u>WCAP-8339</u> , (Non-Proprietary), July, 1974.	15.6
Westinghouse ECCS Evaluation Model Sensitivity Studies, <u>WCAP-8342</u> , July, 1974 (Non-Proprietary), and <u>WCAP-8341</u> (Proprietary).	15.6
Salvatori, R., Westinghouse ECCS - Plant Sensitivity Studies, <u>WCAP-8356</u> , July, 1974 (Non-Proprietary) and <u>WCAP-8340</u> (Proprietary).	15.6
Hellman, J. M. and Yang, J. W., Effects of Fuel Densification Power Spikes on Clad Thermal Transients, <u>WCAP-8359</u> , July, 1974.	4.3
Westinghouse Nuclear Energy Systems Divisions Quality Assurance Plan, <u>"WCAP-8370, Revision 8A"</u> , September, 1977.	3A, 17 <span style="margin-left: 20px;">삭제</span>
George, R. A., et al., Revised Clad Flattening Model, <u>WCAP-8381</u> , July, 1974.	4.2
Morita, T., et al., Topical Report, Power Distribution Control and Load Following Procedures, <u>WCAP-8403</u> , September, 1974.	4.3, 4.4
Baldwin, M. S., Merrian, M. M., Schenkel, H. S., and VandeWalle, D. J., An Evaluation of Loss of Flow Accidents Caused by Power System Frequency Transients in Westinghouse PWRs, <u>WCAP-8424, Revision 1</u> , June, 1975.	15.3
Cooper, F. W. Jr., 17 x 17 Drive Line Components Test - Phase 1B, 11, 111, D-Loop - Drop and Detection, <u>WCAP-8449</u> (Westinghouse Non-Proprietary), December, 1974 and <u>WCAP-8446</u> (Proprietary).	3.9
Burke, T.M., Meyer, C. E. and Shefcheck, J., Analysis of Data from the Zion (Unit 1) ZINC Verification Test, <u>WCAP-8454</u> , December, 1974.	4.4
Bordelon, F. M., et al., Westinghouse ECCS Evaluation Model - Supplementary Information, <u>WCAP-8472-A</u> , April, 1975 (Non-Proprietary), and <u>WCAP-8471-P-A</u> , April, 1975 (Proprietary).	15.6
Meyer, C. E. and Stover, R. L., Incore Power Distribution Determination Westinghouse Pressurized Water Reactors, <u>WCAP-8498</u> , July, 1975.	4.3

Report	Section(s) Referenced
Bamford, W. H. and Buchalet, C. B., Methods for Fracture Mechanics Analysis of Nuclear Reactor Vessels Under Severe Thermal Transients, <u>WCAP-8510</u> , June, 1976.	3.9, 5.3
UHI Plant Internals Vibration Measurement Program and Pre and Post Hot Functional Examinations, <u>WCAP-8517</u> , March, 1975.	3.9
Motley, F.E., Wenzel, A. H. and Cadek, F. F., Critical Heat Flux Testing of 17 x 17 Fuel Assembly Geometry with 22 Inch Grid Spacing, <u>WCAP-8537</u> , May, 1975.	4.4
Buterbaugh, T. L., Julian, H. V., Tome, A.E., Westinghouse ECCS - Three Loop Plant (17 x 17) Sensitivity Studies, <u>WCAP-8573</u> , July, 1975 (Non-Proprietary) and <u>WCAP-8572</u> (Proprietary).	15.6
Caplan, J.S., "The Application of Preheat Temperatures after Welding Pressure Vessel Steels," <u>WCAP-8577</u> , February, 1976.	3A, 5.4
Butterworth, G. and Miller, R. B. "Methodology for Qualifying Westinghouse WRD Supplied NSSS Safety-Related Electrical Equipment," <u>WCAP-8587</u> , Rev. 6, November 1983.	3.10, 3.11
Environmental Qualification Data Packages <u>WCAP-8587</u> , April, 1978, Supplement 1.	3.10, 3.11
<u>WCAP-8687</u> , Supplement 2 "Equipment Qualification Test Report"	3.11
Westinghouse ECCS Evaluation Model October 1975 Version, <u>WCAP-8623</u> , November, 1975 (Non-Proprietary) and <u>WCAP-8622</u> , November, 1975 (Proprietary).	15.6
Jarecki, S. J., "General Method of Developing Multifrequency Biaxial Test Inputs for Bistables", <u>WCAP 8624</u> (Proprietary), Sept. 1975, and <u>WCAP-8695</u> (Non-Proprietary), Aug. 1975.	3.10
Dominick, I. E. and Orr, W. L., Experimental Verification of Wet Fuel Storage Criticality Analyses, <u>WCAP-8683</u> , December, 1975.	4.3
Enrietto, J. F., Delta Ferrite in Production Austenitic Stainless Steel Weldments, <u>WCAP-8693</u> , January, 1976.	5.2
MULTIFLEX, A FORTRAN-IV Computer Program for Analyzing Thermal-Hydraulic-Structure System Dynamics, <u>WCAP-8709</u> , February, 1976, (Non-Proprietary) and <u>WCAP-8708</u> , February, 1976, (Proprietary).	3.6
Eggleston, F. T., Rawlins, D. H., Petrow, J. R., Failure Mode and Effects Analysis (FMEA) of the Engineering Safeguard Features Actuation System, <u>WCAP-8760</u> (Non-Proprietary), April, 1976 and <u>WCAP-8584</u> (Proprietary).	4.6



Report	Section(s) Referenced
Eggleston, F. T., Safety-Related Research and Development for Westinghouse Pressurized Water Reactors, Program Summaries, <u>WCAP-8768</u> , Rev. 1 December, 1976.	4.2, 4.3, 5.4, 1.5
Boyd, C. N., Ciaramitaro, W. and Singleton, N. R., Verification of Neutron Pad and 17 x 17 Guide Tube Designs by Preoperational Tests on the Trojan 1 Power Plant, <u>WCAP-8780</u> , May, 1976.	3.9
Miller, J. V. (Ed.), Improved Analytical Models Used in Westinghouse Fuel Rod Design Computations, <u>WCAP-8785</u> , October, 1976.	4.2
Skaritka, J. (Ed.), Hybrid B <sub>4</sub> C Absorber Control Rod Evaluation Report, <u>WCAP-4846A</u> , October, 1977.	4.2
Julian, H. V., Tabone, C. J., Thompson, C. M., Westinghouse ECCS - Three-Loop Plant (17 x 17) Sensitivity Studies, <u>WCAP-8853</u> , September, 1976 (Non-Proprietary).	15.6
Siroky, R. M. and Marasco, F. W., 7300 Series Process Control System Noise Tests, <u>WCAP-8892-A</u> , June, 1977 (Non-Proprietary).	7.1
"Benchmark Problems Solutions Employed for Verification of the WECAN Computer Program," <u>WCAP-8929</u> , June 1977.	3.9
Risher, D. H. et al., Safety Analysis for the Revised Fuel Rod Internal Pressure Design Basis, <u>WCAP-8964</u> , June, 1977.	4.2
Skwarek, R., Johnson, W. Meyer, P., Westinghouse Emergency Core Cooling System Small Break, October 1975 Model, <u>WCAP-8971</u> (Non-Proprietary), April, 1977 and <u>WCAP-8970</u> , April, 1977 (Proprietary).	15.6
Shopsky, W.E., Failure Mode and Effects Analysis (FMEA) of the Solid State Full Length Rod Control System, <u>WCAP-8976</u> , September, 1977.	4.6
Johnson, W. J., Thompson, C. M., Westinghouse Emergency Core Cooling System Evaluation Model-Modified October, 1975 Version, <u>WCAP-9168</u> , September, 1977 (Proprietary), <u>WCAP-9169</u> , September, 1977, (Non-Proprietary).	15.6
Westinghouse ECCS Evaluation Model February, 1978 (Non-Proprietary). <u>WCAP-9220</u> and <u>WCAP-9221</u> February, 1978 (Proprietary).	15.6
Beaumont, M. D., et al. (Ed), Properties of Fuel and Core Component Materials, <u>WCAP-9224</u> , Revision 1, July, 1978"	4.2
Lang, G. B., and Cunningham, J. P., "Report on the Consequences of a Postulated Main Feedline Rupture," <u>WCAP-9230</u> , January 1978.	15.2
Witt, F. J., Bamford, W. H. Esselman, T. C., "Integrity of the Primary Piping Systems of Westinghouse Nuclear Power Plants During Postulated Seismic Events," <u>WCAP-8283</u> , March, 1977.	3.9



Report	Section(s) Referenced
Bogard, W. T., Esselman, T. C., "Combination of Safe Shutdown Earthquake and Loss-of-Coolant Accident Responses for Faulted Condition Evaluation of Nuclear Power Plants," <u>WCAP-9279</u> , March, 1978.	3.9
Altman, D. A., et. Al., "Verification of Upper Head Injection Reactor Vessel Internals by Pre-operational Tests on Sequoyah 1 Power Plant," <u>WCAP-9944</u> , July, 1981.	3.9
Hollingsworth, S. D., and Wood, D. C., "Reactor Core Response to Excessive Secondary Steam Release," <u>WCAP-9926</u> (Proprietary) and <u>WCAP-9227</u> (Non-Proprietary), January, 1978.	15.1
Camden, T. M. et. al., <u>PALADON</u> -Westinghouse Nodal Computer Code." <u>WCAP-9486</u> (December, 1978).	4.3
"Augmented Startup and Cycle 1 Physics Program Supplement 1," <u>WCAP-8576</u> , June 1976 (Non-Proprietary).	4.3
Leamer, R. D. et. al., "PUO <sub>2</sub> -UO <sub>2</sub> Fueled Critical Experiments," <u>WCAP-3726-1</u> , July 1967.	4.3
Evaluation of Steam Generator Tube, Tube Sheet and Divider Plate under combined LOCA plus SSE Conditions, <u>WCAP-7832</u> , December, 1973.	5.4
Lipchak, J. B., and Bartholomew, R. R., "Test Report Nuclear Instrumentation System Isolation Amplifier," <u>WCAP-7819-Rev-1-A</u> , April, 1975.	7.2
Garber, I., "Isolation Test Process Instrumentation Isolation Amplifier Westinghouse Computer and Instrumentation Division NUCCA 7399 Series," <u>WCAP-7862</u> , September, 1972.	7.2
<u>WCAP-8779</u> , "Corrosion Study for Determining Hydrogen Generation from Aluminum and Zinc During Post Accident Conditions," April, 1976.	6.2
Sheppard, R. M., Massie, H. W., Mark, R. H., and Docherty, P. J., "Westinghouse Mass & Energy Release Data for Containment Design," <u>WCAP-8264-P-A</u> (Proprietary), <u>WCAP-8312-A</u> , Revision 2 (Non-Proprietary) June, 1975.	6.2
Blanchard, A. E., and Katz, D. N., Solid State Rod Control System, Full Length, <u>WCAP-7778</u> , December, 1971.	7.7
Blanchard, A. E. and Calpin, J. E., Digital Rod Position Indication, <u>WCAP-8014</u> , December, 1972	7.7
Blanchard, A. E., Rod Position Monitoring, <u>WCAP-7571</u> , March, 1971.	7.7
Loving, J. J., Incore Instrumentation (Flux-Mapping System and Thermocouples), <u>WCAP-7607</u> , July 1971.	7.7

Report	Section(s) Referenced
Davidson, S. L. (Ed.) et al., "Extended Burnup Evaluation of Westinghouse Fuel," <u>WCAP-10125-P-A</u> , December 1985.	4.3
Nguyen, T. Q. et al., "Qualification of the PHOENIX-P/ANC Nuclear Design System for Pressurized Water Reactor Cores," <u>WCAP-11596-P-A</u> , June 1988 (Westinghouse Proprietary).	4.3
Liu, Y. S., Meliksetian, A., Rathkopf, J. A., Little, D. C., Nakans, F., Poploski, M. J., "ANC-A Westinghouse Advanced Nodal Computer Code," <u>WCAP-10965-P-A</u> , December 1985 (Westinghouse Proprietary).	4.3
Nuclear Regulatory Commission, Letter to All Power Reactor Licensees, from B. K. Grimes "OT Position for Review and Acceptance of Spent Fuel Storage and Handling Applications," April 14, 1978.	4.3
M. N. Baldwin, "Critical Experiments Supporting Close Proximity Water Storage of Power Reactor Fuel," <u>BAW-1484-7</u> , July 1979.	4.3
S. R. Bierman and E. D. Clayton, "Criticality Experiments with Subcritical Cluster of 2.35 wt% and 4.31 wt% <sup>235</sup> U Enriched UO <sub>2</sub> Rods in Water at a Water-to-Fuel Volume Ratio of 1.6, PNL-3314, July 1980.	4.3
Mayhue, L. T. and Yarbrough, M. B., "APOLLO-A One Dimensional Neutron Diffusion Theory Program," <u>WCAP-13524</u> , October, 1992	4.3
S. L. Davidson and W. R. Kramer, ed., "Reference Core Report VANTAGE 5 Fuel Assembly," <u>WCAP-10444-P-A</u> , September 1985 and Addendum 2A, April 1988.	4.1, 4.2, 4.3, 4.4
Letter from A. C. Thadani (NRC) to W. J. Johnson (Westinghouse), January 31, 1989, Subject: Acceptance for Referencing of Licensing Topical Report, <u>WCAP-9226-P/9227-NP</u> , "Reactor Core Response to Excessive Secondary Steam Releases."	4.4
F. E. Motley and F. F. Cadek, "DNB Test Results for R-Grid Thimble Cold Wall Cells," <u>WCAP-7695-L</u> , Addendum 1, October 1972.	4.4
"Partial Response to Request Number 1 for Additional Information on WCAP-8691, Revision 1," Letter from E. P. Rahe, Jr. (Westinghouse) to J. R. Miller (NRC), NS-EPR-2515, October 9, 1981; "Remaining Response to Request Number 1 for Additional Information on WCAP-8691, Revision 1," Letter from E. P. Rahe, Jr. (Westinghouse) to R. J. Miller (NRC), NS-EPR-2572, March 16, 1982.	4.4
Letter from C. Berlinger (NRC) to E. P. Rahe, Jr. (Westinghouse), Subject: "Request for Reduction in Fuel Assembly Burnup Limit for Calculation of Maximum Rod Burn Penalty," June 18, 1986.	4.4

Report	Section(s) Referenced
P. Schuerer and K. R. McAtee, "Extension of Methodology for Calculating Transition Core DNBR Penalties," <u>WCAP-11837-P-A</u> , January 1990.	4.4
R. A. Weiner, et al., "Improved Fuel Performance Models for Westinghouse Fuel Rod Design and Safety Evaluations," <u>WCAP-10851-P-A</u> , August 1988.	4.2, 4.4
W. J. Leech, et al., "Revised PAD Code Thermal Safety Model," <u>WCAP-8720</u> , Addendum 2, October 1982.	4.4
A. J. Frieland and S. Ray, "Improved THINC IV Modeling for PWR Core Design," <u>WCAP-12330-P-A</u> , September 1991.	4.4
Chelemer, H., Boman, L. H., and Sharp, D. R., "Improved Thermal Design Procedure," <u>WCAP-8567-P-A</u> (Proprietary) and <u>WCAP-8568-A</u> (Non-Proprietary), February 1989.	4.4, 15.1, 15.2, 15.3, 15.4, 15.5, 15.6
Letter from W. J. Johnson (Westinghouse) to R. C. Jones (USNRC), "Use of 2700°F PCT Acceptance Limit in Non-LOCA Accidents," NS-NRC-89-3466, October 1989.	15.4
Cooper, K., Starek, R. M., Miseljs, V., Sarver, S. J. and Mangan, M. A., "Overpressure Protection for Westinghouse Pressurizer Water Reactors," <u>WCAP-7769</u> , Revision 1, June 1972. (Also letter NS-CE-622 from C. Eicheldinger (Westinghouse) to D. B. Vassallo (USNRC), additional information on WCAP-7769, Revision 1.)	5.2, 15.2

#### 1.6.2 BECHTEL TOPICAL REPORTS

Bechtel Topical Reports incorporated by references are listed in Table 1.6-1.

MATERIAL INCORPORATED  
BY REFERENCE

Table 1.6-1

BECHTEL TOPICAL REPORTS (Sheet 1 of 2)

Bechtel Topical Report No.	Title	Revision Number	Section Reference	USNRC Approval Status
BC-TOP-1	Containment building liner plate design	1	3.8.1	Approved with conditions 2-7-74
BC-TOP-3-A	Tornado and extreme wind design criteria for nuclear power plants	3	3.3 3.5 3.8.1	Approved 10-4-74
BC-TOP-4-A	Seismic analyses of structures and equipment for nuclear power plants	3	3.7 3.8.1	Approved 10-31-74
BC-TOP-5-A	Prestressed concrete nuclear reactor containment structures	3	3.8.1 3A/1.18 6.2.1	Approved 3-28-75
BC-TOP-7	Full-scale buttress test for prestressed nuclear containment structures	0	3.8.1 3A/1.18	Approved 8-24-73
BC-TOP-8	Tendon end anchor reinforcement test	0	3.8.1 3A/1.18	Approved 8-24-73
BC-TOP-9-A	Design of structures for missile impact	2	3.5 3.6.5 3.8.1	Approved 11-25-74

KRN 3 & 4 FSAR

Table 1.6-1

BECHTEL TOPICAL REPORTS (Sheet 2 of 2)

Bechtel Topical Report No.	Title	Revision Number	Section Reference	USNRC Approval Status
BN-TOP-1	Testing criteria for integrated leak rate testing of primary containment structures for nuclear power plants	1	3.8.1 6.2.1	Approved 2-1-73
BN-TOP-2	Design for pipe break effects	2	3.6 3.8.1 3A/1.46	Approved 6-17-74
BN-TOP-3	Performance and sizing of dry pressure containments	3	3.8.1 6.2.1	Submitted 8-6-75
BN-TOP-4	Subcompartment pressure and temperature transient analysis	1	3.6	Approved 2-23-79
BP-TOP-1	Seismic analysis of piping systems	3	3.7 3.9	Approved 9-29-76
BQ-TOP-1	Bechtel quality assurance program for nuclear power plants	2A	Refer to a Separately Published QA Manual	Approved July 1977



## KRN 3 & 4 FSAR

### DRAWINGS AND OTHER DETAILED INFORMATION

#### 1.7 DRAWINGS AND OTHER DETAILED INFORMATION

The figures included in each chapter of FSAR are reference only and the drawings listed in Table 1.7-1 and 1.7-2 are only controlled drawings.

The drawing list contains FSAR figure & section number, drawing type, controlled drawing number, title, revision number and revision date.

However, if there is no applicable controlled drawing, the figure included in FSAR shall be deemed controlled drawing.

539

##### 1.7.1 ELECTRICAL, INSTRUMENTATION AND CONTROL DRAWINGS

Table 1.7-1 contains a list of electrical, instrumentation control drawings and the corresponding FSAR figure number if applicable. These drawings are considered necessary to evaluate the safety-related features of KRN 3&4.

539

##### 1.7.2 PIPING AND INSTRUMENTATION DIAGRAMS

Table 1.7-2 contains a list of piping and instrumentation diagram and the corresponding FSAR figure number if applicable.

The p&i legend, figures 1.1-1 and 1.1-2, provides an explanation of symbols and characters used in these FSAR figures.

##### 1.7.3 OTHER DETAILED INFORMATION

Information will be provided as requested by ROK-NRB.

539

Amendment 539  
2015. 11. 19

KRN 3&4 FSAR

1.8 Improvement Action Items For Post Fukushima Daiichi Accident

475

Improvement action items issued in the domestic NPP safety review report performed as a part of countermeasures post Fukushima Daiichi accident are described in Appendix 1A.

